

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Ventilation and Circulation	New	High Efficiency Ventilation Hoods	High Efficiency Ventilation Hoods	Standard Ventilation Hood	Per Kitchen Exhaust Hood HP	392.53	15	\$173.95	25%	45%	\$0.06	1.6	0
Lodging	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	2637.91	13	\$291.39	75%	98%	\$0.02	5.8	407
Lodging	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	894.21	13	\$96.26	75%	98%	\$0.02	6.0	158
Lodging	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	77.13	12	\$100.49	50%	95%	\$0.21	0.5	0
Lodging	Water Heat GT 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	77.13	12	\$100.49	50%	95%	\$0.21	0.5	0
Lodging	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	77.13	12	\$100.49	50%	78%	\$0.21	0.5	0
Lodging	Water Heat GT 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	77.13	12	\$100.49	50%	78%	\$0.21	0.5	0
Lodging	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	14679.75	25	\$16,515.48	5%	100%	\$0.13	0.9	0
Lodging	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	6408.42	25	\$16,515.48	25%	100%	\$0.29	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	222.24	11	\$254.34	100%	34%	\$0.19	0.5	0
Lodging	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	222.24	11	\$254.34	100%	34%	\$0.19	0.5	0
Lodging	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	437.81	11	\$617.68	100%	95%	\$0.24	0.4	0
Lodging	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	437.81	11	\$617.68	100%	95%	\$0.24	0.4	0
Lodging	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	225.62	11	\$363.34	100%	95%	\$0.27	0.4	0
Lodging	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	225.62	11	\$363.34	100%	95%	\$0.27	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	20.00	10	\$16.67	100%	25%	\$0.15	0.6	0
Lodging	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	20.00	10	\$16.67	100%	55%	\$0.15	0.6	0
Lodging	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	36919.58	14	#####	50%	95%	\$0.07	1.3	0
Lodging	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	16117.18	14	#####	50%	95%	\$0.17	0.6	0
Lodging	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	2207.97	8	\$2,328.64	50%	75%	\$0.22	0.4	0
Lodging	Water Heat GT 55 Gal	Existing	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	3925.38	7	\$1,279.14	95%	80%	\$0.08	1.2	0
Lodging	Water Heat GT 55 Gal	New	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	3925.38	7	\$1,279.14	95%	80%	\$0.08	1.2	0
Lodging	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	1474.47	14	\$430.81	100%	14%	\$0.04	2.3	0
Lodging	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	366.99	15	\$224.27	75%	90%	\$0.09	1.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	35922.19	7	\$1,250.53	95%	100%	\$0.01	11.1	0
Lodging	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	15681.77	7	\$1,250.53	75%	100%	\$0.02	4.8	0
Lodging	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	26272.53	7	\$990.91	95%	90%	\$0.01	10.2	0
Lodging	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	11469.23	7	\$990.91	75%	90%	\$0.02	4.5	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2551.29	12	\$0.00	95%	75%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2551.29	12	\$0.00	95%	75%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1800.91	12	\$0.00	95%	50%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1800.91	12	\$0.00	95%	50%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1050.53	12	\$0.00	95%	35%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1050.53	12	\$0.00	95%	35%	\$0.00	999.0	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	1200.61	12	\$111.32	95%	25%	\$0.01	6.5	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	5.50	5	\$7.38	95%	25%	\$0.40	0.2	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	49.87	5	\$5.27	95%	90%	\$0.03	2.7	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	49.87	5	\$5.27	95%	90%	\$0.03	2.7	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	2412.51	9	\$276.57	75%	85%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	2412.51	9	\$276.57	75%	85%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	1809.38	9	\$207.43	75%	75%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	1809.38	9	\$207.43	75%	75%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	1206.26	9	\$138.29	75%	50%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	1206.26	9	\$138.29	75%	50%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	1206.26	9	\$138.29	75%	35%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	1206.26	9	\$138.29	75%	35%	\$0.02	4.1	0
Lodging	Water Heat GT 55 Gal	Existing	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	44406.26	10	\$5,412.44	2%	98%	\$0.02	4.2	0
Lodging	Water Heat GT 55 Gal	New	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	19385.47	10	\$5,412.44	2%	98%	\$0.05	1.9	0
Lodging	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.32	15	\$4.24	100%	100%	\$6.91	0.0	0
Lodging	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.32	15	\$4.24	100%	100%	\$6.91	0.0	0
Lodging	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	1650.84	12	#####	75%	85%	\$1.31	0.1	0
Lodging	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	1650.84	12	#####	75%	85%	\$1.31	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.10	10	\$0.06	90%	100%	\$0.11	0.9	0
Lodging	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.10	10	\$0.06	90%	100%	\$0.11	0.9	0
Lodging	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	10275.83	2	\$336.91	75%	94%	\$0.02	3.8	0
Lodging	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	163.66	12	\$100.49	50%	95%	\$0.10	1.0	0
Lodging	Water Heat LE 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	163.66	12	\$100.49	50%	95%	\$0.10	1.0	0
Lodging	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	163.66	12	\$100.49	50%	78%	\$0.10	1.0	0
Lodging	Water Heat LE 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	163.66	12	\$100.49	50%	78%	\$0.10	1.0	0
Lodging	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	13341.89	25	\$16,515.48	5%	100%	\$0.14	0.8	0
Lodging	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	13289.04	25	\$16,515.48	25%	100%	\$0.14	0.8	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	222.24	11	\$254.34	100%	34%	\$0.19	0.5	0
Lodging	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	222.24	11	\$254.34	100%	34%	\$0.19	0.5	0
Lodging	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	437.81	11	\$617.68	100%	95%	\$0.24	0.4	0
Lodging	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	437.81	11	\$617.68	100%	95%	\$0.24	0.4	0
Lodging	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	225.62	11	\$363.34	100%	95%	\$0.27	0.4	0
Lodging	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	225.62	11	\$363.34	100%	95%	\$0.27	0.4	0
Lodging	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr	Per Residential Dishwasher	20.00	10	\$16.67	100%	25%	\$0.15	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					and 5.0 gal/cycle									
Lodging	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	20.00	10	\$16.67	100%	55%	\$0.15	0.6	0
Lodging	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	33554.87	14	#####	50%	95%	\$0.08	1.2	0
Lodging	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	33421.94	14	#####	50%	95%	\$0.08	1.2	0
Lodging	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	2006.75	8	\$2,328.64	50%	75%	\$0.24	0.4	0
Lodging	Water Heat LE 55 Gal	Existing	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	3925.38	7	\$1,279.14	95%	80%	\$0.08	1.2	0
Lodging	Water Heat LE 55 Gal	New	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	3925.38	7	\$1,279.14	95%	80%	\$0.08	1.2	0
Lodging	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	1474.47	14	\$430.81	100%	14%	\$0.04	2.3	0
Lodging	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	333.55	15	\$224.27	75%	90%	\$0.10	1.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	32311.75	7	\$1,250.53	95%	100%	\$0.01	10.0	0
Lodging	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	32183.74	7	\$1,250.53	75%	100%	\$0.01	9.9	0
Lodging	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	23454.85	7	\$990.91	95%	90%	\$0.01	9.1	0
Lodging	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	23361.93	7	\$990.91	75%	90%	\$0.01	9.1	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	5413.61	12	\$0.00	95%	75%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	5413.61	12	\$0.00	95%	75%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	3821.37	12	\$0.00	95%	50%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	3821.37	12	\$0.00	95%	50%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2229.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2229.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	2547.58	12	\$111.32	95%	25%	\$0.01	13.8	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	11.67	5	\$7.38	95%	25%	\$0.19	0.5	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	105.81	5	\$5.27	95%	90%	\$0.02	5.8	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	105.81	5	\$5.27	95%	90%	\$0.02	5.8	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	5119.13	9	\$276.57	75%	85%	\$0.01	8.7	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	5119.13	9	\$276.57	75%	85%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	3839.35	9	\$207.43	75%	75%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	3839.35	9	\$207.43	75%	75%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	2559.57	9	\$138.29	75%	50%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	2559.57	9	\$138.29	75%	50%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	2559.57	9	\$138.29	75%	35%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	2559.57	9	\$138.29	75%	35%	\$0.01	8.7	0
Lodging	Water Heat LE 55 Gal	Existing	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	40359.23	10	\$5,412.44	2%	98%	\$0.02	3.9	0
Lodging	Water Heat LE 55 Gal	New	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	40199.35	10	\$5,412.44	2%	98%	\$0.02	3.8	0
Lodging	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.31	15	\$3.28	100%	100%	\$1.17	0.1	0
Lodging	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.31	15	\$3.28	100%	100%	\$1.17	0.1	0
Lodging	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	3502.92	12	#####	75%	85%	\$0.62	0.2	0
Lodging	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	3502.92	12	#####	75%	85%	\$0.62	0.2	0
Lodging	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.09	10	\$0.54	90%	100%	\$0.09	1.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Lodging	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.09	10	\$0.54	90%	100%	\$0.09	1.1	0
Lodging	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	9339.33	2	\$336.91	75%	94%	\$0.02	3.4	0
Office	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.50	4	\$1.25	95%	86%	\$0.91	0.1	0
Office	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.52	4	\$1.25	95%	86%	\$0.87	0.1	0
Office	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.28	4	\$0.00	90%	100%	\$0.00	2,996.0	1,440
Office	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.28	4	\$0.00	90%	100%	\$0.00	2,996.0	43
Office	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	2520.25	5	\$560.06	50%	80%	\$0.07	1.3	3,017
Office	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	2520.25	5	\$560.06	50%	80%	\$0.07	1.3	71
Office	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	2600.81	10	\$91.89	100%	65%	\$0.01	17.2	0
Office	Cooling Chillers	New	Active chilled beam cooling	Active chilled beam cooling	Standard Building Design and Cooling System	Per Building	2688.20	15	#####	60%	100%	\$2.36	0.1	0
Office	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	32.03	20	\$3,206.89	95%	95%	\$12.36	0.0	0
Office	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	31.92	20	\$3,206.89	95%	95%	\$12.41	0.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	13.44	15	\$1,685.00	95%	95%	\$17.73	0.0	0
Office	Cooling Chillers	Existing	Automated control system	Automated control system	Baseline DX	Per Building	674.35	10	\$2,990.63	95%	96%	\$0.80	0.1	0
Office	Cooling Chillers	New	Automated control system	Automated control system	Baseline DX	Per Building	672.05	10	\$2,990.63	95%	96%	\$0.80	0.1	0
Office	Cooling Chillers	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	7422.19	15	\$4,024.33	25%	62%	\$0.08	1.6	0
Office	Cooling Chillers	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	4495.69	15	\$2,012.17	25%	95%	\$0.06	1.9	0
Office	Cooling Chillers	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	4480.33	15	\$2,012.17	75%	95%	\$0.06	1.9	0
Office	Cooling Chillers	Existing	Chilled Water Reset, Optimizer System for Chiller(s)	Chilled Water Reset, Optimizer System for Chiller(s)	0	Per Building	269.74	10	\$5,692.00	95%	81%	\$3.80	0.0	0
Office	Cooling Chillers	Existing	Chiller Tuneup/Diagnostics	Chiller Tuneup/Diagnostics	Existing Conditions	Per Building	1078.96	10	\$2,693.69	25%	24%	\$0.45	0.2	0
Office	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.41	20	\$0.95	90%	100%	\$0.29	0.4	0
Office	Cooling Chillers	New	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.41	20	\$0.95	90%	100%	\$0.29	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling Chillers	Existing	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.14	20	\$0.32	90%	100%	\$0.29	0.4	0
Office	Cooling Chillers	New	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.14	20	\$0.32	90%	100%	\$0.29	0.4	0
Office	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.30	20	\$0.71	90%	100%	\$0.29	0.4	0
Office	Cooling Chillers	New	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.30	20	\$0.71	90%	100%	\$0.29	0.4	0
Office	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	2697.41	15	#####	95%	75%	\$1.06	0.1	0
Office	Cooling Chillers	Existing	Cooling Tower Optimization	Cooling Tower Optimization	Existing Conditions	Per Building	42.01	8	\$493.84	10%	90%	\$2.47	0.0	0
Office	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2016.15	7	\$8,354.09	75%	85%	\$0.96	0.1	0
Office	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	138.41	20	#####	75%	99%	\$69.26	0.0	0
Office	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	137.94	20	#####	75%	99%	\$69.50	0.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2277.81	30	\$159.70	20%	84%	\$0.01	18.6	0
Office	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2270.03	30	\$159.70	80%	84%	\$0.01	18.5	0
Office	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	2157.93	7	\$2,263.96	75%	75%	\$0.24	0.4	0
Office	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2427.67	18	\$17,337.01	1%	98%	\$0.92	0.1	0
Office	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2419.38	18	\$17,337.01	1%	98%	\$0.93	0.1	0
Office	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	3417.63	13	\$1,877.70	75%	98%	\$0.08	1.4	0
Office	Cooling Chillers	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	6801.70	15	\$2,154.69	10%	66%	\$0.04	2.7	0
Office	Cooling Chillers	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	4495.69	15	\$1,077.34	10%	95%	\$0.03	3.6	0
Office	Cooling Chillers	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	4480.33	15	\$1,077.34	50%	95%	\$0.03	3.6	0
Office	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	674.35	5	\$1,202.28	50%	95%	\$0.54	0.2	0
Office	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	672.05	5	\$1,202.28	50%	95%	\$0.54	0.2	0
Office	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	3530.39	10	\$91.89	100%	65%	\$0.00	23.4	2,862

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	282.43	20	\$3,206.89	95%	95%	\$1.40	0.1	0
Office	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	273.70	20	\$3,206.89	95%	95%	\$1.45	0.1	0
Office	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	17.74	15	\$1,685.00	95%	95%	\$13.43	0.0	0
Office	Cooling DX	Existing	Automated control system	Automated control system	Baseline DX	Per Building	915.38	10	\$2,990.63	95%	96%	\$0.59	0.2	0
Office	Cooling DX	New	Automated control system	Automated control system	Baseline DX	Per Building	887.10	10	\$2,990.63	95%	96%	\$0.61	0.2	0
Office	Cooling DX	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	10075.02	15	\$4,024.33	25%	62%	\$0.06	2.1	1,210
Office	Cooling DX	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6102.53	15	\$2,012.17	25%	95%	\$0.05	2.6	1,223
Office	Cooling DX	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	5913.98	15	\$2,012.17	75%	95%	\$0.05	2.5	85
Office	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3661.52	15	\$4,780.80	95%	95%	\$0.18	0.7	0
Office	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	1662.31	5	\$910.19	95%	45%	\$0.17	0.6	0
Office	Cooling DX	Existing	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.10	15	\$0.26	90%	100%	\$0.36	0.3	0
Office	Cooling DX	New	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.10	15	\$0.26	90%	100%	\$0.36	0.3	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling DX	Existing	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.16	15	\$0.42	90%	100%	\$0.37	0.3	0
Office	Cooling DX	New	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.16	15	\$0.42	90%	100%	\$0.37	0.3	0
Office	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1903.99	15	\$2,088.52	75%	99%	\$0.16	0.8	0
Office	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1845.16	15	\$1,113.88	75%	99%	\$0.09	1.4	25
Office	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	338.92	15	\$3,250.69	95%	62%	\$1.36	0.1	0
Office	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	338.92	15	\$2,470.52	45%	80%	\$1.03	0.1	0
Office	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	8645.26	15	#####	90%	100%	\$1.18	0.1	0
Office	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2661.29	7	\$8,354.09	95%	85%	\$0.73	0.1	0
Office	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1220.51	20	#####	75%	99%	\$7.85	0.0	0
Office	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1182.80	20	#####	75%	99%	\$8.10	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	1662.31	10	\$934.79	95%	24%	\$0.10	1.1	326
Office	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3091.95	30	\$159.70	20%	84%	\$0.01	25.3	553
Office	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2996.42	30	\$159.70	80%	84%	\$0.01	24.5	54
Office	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	2558.11	10	\$4,160.88	10%	45%	\$0.29	0.4	0
Office	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	2929.22	7	\$2,263.96	95%	75%	\$0.18	0.6	0
Office	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3295.37	18	\$17,337.01	1%	98%	\$0.68	0.2	0
Office	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3193.55	18	\$17,337.01	1%	98%	\$0.70	0.2	0
Office	Cooling DX	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	9232.75	15	\$2,154.69	10%	66%	\$0.03	3.7	534
Office	Cooling DX	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	6102.53	15	\$1,077.34	10%	95%	\$0.02	4.8	523
Office	Cooling DX	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	5913.98	15	\$1,077.34	50%	95%	\$0.03	4.7	67
Office	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	915.38	5	\$1,202.28	50%	95%	\$0.40	0.3	0
Office	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	887.10	5	\$1,202.28	50%	95%	\$0.41	0.3	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	70
Office	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	2
Office	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.07	4	\$0.00	90%	100%	\$0.00	743.5	179
Office	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.07	4	\$0.00	90%	100%	\$0.00	743.5	2
Office	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	3
Office	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	0
Office	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	5640.60	10	\$91.89	100%	65%	\$0.00	32.7	1,740
Office	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	249.66	20	\$3,206.89	95%	95%	\$1.59	0.1	0
Office	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	241.27	20	\$3,206.89	95%	95%	\$1.64	0.1	0
Office	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.16	15	\$0.08	90%	100%	\$0.08	1.4	0
Office	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.16	15	\$0.08	90%	100%	\$0.08	1.4	0
Office	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.30	15	\$0.17	90%	100%	\$0.08	1.3	497

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.30	15	\$0.17	90%	100%	\$0.08	1.3	17
Office	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	587.98	15	\$1,685.00	95%	95%	\$0.41	0.3	0
Office	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	389.05	15	\$1,685.00	95%	95%	\$0.61	0.2	0
Office	Heat Pump	Existing	Automated control system	Automated control system	Baseline DX	Per Building	1649.12	10	\$2,990.63	95%	96%	\$0.33	0.3	0
Office	Heat Pump	New	Automated control system	Automated control system	Baseline DX	Per Building	1593.74	10	\$2,990.63	95%	96%	\$0.34	0.3	0
Office	Heat Pump	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	18150.85	15	\$4,024.33	25%	62%	\$0.03	3.3	832
Office	Heat Pump	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	10994.13	15	\$2,012.17	25%	95%	\$0.03	4.0	840
Office	Heat Pump	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	10624.94	15	\$2,012.17	75%	95%	\$0.03	3.9	59
Office	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3236.60	15	\$4,529.18	95%	95%	\$0.20	0.5	0
Office	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	1469.40	5	\$910.19	95%	45%	\$0.19	0.5	0
Office	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	3161.38	15	\$2,088.52	75%	99%	\$0.09	1.1	764



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	3055.22	15	\$1,113.88	75%	99%	\$0.05	2.0	16
Office	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	299.59	15	\$3,250.69	95%	62%	\$1.53	0.1	0
Office	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	299.59	15	\$2,470.52	45%	80%	\$1.17	0.1	0
Office	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	4781.22	7	\$8,354.09	95%	85%	\$0.40	0.2	0
Office	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1731.86	20	#####	75%	99%	\$5.54	0.0	0
Office	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1673.70	20	#####	75%	99%	\$5.73	0.0	0
Office	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.23	15	\$18.71	90%	100%	\$2.15	0.0	0
Office	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.23	15	\$18.71	90%	100%	\$2.15	0.0	0
Office	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	1469.40	10	\$885.59	95%	24%	\$0.11	0.9	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2733.13	30	\$159.70	20%	84%	\$0.01	19.3	160
Office	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2641.35	30	\$159.70	80%	84%	\$0.01	18.6	18
Office	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	2558.11	10	\$4,160.88	10%	45%	\$0.29	0.3	0
Office	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	5277.18	7	\$2,263.96	95%	75%	\$0.10	0.9	0
Office	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2912.94	18	\$17,337.01	1%	98%	\$0.77	0.1	0
Office	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2815.12	18	\$17,337.01	1%	98%	\$0.80	0.1	0
Office	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	19591.27	15	#####	50%	95%	\$2.18	0.1	0
Office	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	18933.37	15	#####	95%	95%	\$2.25	0.1	0
Office	Heat Pump	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	16633.44	15	\$2,154.69	10%	66%	\$0.02	5.7	367
Office	Heat Pump	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	10994.13	15	\$1,077.34	10%	95%	\$0.01	7.6	359
Office	Heat Pump	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	10624.94	15	\$1,077.34	50%	95%	\$0.01	7.3	47



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.86	15	\$1.74	90%	100%	\$0.29	0.4	0
Office	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.86	15	\$1.74	90%	100%	\$0.29	0.4	0
Office	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1649.12	5	\$1,202.28	50%	95%	\$0.22	0.4	0
Office	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1593.74	5	\$1,202.28	50%	95%	\$0.23	0.4	0
Office	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	484.54	10	\$100.00	85%	45%	\$0.04	2.6	186
Office	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	1356.70	8	\$225.00	50%	45%	\$0.03	2.7	327
Office	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	1356.70	8	\$225.00	50%	75%	\$0.03	2.7	13
Office	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	1162.89	8	\$363.17	10%	100%	\$0.07	1.5	112
Office	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	1829.78	10	\$100.00	85%	45%	\$0.01	10.0	0
Office	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	77.01	13	\$6.00	0%	85%	\$0.01	8.7	0
Office	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	3492.75	8	\$5,173.27	65%	100%	\$0.31	0.3	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	4940.41	10	\$1,131.84	10%	98%	\$0.04	2.4	1,426
Office	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.20	13	\$0.18	90%	100%	\$0.14	0.8	0
Office	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.19	13	\$0.75	90%	100%	\$0.61	0.2	0
Office	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.23	13	\$0.36	90%	100%	\$0.24	0.4	0
Office	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.06	13	\$0.13	90%	100%	\$0.35	0.3	0
Office	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.37	20	\$2.25	90%	100%	\$0.76	0.2	0
Office	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	4391.48	8	\$762.48	90%	98%	\$0.04	2.6	2,874
Office	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	4391.48	8	\$363.17	10%	99%	\$0.02	5.5	424
Office	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	48.48	10	\$100.00	85%	45%	\$0.37	0.3	0
Office	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	92.54	8	\$5,173.27	65%	100%	\$11.74	0.0	0
Office	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	130.90	10	\$1,131.84	10%	98%	\$1.56	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal Halide - Above Standard	Efficient Metal Halide	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.01	15	\$0.00	90%	100%	\$0.09	1.2	0
Office	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.03	15	\$0.01	90%	100%	\$0.06	1.8	252
Office	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.04	20	\$0.01	90%	100%	\$0.04	3.1	22
Office	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.03	20	-\$0.01	90%	100%	-\$0.03	999.0	0
Office	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	116.36	8	\$762.48	90%	98%	\$1.38	0.1	0
Office	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	116.36	8	\$363.17	10%	99%	\$0.66	0.2	0
Office	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	38.02	10	\$9.50	95%	25%	\$0.04	2.2	9

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.26	15	\$0.06	100%	100%	\$0.03	3.4	0
Office	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.39	15	\$0.08	100%	100%	\$0.03	3.7	0
Office	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.77	15	\$0.16	100%	100%	\$0.03	3.7	610
Office	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	4093.48	8	\$5,173.27	65%	100%	\$0.27	0.4	0
Office	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	28.21	16	\$12.00	95%	50%	\$0.06	1.9	46
Office	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	5790.13	10	\$1,131.84	30%	98%	\$0.04	2.8	99
Office	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	5146.79	8	\$762.48	90%	98%	\$0.03	3.1	56
Office	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	73.58	30	\$7.50	75%	95%	\$0.01	11.4	178
Office	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	73.58	30	\$7.50	75%	95%	\$0.01	11.4	3
Office	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	243.78	10	\$100.00	85%	45%	\$0.07	1.3	26
Office	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	465.33	8	\$5,173.27	65%	100%	\$2.33	0.0	0
Office	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	658.19	10	\$1,131.84	10%	98%	\$0.31	0.3	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	Per Building	0.16	5	\$0.00	90%	100%	\$0.01	10.8	991
Office	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	Per Building	0.13	2	\$0.00	90%	100%	\$0.01	6.1	0
Office	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	Per Building	0.17	12	\$0.03	90%	100%	\$0.04	2.9	2,006
Office	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	585.06	8	\$762.48	90%	98%	\$0.27	0.4	0
Office	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	585.06	8	\$363.17	10%	99%	\$0.13	0.7	0
Office	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	29.12	15	\$2.80	75%	75%	\$0.01	7.7	65
Office	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	29.12	15	\$2.80	75%	75%	\$0.01	7.7	2
Office	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	14.74	4	\$1.46	100%	20%	\$0.04	2.4	12
Office	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	14.74	4	\$1.46	100%	20%	\$0.04	2.4	0
Office	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	925.98	10	\$0.00	95%	20%	\$0.00	999.0	701
Office	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	925.98	10	\$0.00	95%	20%	\$0.00	999.0	17
Office	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.20	5	\$0.84	95%	20%	\$1.24	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.20	5	\$0.84	95%	20%	\$1.24	0.1	0
Office	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	578.72	5	\$98.01	95%	95%	\$0.05	1.8	560
Office	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	578.72	5	\$98.01	95%	95%	\$0.05	1.8	14
Office	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.01	6	\$0.00	90%	100%	\$0.00	1,630.0	5
Office	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.01	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Office	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.08	5	\$0.00	90%	100%	\$0.00	4,559.7	81
Office	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.08	5	\$0.00	90%	100%	\$0.00	4,559.7	1
Office	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0
Office	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0
Office	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	179
Office	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	10
Office	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.00	90%	100%	\$0.10	1.0	0
Office	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.00	90%	100%	\$0.10	1.0	0
Office	Room Cooling	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	8920.14	15	\$4,024.33	25%	62%	\$0.06	1.9	167



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Room Cooling	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	5403.01	15	\$2,012.17	25%	95%	\$0.05	2.3	169
Office	Room Cooling	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	5392.74	15	\$2,012.17	75%	95%	\$0.05	2.3	12
Office	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.05	12	\$0.01	90%	100%	\$0.04	2.8	8
Office	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.05	12	\$0.01	90%	100%	\$0.04	2.8	0
Office	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.49	4	\$1.25	95%	86%	\$0.93	0.1	0
Office	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.49	4	\$1.25	95%	86%	\$0.93	0.1	0
Office	Servers	Existing	Data Center - Server/Storage Consolidation	Data Center - Server/Storage Consolidation	No Consolidation	Per Building	3365.04	4	\$4,225.06	75%	80%	\$0.46	0.2	0
Office	Servers	Existing	Data Center - Server/Storage Virtualization	Data Center - Server/Storage Virtualization	No Virtualization	Per Building	3365.04	4	\$4,225.06	75%	80%	\$0.46	0.2	0
Office	Servers	New	Data Center - Server/Storage Virtualization	Data Center - Server/Storage Virtualization	No Virtualization	Per Building	3349.74	4	\$4,225.06	75%	80%	\$0.46	0.2	0
Office	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.14	4	\$0.19	90%	100%	\$0.49	0.2	0
Office	Servers	New	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.14	4	\$0.19	90%	100%	\$0.49	0.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Space Heat	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	2936.02	10	\$91.89	100%	65%	\$0.01	16.4	212
Office	Space Heat	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	685.07	15	\$1,685.00	95%	95%	\$0.35	0.3	0
Office	Space Heat	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	450.19	15	\$1,685.00	95%	95%	\$0.53	0.2	0
Office	Space Heat	Existing	Automated control system	Automated control system	Baseline DX	Per Building	978.67	10	\$2,990.63	95%	96%	\$0.55	0.2	0
Office	Space Heat	New	Automated control system	Automated control system	Baseline DX	Per Building	978.67	10	\$2,990.63	95%	96%	\$0.55	0.2	0
Office	Space Heat	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	10771.67	15	\$4,024.33	25%	62%	\$0.05	1.9	119
Office	Space Heat	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6524.50	15	\$2,012.17	25%	95%	\$0.04	2.3	120
Office	Space Heat	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6524.50	15	\$2,012.17	75%	95%	\$0.04	2.3	9
Office	Space Heat	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1722.47	15	\$2,088.52	75%	99%	\$0.17	0.6	0
Office	Space Heat	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1722.47	15	\$1,113.88	75%	99%	\$0.09	1.1	2
Office	Space Heat	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	12895.02	15	#####	90%	100%	\$0.79	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Space Heat	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2936.02	7	\$8,354.09	95%	85%	\$0.66	0.1	0
Office	Space Heat	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	760.82	20	#####	75%	99%	\$12.60	0.0	0
Office	Space Heat	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	760.82	20	#####	75%	99%	\$12.60	0.0	0
Office	Space Heat	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	3131.76	7	\$2,263.96	95%	75%	\$0.17	0.5	0
Office	Space Heat	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	9871.16	15	\$2,154.69	10%	66%	\$0.03	3.3	52
Office	Space Heat	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	6524.50	15	\$1,077.34	10%	95%	\$0.02	4.3	51
Office	Space Heat	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	6524.50	15	\$1,077.34	50%	95%	\$0.02	4.3	7
Office	Vending Machines	Existing	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	271.96	5	\$35.98	100%	50%	\$0.04	2.2	542
Office	Vending Machines	New	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	271.96	5	\$35.98	100%	50%	\$0.04	2.2	13
Office	Vending Machines	Existing	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	68.46	5	\$31.98	100%	50%	\$0.14	0.6	0
Office	Vending Machines	New	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	68.46	5	\$31.98	100%	50%	\$0.14	0.6	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Vending Machines	Existing	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.02	90%	100%	\$0.27	0.4	0
Office	Vending Machines	New	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.02	90%	100%	\$0.27	0.4	0
Office	Ventilation and Circulation	Existing	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	2449.00	5	\$356.44	20%	85%	\$0.04	2.1	1,658
Office	Ventilation and Circulation	New	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	2449.00	5	\$356.44	20%	85%	\$0.04	2.1	41
Office	Ventilation and Circulation	Existing	Downsizing motor during retrofit	Downsizing motor during retrofit	Larger hp standard motor	Per Motor	104.96	20	\$8,793.77	10%	95%	\$10.35	0.0	0
Office	Ventilation and Circulation	Existing	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	2383.57	15	\$1,040.69	15%	95%	\$0.06	1.7	745
Office	Ventilation and Circulation	New	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	2383.57	15	\$1,040.69	15%	95%	\$0.06	1.7	31
Office	Ventilation and Circulation	Existing	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	152.52	18	\$1,044.90	75%	95%	\$0.89	0.1	0
Office	Ventilation and Circulation	New	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	152.52	18	\$1,044.90	75%	95%	\$0.89	0.1	0
Office	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	216.61	15	\$2.66	95%	76%	\$0.00	61.6	621



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	216.61	15	\$2.66	95%	76%	\$0.00	61.6	15
Office	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	110.58	15	\$2.66	95%	76%	\$0.00	31.4	308
Office	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	110.58	15	\$2.66	95%	76%	\$0.00	31.4	8
Office	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	169.77	15	\$2.66	95%	76%	\$0.00	48.3	481
Office	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	169.77	15	\$2.66	95%	76%	\$0.00	48.3	12
Office	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	110.12	15	\$2.66	95%	76%	\$0.00	31.3	305
Office	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	110.12	15	\$2.66	95%	76%	\$0.00	31.3	7
Office	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	124.93	15	\$2.66	95%	76%	\$0.00	35.5	351
Office	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	124.93	15	\$2.66	95%	76%	\$0.00	35.5	9

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					1200-3600 RPM									
Office	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	6044.21	13	\$1,408.27	75%	98%	\$0.04	2.9	16,957
Office	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	1621.81	13	\$465.23	75%	98%	\$0.04	2.4	3,027
Office	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	580.96	25	\$833.35	5%	100%	\$0.16	0.7	0
Office	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	253.62	25	\$833.35	25%	100%	\$0.37	0.3	0
Office	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.74	11	\$12.29	100%	34%	\$0.19	0.5	0
Office	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.74	11	\$12.29	100%	34%	\$0.19	0.5	0
Office	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.16	11	\$29.85	100%	95%	\$0.24	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.16	11	\$29.85	100%	95%	\$0.24	0.4	0
Office	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.90	11	\$17.56	100%	95%	\$0.27	0.4	0
Office	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.90	11	\$17.56	100%	95%	\$0.27	0.4	0
Office	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.63	10	\$8.86	100%	25%	\$0.15	0.7	0
Office	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.63	10	\$8.86	100%	55%	\$0.15	0.7	0
Office	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	1461.12	14	\$950.00	50%	95%	\$0.10	1.1	31
Office	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	637.85	14	\$950.00	50%	95%	\$0.22	0.5	0
Office	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	87.38	8	\$117.50	50%	75%	\$0.28	0.3	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	77%	\$0.04	2.5	3
Office	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	14.52	15	\$224.27	75%	90%	\$2.18	0.1	0
Office	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	1421.65	7	\$63.10	95%	85%	\$0.01	9.1	97
Office	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	620.62	7	\$63.10	75%	85%	\$0.02	4.0	1
Office	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	1039.76	7	\$50.00	95%	76%	\$0.01	8.4	0
Office	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	453.90	7	\$50.00	75%	76%	\$0.03	3.7	0
Office	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	367.46	12	\$0.00	95%	75%	\$0.00	999.0	25
Office	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	367.46	12	\$0.00	95%	75%	\$0.00	999.0	1
Office	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	259.38	12	\$0.00	95%	50%	\$0.00	999.0	0
Office	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	259.38	12	\$0.00	95%	50%	\$0.00	999.0	0
Office	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	151.31	12	\$0.00	95%	35%	\$0.00	999.0	0
Office	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	151.31	12	\$0.00	95%	35%	\$0.00	999.0	0
Office	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	172.92	12	\$5.38	95%	25%	\$0.00	20.3	4
Office	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	86.87	9	\$1.34	75%	85%	\$0.00	32.2	5
Office	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	86.87	9	\$1.34	75%	85%	\$0.00	32.2	0
Office	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	65.15	9	\$1.00	75%	75%	\$0.00	32.2	0
Office	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	65.15	9	\$1.00	75%	75%	\$0.00	32.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	43.43	9	\$0.67	75%	50%	\$0.00	32.2	0
Office	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	43.43	9	\$0.67	75%	50%	\$0.00	32.2	0
Office	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	43.43	9	\$0.67	75%	35%	\$0.00	32.2	1
Office	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	43.43	9	\$0.67	75%	35%	\$0.00	32.2	0
Office	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.05	15	\$0.89	100%	100%	\$8.81	0.0	0
Office	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.05	15	\$0.89	100%	100%	\$8.81	0.0	0
Office	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	237.77	12	\$651.25	75%	85%	\$0.44	0.2	0
Office	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	237.77	12	\$651.25	75%	85%	\$0.44	0.2	0
Office	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	10	\$0.01	90%	100%	\$0.14	0.7	0
Office	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	10	\$0.01	90%	100%	\$0.14	0.7	0
Office	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	406.67	2	\$17.00	75%	94%	\$0.03	3.1	15

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	528.02	25	\$833.35	5%	100%	\$0.18	0.7	0
Office	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	525.93	25	\$833.35	25%	100%	\$0.18	0.7	0
Office	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.74	11	\$12.29	100%	34%	\$0.19	0.5	0
Office	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.74	11	\$12.29	100%	34%	\$0.19	0.5	0
Office	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.16	11	\$29.85	100%	95%	\$0.24	0.4	0
Office	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.16	11	\$29.85	100%	95%	\$0.24	0.4	0
Office	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.90	11	\$17.56	100%	95%	\$0.27	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	10.90	11	\$17.56	100%	95%	\$0.27	0.4	0
Office	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.63	10	\$8.86	100%	25%	\$0.15	0.7	0
Office	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.63	10	\$8.86	100%	55%	\$0.15	0.7	0
Office	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	1327.96	14	\$950.00	50%	95%	\$0.10	1.0	454
Office	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	1322.70	14	\$950.00	50%	95%	\$0.11	1.0	15
Office	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	79.42	8	\$117.50	50%	75%	\$0.31	0.3	0
Office	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	77%	\$0.04	2.5	42
Office	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	13.20	15	\$224.27	75%	90%	\$2.40	0.0	0
Office	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	1278.76	7	\$63.10	95%	85%	\$0.01	8.2	1,379
Office	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	1273.70	7	\$63.10	75%	85%	\$0.01	8.2	28
Office	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	928.25	7	\$50.00	95%	76%	\$0.01	7.5	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	924.57	7	\$50.00	75%	76%	\$0.01	7.5	0
Office	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	779.71	12	\$0.00	95%	75%	\$0.00	999.0	1,058
Office	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	779.71	12	\$0.00	95%	75%	\$0.00	999.0	26
Office	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	550.39	12	\$0.00	95%	50%	\$0.00	999.0	0
Office	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	550.39	12	\$0.00	95%	50%	\$0.00	999.0	0
Office	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	321.06	12	\$0.00	95%	35%	\$0.00	999.0	0
Office	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	321.06	12	\$0.00	95%	35%	\$0.00	999.0	0
Office	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	366.92	12	\$5.38	95%	25%	\$0.00	43.1	166
Office	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	184.33	9	\$1.34	75%	85%	\$0.00	68.4	224
Office	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	184.33	9	\$1.34	75%	85%	\$0.00	68.4	6
Office	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	138.24	9	\$1.00	75%	75%	\$0.00	68.4	0
Office	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	138.24	9	\$1.00	75%	75%	\$0.00	68.4	0
Office	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	92.16	9	\$0.67	75%	50%	\$0.00	68.4	0
Office	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	92.16	9	\$0.67	75%	50%	\$0.00	68.4	0
Office	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	92.16	9	\$0.67	75%	35%	\$0.00	68.4	46
Office	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	92.16	9	\$0.67	75%	35%	\$0.00	68.4	1
Office	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.22	15	\$0.69	100%	100%	\$1.50	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Office	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.22	15	\$0.69	100%	100%	\$1.50	0.1	0
Office	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	504.52	12	\$651.25	75%	85%	\$0.21	0.5	0
Office	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	504.52	12	\$651.25	75%	85%	\$0.21	0.5	0
Office	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.18	10	\$0.11	90%	100%	\$0.11	0.9	0
Office	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.18	10	\$0.11	90%	100%	\$0.11	0.9	0
Office	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	369.61	2	\$17.00	75%	94%	\$0.03	2.8	213
Other Commercial	Compressed Air	Existing	Air Entraining Air Nozzle	Increase Pressure Air Entraining Air Nozzles	Standard Nozzle	Per Compressed Air System	1031.68	15	\$700.00	90%	100%	\$0.10	1.1	12
Other Commercial	Compressed Air	New	Air Entraining Air Nozzle	Increase Pressure Air Entraining Air Nozzles	Standard Nozzle	Per Compressed Air System	1031.68	15	\$700.00	90%	100%	\$0.10	1.1	0
Other Commercial	Compressed Air	Existing	Compressed Air System Improvements	Compressed Air System Improvements	Existing Compressed Air System	Per Compressed Air System	50133.31	10	\$7,590.12	35%	90%	\$0.03	3.5	589
Other Commercial	Compressed Air	Existing	Low Pressure-drop Filters	Low Pressure-drop Filters	Standard Filter	Per Compressed Air System	1614.08	5	\$1,000.00	35%	90%	\$0.19	0.5	0
Other Commercial	Compressed Air	New	Low Pressure-drop Filters	Low Pressure-drop Filters	Standard Filter	Per Compressed Air System	1614.08	5	\$1,000.00	35%	90%	\$0.19	0.5	0
Other Commercial	Compressed Air	Existing	VFD Controlled Compressor	VFD Controlled Compressor	Standard Compressor	Per Compressed Air System	34632.00	10	\$14,146.00	35%	90%	\$0.07	1.3	407

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Compressed Air	New	VFD Controlled Compressor	VFD Controlled Compressor	Standard Compressor	Per Compressed Air System	34632.00	10	\$14,146.00	35%	90%	\$0.07	1.3	10
Other Commercial	Compressed Air	Existing	Zero Loss Condensate Drains	Zero Loss Condensate Drains	Standard Drains	Per Compressed Air System	2192.03	5	\$700.00	35%	90%	\$0.10	0.9	0
Other Commercial	Compressed Air	New	Zero Loss Condensate Drains	Zero Loss Condensate Drains	Standard Drains	Per Compressed Air System	2192.03	5	\$700.00	35%	90%	\$0.10	0.9	0
Other Commercial	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.24	4	\$4.40	95%	86%	\$6.64	0.0	0
Other Commercial	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.25	4	\$4.40	95%	86%	\$6.40	0.0	0
Other Commercial	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.04	4	\$0.00	90%	100%	\$0.00	2,996.0	195
Other Commercial	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.04	4	\$0.00	90%	100%	\$0.00	2,996.0	6
Other Commercial	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	1210.82	5	\$269.07	50%	80%	\$0.07	1.3	409
Other Commercial	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	1210.82	5	\$269.07	50%	80%	\$0.07	1.3	10
Other Commercial	Cooking	Existing	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	64.88	12	\$0.00	15%	95%	\$0.00	105,796.6	10
Other Commercial	Cooking	New	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	64.88	12	\$0.00	15%	95%	\$0.00	105,796.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooking	Existing	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	397.98	12	\$7.50	5%	95%	\$0.00	32.5	21
Other Commercial	Cooking	New	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	397.98	12	\$7.50	5%	95%	\$0.00	32.5	1
Other Commercial	Cooking	Existing	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	238.79	12	\$0.00	90%	90%	\$0.00	389,391.8	218
Other Commercial	Cooking	New	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	238.79	12	\$0.00	90%	90%	\$0.00	389,391.8	5
Other Commercial	Cooking	Existing	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	72.64	12	\$0.00	5%	55%	\$0.00	118,457.2	0
Other Commercial	Cooking	New	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	72.64	12	\$0.00	5%	55%	\$0.00	118,457.2	0
Other Commercial	Cooking	Existing	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	35.69	12	\$7.88	0%	95%	\$0.04	2.8	0
Other Commercial	Cooking	New	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	35.69	12	\$7.88	0%	95%	\$0.04	2.8	0
Other Commercial	Cooking	Existing	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	35.80	12	\$0.00	20%	95%	\$0.00	116,740.7	8
Other Commercial	Cooking	New	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	35.80	12	\$0.00	20%	95%	\$0.00	116,740.7	0
Other Commercial	Cooking	Existing	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	148.32	12	\$112.28	5%	95%	\$0.12	0.8	0
Other Commercial	Cooking	New	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	148.32	12	\$112.28	5%	95%	\$0.12	0.8	0
Other Commercial	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	13339.37	10	\$323.01	100%	58%	\$0.00	25.2	355
Other Commercial	Cooling Chillers	New	Active chilled beam cooling	Active chilled beam cooling	Standard Building Design	Per Building	12048.42	15	#####	60%	100%	\$1.85	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
						and Cooling System								
Other Commercial	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	163.29	20	\$11,002.62	95%	95%	\$8.32	0.0	0
Other Commercial	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	138.60	20	\$11,002.62	95%	95%	\$9.80	0.0	0
Other Commercial	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	60.24	15	\$1,685.00	95%	95%	\$3.95	0.0	0
Other Commercial	Cooling Chillers	Existing	Automated control system	Automated control system	Baseline DX	Per Building	3548.75	10	\$15,290.17	95%	96%	\$0.78	0.1	0
Other Commercial	Cooling Chillers	New	Automated control system	Automated control system	Baseline DX	Per Building	3012.11	10	\$15,290.17	95%	96%	\$0.91	0.1	0
Other Commercial	Cooling Chillers	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	39058.89	15	\$13,807.21	25%	62%	\$0.05	2.4	134
Other Commercial	Cooling Chillers	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	23658.32	15	\$6,903.60	25%	95%	\$0.04	2.9	178
Other Commercial	Cooling Chillers	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	20080.71	15	\$6,903.60	75%	95%	\$0.05	2.5	12
Other Commercial	Cooling Chillers	Existing	Chilled Water Reset, Optimizer System for Chiller(s)	Chilled Water Reset, Optimizer System for Chiller(s)	0	Per Building	1419.50	10	#####	95%	81%	\$2.54	0.0	0
Other Commercial	Cooling Chillers	Existing	Chiller Tuneup/Diagnostics	Chiller Tuneup/Diagnostics	Existing Conditions	Per Building	5678.00	10	#####	25%	24%	\$0.44	0.3	0
Other Commercial	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.52 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.49	20	\$1.27	90%	100%	\$0.32	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling Chillers	New	Chillers 150-300 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.52 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.49	20	\$1.27	90%	100%	\$0.32	0.4	0
Other Commercial	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - High Efficiency	High Efficiency - 0.63 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.15	20	\$0.40	90%	100%	\$0.32	0.4	0
Other Commercial	Cooling Chillers	New	Chillers 150-300 tons (screw) - High Efficiency	High Efficiency - 0.63 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.15	20	\$0.40	90%	100%	\$0.32	0.4	0
Other Commercial	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - Premium Efficiency	Premium Efficiency - 0.58 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.30	20	\$0.79	90%	100%	\$0.32	0.4	0
Other Commercial	Cooling Chillers	New	Chillers 150-300 tons (screw) - Premium Efficiency	Premium Efficiency - 0.58 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	Per Building	0.30	20	\$0.79	90%	100%	\$0.32	0.4	0
Other Commercial	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	14194.99	15	#####	95%	75%	\$1.04	0.1	0
Other Commercial	Cooling Chillers	Existing	Cooling Tower Optimization	Cooling Tower Optimization	Existing Conditions	Per Building	221.09	8	\$2,555.74	10%	90%	\$2.43	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	9036.32	7	#####	75%	85%	\$0.75	0.1	0
Other Commercial	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	724.02	20	#####	75%	99%	\$45.43	0.0	0
Other Commercial	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	614.54	20	#####	75%	99%	\$53.52	0.0	0
Other Commercial	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	11986.88	30	\$241.65	20%	84%	\$0.00	65.1	79
Other Commercial	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	10174.23	30	\$241.65	80%	84%	\$0.00	55.2	8
Other Commercial	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	11356.00	7	\$7,957.72	75%	75%	\$0.16	0.7	0
Other Commercial	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	12775.49	18	#####	1%	98%	\$0.90	0.1	0
Other Commercial	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	10843.58	18	#####	1%	98%	\$1.06	0.1	0
Other Commercial	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	23321.59	13	\$6,600.03	75%	98%	\$0.04	2.7	600
Other Commercial	Cooling Chillers	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	35793.58	15	\$4,985.28	10%	66%	\$0.02	6.2	78
Other Commercial	Cooling Chillers	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	23658.32	15	\$2,492.64	10%	95%	\$0.01	8.1	76
Other Commercial	Cooling Chillers	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	20080.71	15	\$2,492.64	50%	95%	\$0.02	6.9	9



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	3548.75	5	\$1,819.19	50%	95%	\$0.15	0.7	0
Other Commercial	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	3012.11	5	\$1,819.19	50%	95%	\$0.18	0.6	0
Other Commercial	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	14794.91	10	\$323.01	100%	58%	\$0.00	28.0	2,269
Other Commercial	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	1183.59	20	\$11,002.62	95%	95%	\$1.15	0.1	0
Other Commercial	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	1147.02	20	\$11,002.62	95%	95%	\$1.18	0.1	0
Other Commercial	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	76.29	15	\$1,685.00	95%	95%	\$3.12	0.0	0
Other Commercial	Cooling DX	Existing	Automated control system	Automated control system	Baseline DX	Per Building	3935.97	10	\$15,290.17	95%	96%	\$0.70	0.2	0
Other Commercial	Cooling DX	New	Automated control system	Automated control system	Baseline DX	Per Building	3814.36	10	\$15,290.17	95%	96%	\$0.72	0.2	0
Other Commercial	Cooling DX	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	43320.83	15	\$13,807.21	25%	62%	\$0.05	2.7	1,123
Other Commercial	Cooling DX	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	26239.82	15	\$6,903.60	25%	95%	\$0.04	3.3	1,135
Other Commercial	Cooling DX	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	25429.08	15	\$6,903.60	75%	95%	\$0.04	3.2	77
Other Commercial	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	15743.89	15	#####	95%	95%	\$0.22	0.6	0
Other Commercial	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	6966.29	5	\$4,653.53	95%	45%	\$0.20	0.5	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling DX	Existing	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.12	15	\$0.38	90%	100%	\$0.43	0.3	0
Other Commercial	Cooling DX	New	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.12	15	\$0.38	90%	100%	\$0.43	0.3	0
Other Commercial	Cooling DX	Existing	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.19	15	\$0.61	90%	100%	\$0.44	0.3	0
Other Commercial	Cooling DX	New	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.19	15	\$0.61	90%	100%	\$0.44	0.3	0
Other Commercial	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	8186.83	15	\$7,341.07	50%	99%	\$0.13	1.0	0
Other Commercial	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	7933.87	15	\$3,915.24	50%	99%	\$0.07	1.7	15
Other Commercial	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	1420.31	15	\$16,619.75	95%	65%	\$1.65	0.1	0
Other Commercial	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	1420.31	15	\$12,631.01	45%	80%	\$1.26	0.1	0
Other Commercial	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	37173.08	15	#####	90%	100%	\$1.41	0.1	0
Other Commercial	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	11443.09	7	#####	95%	85%	\$0.59	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	5247.96	20	#####	75%	99%	\$6.27	0.0	0
Other Commercial	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	5085.82	20	#####	75%	99%	\$6.47	0.0	0
Other Commercial	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	6966.29	10	\$4,779.30	95%	24%	\$0.12	0.9	0
Other Commercial	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	13294.84	30	\$241.65	20%	84%	\$0.00	72.2	503
Other Commercial	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	12884.07	30	\$241.65	80%	84%	\$0.00	69.9	49
Other Commercial	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	14061.33	10	#####	10%	45%	\$0.27	0.4	0
Other Commercial	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	12595.12	7	\$7,957.72	95%	75%	\$0.15	0.7	0
Other Commercial	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	14169.51	18	#####	1%	98%	\$0.81	0.2	0
Other Commercial	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	13731.70	18	#####	1%	98%	\$0.83	0.2	0
Other Commercial	Cooling DX	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	39699.23	15	\$4,985.28	10%	66%	\$0.02	6.8	496
Other Commercial	Cooling DX	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	26239.82	15	\$2,492.64	10%	95%	\$0.01	9.0	485

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Cooling DX	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	25429.08	15	\$2,492.64	50%	95%	\$0.01	8.7	61
Other Commercial	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	3935.97	5	\$1,819.19	50%	95%	\$0.14	0.8	0
Other Commercial	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	3814.36	5	\$1,819.19	50%	95%	\$0.14	0.7	0
Other Commercial	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	11
Other Commercial	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	0
Other Commercial	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	24
Other Commercial	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	0
Other Commercial	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.04	3.2	2
Other Commercial	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.04	3.2	0
Other Commercial	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	19849.11	10	\$323.01	100%	58%	\$0.00	32.9	440
Other Commercial	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	1077.45	20	\$11,002.62	95%	95%	\$1.26	0.1	0
Other Commercial	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	1045.49	20	\$11,002.62	95%	95%	\$1.30	0.1	0
Other Commercial	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.17	15	\$0.12	90%	100%	\$0.10	1.0	47
Other Commercial	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.17	15	\$0.12	90%	100%	\$0.10	1.0	2



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.32	15	\$0.25	90%	100%	\$0.11	1.0	0
Other Commercial	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.32	15	\$0.25	90%	100%	\$0.11	1.0	0
Other Commercial	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	1488.89	15	\$1,685.00	95%	95%	\$0.16	0.7	0
Other Commercial	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	1018.92	15	\$1,685.00	95%	95%	\$0.23	0.5	0
Other Commercial	Heat Pump	Existing	Automated control system	Automated control system	Baseline DX	Per Building	5710.00	10	\$15,290.17	95%	96%	\$0.48	0.2	0
Other Commercial	Heat Pump	New	Automated control system	Automated control system	Baseline DX	Per Building	5540.61	10	\$15,290.17	95%	96%	\$0.50	0.2	0
Other Commercial	Heat Pump	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	62846.41	15	\$13,807.21	25%	62%	\$0.03	3.4	238
Other Commercial	Heat Pump	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	38066.65	15	\$6,903.60	25%	95%	\$0.03	4.1	240
Other Commercial	Heat Pump	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	36937.40	15	\$6,903.60	75%	95%	\$0.03	4.0	17
Other Commercial	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	14332.04	15	#####	95%	95%	\$0.23	0.5	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	6341.58	5	\$4,653.53	95%	45%	\$0.22	0.4	0
Other Commercial	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	11196.16	15	\$7,341.07	50%	99%	\$0.09	1.1	149
Other Commercial	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	10864.02	15	\$3,915.24	50%	99%	\$0.05	2.1	3
Other Commercial	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	1292.94	15	\$16,619.75	95%	65%	\$1.82	0.1	0
Other Commercial	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	1292.94	15	\$12,631.01	45%	80%	\$1.38	0.1	0
Other Commercial	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	16621.83	7	#####	95%	85%	\$0.41	0.2	0
Other Commercial	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	6052.45	20	#####	75%	99%	\$5.43	0.0	0
Other Commercial	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	5872.90	20	#####	75%	99%	\$5.60	0.0	0
Other Commercial	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.32	15	\$27.21	90%	100%	\$2.91	0.0	0
Other Commercial	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.32	15	\$27.21	90%	100%	\$2.91	0.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	6341.58	10	\$4,527.76	95%	24%	\$0.13	0.8	0
Other Commercial	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	12102.61	30	\$241.65	20%	84%	\$0.00	56.7	66
Other Commercial	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	11743.59	30	\$241.65	80%	84%	\$0.00	55.0	6
Other Commercial	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	14061.33	10	#####	10%	45%	\$0.27	0.4	0
Other Commercial	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	18271.99	7	\$7,957.72	95%	75%	\$0.10	0.9	0
Other Commercial	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	12898.84	18	#####	1%	98%	\$0.89	0.1	0
Other Commercial	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	12516.19	18	#####	1%	98%	\$0.92	0.1	0
Other Commercial	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	67833.79	15	#####	50%	95%	\$2.21	0.1	0
Other Commercial	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	65821.51	15	#####	95%	95%	\$2.28	0.1	0
Other Commercial	Heat Pump	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	57592.48	15	\$4,985.28	10%	66%	\$0.01	8.6	105
Other Commercial	Heat Pump	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	38066.65	15	\$2,492.64	10%	95%	\$0.01	11.4	103

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Heat Pump	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	36937.40	15	\$2,492.64	50%	95%	\$0.01	11.0	13
Other Commercial	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.83	15	\$2.52	90%	100%	\$0.43	0.2	0
Other Commercial	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.83	15	\$2.52	90%	100%	\$0.43	0.2	0
Other Commercial	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	5710.00	5	\$1,819.19	50%	95%	\$0.10	0.9	0
Other Commercial	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	5540.61	5	\$1,819.19	50%	95%	\$0.10	0.9	0
Other Commercial	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	1703.13	10	\$100.00	85%	45%	\$0.01	9.2	176
Other Commercial	Lighting Exterior	Existing	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	840.95	15	\$17.36	100%	95%	\$0.00	36.5	899
Other Commercial	Lighting Exterior	New	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	840.95	15	\$17.36	100%	95%	\$0.00	36.5	22
Other Commercial	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	4768.76	8	\$228.96	50%	45%	\$0.01	9.4	310
Other Commercial	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	4768.76	8	\$228.96	50%	75%	\$0.01	9.4	13
Other Commercial	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	4087.51	8	\$372.07	10%	100%	\$0.02	4.9	106
Other Commercial	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	5249.69	10	\$100.00	85%	45%	\$0.00	28.3	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	77.01	13	\$6.00	0%	85%	\$0.01	8.6	0
Other Commercial	Lighting Interior Fluorescent	Existing	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	943.91	15	\$1,230.92	50%	95%	\$0.18	0.6	0
Other Commercial	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	4129.54	8	\$11,673.09	65%	100%	\$0.59	0.2	0
Other Commercial	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	14174.15	10	\$3,883.28	10%	98%	\$0.05	2.0	1,171
Other Commercial	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.15	13	\$0.18	90%	100%	\$0.18	0.6	0
Other Commercial	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.15	13	\$0.64	90%	100%	\$0.64	0.2	0
Other Commercial	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.20	13	\$0.36	90%	100%	\$0.28	0.4	0
Other Commercial	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.06	13	\$0.15	90%	100%	\$0.41	0.2	0
Other Commercial	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.31	20	\$1.93	90%	100%	\$0.77	0.1	0
Other Commercial	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	12599.25	8	\$2,680.08	90%	98%	\$0.04	2.1	2,358

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	12599.25	8	\$372.07	10%	99%	\$0.01	15.2	348
Other Commercial	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	178.95	10	\$100.00	85%	45%	\$0.10	1.0	0
Other Commercial	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	140.77	8	\$11,673.09	65%	100%	\$17.41	0.0	0
Other Commercial	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	483.16	10	\$3,883.28	10%	98%	\$1.45	0.1	0
Other Commercial	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal Halide - Above Standard	Efficient Metal Halide	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.01	15	\$0.01	90%	100%	\$0.09	1.1	0
Other Commercial	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.03	15	\$0.01	90%	100%	\$0.06	1.8	263
Other Commercial	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.04	20	\$0.01	90%	100%	\$0.04	3.0	23
Other Commercial	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.03	20	-\$0.01	90%	100%	-\$0.03	999.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	429.48	8	\$2,680.08	90%	98%	\$1.31	0.1	0
Other Commercial	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	429.48	8	\$372.07	10%	99%	\$0.18	0.5	0
Other Commercial	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	152.07	10	\$38.00	95%	25%	\$0.04	2.2	11
Other Commercial	Lighting Interior Other	New	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	943.91	15	\$1,230.92	50%	95%	\$0.18	0.6	0
Other Commercial	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.26	15	\$0.14	100%	100%	\$0.08	1.4	0
Other Commercial	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.39	15	\$0.16	100%	100%	\$0.06	1.9	0
Other Commercial	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.77	15	\$0.31	100%	100%	\$0.06	1.9	606
Other Commercial	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	5929.44	8	\$11,673.09	65%	100%	\$0.41	0.2	0
Other Commercial	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	112.83	16	\$48.00	95%	50%	\$0.06	1.9	51
Other Commercial	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	20352.09	10	\$3,883.28	30%	98%	\$0.03	2.8	99
Other Commercial	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	18090.75	8	\$2,680.08	90%	98%	\$0.03	3.0	55

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	294.34	30	\$30.00	75%	95%	\$0.01	11.3	201
Other Commercial	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	294.34	30	\$30.00	75%	95%	\$0.01	11.3	3
Other Commercial	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	1482.85	10	\$100.00	85%	45%	\$0.01	8.0	44
Other Commercial	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	1166.45	8	\$11,673.09	65%	100%	\$2.10	0.0	0
Other Commercial	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	4003.69	10	\$3,883.28	10%	98%	\$0.17	0.6	0
Other Commercial	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	Per Building	0.28	5	\$0.01	90%	100%	\$0.01	10.8	854
Other Commercial	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	Per Building	0.23	2	\$0.00	90%	100%	\$0.01	6.1	0
Other Commercial	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	Per Building	0.30	12	\$0.05	90%	100%	\$0.04	2.9	4,387
Other Commercial	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	3558.83	8	\$2,680.08	90%	98%	\$0.16	0.6	0
Other Commercial	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	3558.83	8	\$372.07	10%	99%	\$0.02	4.3	28
Other Commercial	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	4
Other Commercial	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Other Plug Load	Existing	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	75%	90%	\$6.49	0.0	0
Other Commercial	Other Plug Load	New	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	100%	90%	\$6.49	0.0	0
Other Commercial	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	8.08	4	\$0.80	100%	20%	\$0.04	2.4	2
Other Commercial	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	8.08	4	\$0.80	100%	20%	\$0.04	2.4	0
Other Commercial	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	948.66	10	\$0.00	95%	20%	\$0.00	999.0	203
Other Commercial	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	948.66	10	\$0.00	95%	20%	\$0.00	999.0	5
Other Commercial	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.72	5	\$2.94	95%	20%	\$1.24	0.1	0
Other Commercial	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.72	5	\$2.94	95%	20%	\$1.24	0.1	0
Other Commercial	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	278.04	5	\$47.09	95%	95%	\$0.05	1.8	76
Other Commercial	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	278.04	5	\$47.09	95%	95%	\$0.05	1.8	2
Other Commercial	Other Plug Load	Existing	VFD on Process	VFD on Process	Standard Motor	Per Process Motor VFD	7849.68	15	\$11,000.00	55%	98%	\$0.20	0.5	0
Other Commercial	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	1
Other Commercial	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Other Commercial	Pool Pump	Existing	Pool Pump - Two Speed	Pool Pump - Two Speed	Pool Pump - Constant Speed	Per Building	0.02	10	\$0.00	100%	100%	\$0.01	7.6	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Pool Pump	New	Pool Pump - Two Speed	Pool Pump - Two Speed	Pool Pump - Constant Speed	Per Building	0.02	10	\$0.00	100%	100%	\$0.01	7.6	0
Other Commercial	Pool Pump	Existing	Pool Pump - VSD	Pool Pump - VSD	Pool Pump - Constant Speed	Per Building	0.04	10	\$0.01	100%	100%	\$0.03	3.6	598
Other Commercial	Pool Pump	New	Pool Pump - VSD	Pool Pump - VSD	Pool Pump - Constant Speed	Per Building	0.04	10	\$0.01	100%	100%	\$0.03	3.6	30
Other Commercial	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.01	5	\$0.00	90%	100%	\$0.00	4,559.7	12
Other Commercial	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.01	5	\$0.00	90%	100%	\$0.00	4,559.7	0
Other Commercial	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	1804.25	12	\$123.50	50%	60%	\$0.01	9.0	588
Other Commercial	Refrigeration	New	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	1804.25	12	\$123.50	50%	60%	\$0.01	9.0	14
Other Commercial	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	3320.98	12	\$123.50	50%	60%	\$0.01	16.5	1,121
Other Commercial	Refrigeration	New	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	3320.98	12	\$123.50	50%	60%	\$0.01	16.5	28
Other Commercial	Refrigeration	Existing	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	267.78	8	\$43.47	95%	80%	\$0.03	2.7	229
Other Commercial	Refrigeration	New	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	267.78	8	\$43.47	95%	80%	\$0.03	2.7	6
Other Commercial	Refrigeration	Existing	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	646.18	8	\$43.47	95%	80%	\$0.01	6.5	552
Other Commercial	Refrigeration	New	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	646.18	8	\$43.47	95%	80%	\$0.01	6.5	14



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigeration	Existing	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	3.01	12	\$0.94	95%	81%	\$0.05	2.0	3
Other Commercial	Refrigeration	New	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	3.01	12	\$0.94	95%	81%	\$0.05	2.0	0
Other Commercial	Refrigeration	Existing	Compressor VSD retrofit	Compressor VSD retrofit	Base Refrigeration System - Grocery	Per Refrigerator/Freezer Compressor Motor HP	341.98	15	\$194.84	70%	86%	\$0.08	1.3	186
Other Commercial	Refrigeration	Existing	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	103.94	10	\$613.02	60%	100%	\$1.06	0.1	0
Other Commercial	Refrigeration	New	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	103.94	10	\$613.02	60%	100%	\$1.06	0.1	0
Other Commercial	Refrigeration	Existing	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	25.98	10	\$613.02	90%	100%	\$4.25	0.0	0
Other Commercial	Refrigeration	New	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	25.98	10	\$613.02	90%	100%	\$4.25	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigeration	Existing	Door Gasket - Cooler	Door Gasket - Cooler	Existing Gasket	Per linear foot of gasket on walk-in or reach-in cooler	100.31	4	\$22.29	95%	90%	\$0.08	1.1	96
Other Commercial	Refrigeration	Existing	Door Gasket - Freezer	Door Gasket - Freezer	Existing Gasket	Per linear foot of gasket on walk-in or reach-in freezer	351.09	4	\$22.29	95%	90%	\$0.02	3.8	338
Other Commercial	Refrigeration	Existing	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	551.95	15	\$355.16	95%	93%	\$0.09	1.1	547
Other Commercial	Refrigeration	New	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	551.95	15	\$355.16	95%	93%	\$0.09	1.1	13
Other Commercial	Refrigeration	Existing	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	276.13	15	\$369.60	10%	95%	\$0.19	0.6	0
Other Commercial	Refrigeration	New	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	276.13	15	\$369.60	5%	95%	\$0.19	0.6	0
Other Commercial	Refrigeration	Existing	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	352.77	15	\$33.44	90%	100%	\$0.01	7.8	0
Other Commercial	Refrigeration	New	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	352.77	15	\$33.44	90%	100%	\$0.01	7.8	0
Other Commercial	Refrigeration	Existing	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	256.67	15	\$118.72	65%	100%	\$0.07	1.6	168



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigeration	New	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	256.67	15	\$118.72	95%	100%	\$0.07	1.6	6
Other Commercial	Refrigeration	Existing	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	23.72	10	\$52.80	75%	55%	\$0.40	0.2	0
Other Commercial	Refrigeration	New	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	23.72	10	\$52.80	95%	55%	\$0.40	0.2	0
Other Commercial	Refrigeration	Existing	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	132.17	15	\$94.74	50%	85%	\$0.10	1.0	63
Other Commercial	Refrigeration	New	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	132.17	15	\$94.74	95%	92%	\$0.10	1.0	3
Other Commercial	Refrigeration	Existing	Insulation for bare suction lines	Insulation for bare suction lines	No Insulation	Per linear feet of walk-in cooler/freezer suction line	476.83	11	\$254.87	95%	50%	\$0.09	1.1	198
Other Commercial	Refrigeration	Existing	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	615.87	8	\$469.31	95%	80%	\$0.16	0.6	0
Other Commercial	Refrigeration	New	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	615.87	8	\$469.31	95%	80%	\$0.16	0.6	0
Other Commercial	Refrigeration	Existing	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	132.17	15	\$94.74	50%	95%	\$0.10	1.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigeration	New	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	132.17	15	\$94.74	95%	95%	\$0.10	1.0	0
Other Commercial	Refrigeration	Existing	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	1907.61	15	\$1,024.02	95%	86%	\$0.08	1.4	1,753
Other Commercial	Refrigeration	New	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	1907.61	15	\$1,024.02	95%	86%	\$0.08	1.4	43
Other Commercial	Refrigeration	Existing	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	211.74	15	\$441.08	95%	49%	\$0.29	0.4	0
Other Commercial	Refrigeration	New	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	211.74	15	\$441.08	0%	49%	\$0.29	0.4	0
Other Commercial	Refrigeration	Existing	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	836.14	15	\$441.08	95%	49%	\$0.07	1.4	438
Other Commercial	Refrigeration	New	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	836.14	15	\$441.08	0%	49%	\$0.07	1.4	0
Other Commercial	Refrigeration	Existing	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	624.40	15	\$441.08	95%	49%	\$0.10	1.0	327
Other Commercial	Refrigeration	New	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	624.40	15	\$441.08	0%	49%	\$0.10	1.0	0
Other Commercial	Refrigeration	Existing	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	1767.20	3	\$3,764.62	10%	85%	\$0.99	0.1	0
Other Commercial	Refrigeration	New	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	1767.20	3	\$3,764.62	5%	90%	\$0.99	0.1	0
Other Commercial	Refrigeration	Existing	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	439.22	4	\$44.47	95%	78%	\$0.04	2.4	366



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigeration	New	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	673.98	4	\$44.47	95%	78%	\$0.02	3.7	14
Other Commercial	Refrigeration	Existing	Vertical night covers	Vertical night covers	No covers present	Per ft of vertical display case width	42.87	5	\$36.74	95%	100%	\$0.26	0.3	0
Other Commercial	Refrigeration	New	Vertical night covers	Vertical night covers	No covers present	Per ft of vertical display case width	42.87	5	\$36.74	95%	100%	\$0.26	0.3	0
Other Commercial	Refrigeration	Existing	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	230.16	15	\$139.32	75%	49%	\$0.09	1.2	95
Other Commercial	Refrigeration	New	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	230.16	15	\$139.32	95%	49%	\$0.09	1.2	3
Other Commercial	Refrigeration	Existing	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	615.81	15	\$139.32	75%	49%	\$0.03	3.3	255
Other Commercial	Refrigeration	New	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	615.81	15	\$139.32	95%	49%	\$0.03	3.3	8
Other Commercial	Refrigeration	Existing	eCube	eCube	No eCube	Per Walk-in	681.01	9	\$222.36	95%	95%	\$0.06	1.5	691
Other Commercial	Refrigeration	New	eCube	eCube	No eCube	Per Walk-in	681.01	9	\$222.36	95%	95%	\$0.06	1.5	17
Other Commercial	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0
Other Commercial	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0
Other Commercial	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.09	1.0	137
Other Commercial	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.09	1.0	8

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.09	1.0	0
Other Commercial	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.09	1.0	0
Other Commercial	Room Cooling	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	38355.03	15	\$13,807.21	25%	62%	\$0.05	2.4	1,149
Other Commercial	Room Cooling	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	23231.99	15	\$6,903.60	25%	95%	\$0.04	2.9	1,161
Other Commercial	Room Cooling	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	23187.83	15	\$6,903.60	75%	95%	\$0.04	2.9	85
Other Commercial	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.06	12	\$0.02	90%	100%	\$0.05	2.4	52
Other Commercial	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.06	12	\$0.02	90%	100%	\$0.05	2.4	2
Other Commercial	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.39	4	\$4.40	95%	86%	\$4.08	0.0	0
Other Commercial	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.39	4	\$4.40	95%	86%	\$4.10	0.0	0
Other Commercial	Servers	Existing	Data Center - Server/Storage Consolidation	Data Center - Server/Storage Consolidation	No Consolidation	Per Building	2689.57	4	\$3,376.94	75%	80%	\$0.46	0.2	0
Other Commercial	Servers	Existing	Data Center - Server/Storage Virtualization	Data Center - Server/Storage Virtualization	No Virtualization	Per Building	2689.57	4	\$3,376.94	75%	80%	\$0.46	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Servers	New	Data Center - Server/Storage Virtualization	Data Center - Server/Storage Virtualization	No Virtualization	Per Building	2677.33	4	\$3,376.94	75%	80%	\$0.46	0.2	0
Other Commercial	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.03	4	\$0.04	90%	100%	\$0.49	0.2	0
Other Commercial	Servers	New	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.03	4	\$0.04	90%	100%	\$0.49	0.2	0
Other Commercial	Space Heat	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	7219.25	10	\$323.01	100%	58%	\$0.01	12.0	22
Other Commercial	Space Heat	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	1684.49	15	\$1,685.00	95%	95%	\$0.14	0.7	0
Other Commercial	Space Heat	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	1106.95	15	\$1,685.00	95%	95%	\$0.22	0.5	0
Other Commercial	Space Heat	Existing	Automated control system	Automated control system	Baseline DX	Per Building	2406.42	10	\$15,290.17	95%	96%	\$1.14	0.1	0
Other Commercial	Space Heat	New	Automated control system	Automated control system	Baseline DX	Per Building	2406.42	10	\$15,290.17	95%	96%	\$1.14	0.1	0
Other Commercial	Space Heat	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	26485.96	15	\$13,807.21	25%	62%	\$0.07	1.4	14
Other Commercial	Space Heat	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	16042.79	15	\$6,903.60	25%	95%	\$0.06	1.7	14
Other Commercial	Space Heat	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	16042.79	15	\$6,903.60	75%	95%	\$0.06	1.7	1
Other Commercial	Space Heat	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	4235.30	15	\$7,341.07	50%	99%	\$0.25	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Space Heat	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	4235.30	15	\$3,915.24	50%	99%	\$0.13	0.8	0
Other Commercial	Space Heat	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	31706.97	15	#####	90%	100%	\$1.65	0.1	0
Other Commercial	Space Heat	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	7219.25	7	#####	95%	85%	\$0.94	0.1	0
Other Commercial	Space Heat	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1442.62	20	#####	75%	99%	\$22.80	0.0	0
Other Commercial	Space Heat	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1442.62	20	#####	75%	99%	\$22.80	0.0	0
Other Commercial	Space Heat	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	7700.54	7	\$7,957.72	95%	75%	\$0.24	0.4	0
Other Commercial	Space Heat	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	24271.74	15	\$4,985.28	10%	66%	\$0.03	3.6	6
Other Commercial	Space Heat	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	16042.79	15	\$2,492.64	10%	95%	\$0.02	4.8	6
Other Commercial	Space Heat	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	16042.79	15	\$2,492.64	50%	95%	\$0.02	4.8	1
Other Commercial	Vending Machines	Existing	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	550.30	5	\$72.80	100%	50%	\$0.04	2.2	310
Other Commercial	Vending Machines	New	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	550.30	5	\$72.80	100%	50%	\$0.04	2.2	8
Other Commercial	Vending Machines	Existing	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	138.52	5	\$64.71	100%	50%	\$0.14	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Vending Machines	New	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	138.52	5	\$64.71	100%	50%	\$0.14	0.6	0
Other Commercial	Vending Machines	Existing	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.01	90%	100%	\$0.27	0.4	0
Other Commercial	Vending Machines	New	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.01	90%	100%	\$0.27	0.4	0
Other Commercial	Ventilation and Circulation	Existing	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	8608.13	5	\$1,252.88	5%	85%	\$0.04	2.1	412
Other Commercial	Ventilation and Circulation	New	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	8608.13	5	\$1,252.88	5%	85%	\$0.04	2.1	10
Other Commercial	Ventilation and Circulation	Existing	Downsizing motor during retrofit	Downsizing motor during retrofit	Larger hp standard motor	Per Motor	427.20	20	#####	10%	95%	\$8.94	0.0	0
Other Commercial	Ventilation and Circulation	Existing	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	9701.69	15	\$5,320.71	15%	95%	\$0.08	1.4	792
Other Commercial	Ventilation and Circulation	New	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	9701.69	15	\$5,320.71	15%	95%	\$0.08	1.4	36
Other Commercial	Ventilation and Circulation	Existing	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	1359.80	18	\$5,342.25	75%	95%	\$0.51	0.2	0
Other Commercial	Ventilation and Circulation	New	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced	Per Air Handler Recirculating Fan Motor (1 HP or less)	1359.80	18	\$5,342.25	75%	95%	\$0.51	0.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					with 85% eff. ECPM motor									
Other Commercial	Ventilation and Circulation	Existing	Energy Efficient Laboratory Fume Hood	Energy Efficient Laboratory Fume Hood	Standard Fume Hood	Per Building	67.37	13	\$3,050.87	5%	59%	\$6.93	0.0	0
Other Commercial	Ventilation and Circulation	New	Energy Efficient Laboratory Fume Hood	Energy Efficient Laboratory Fume Hood	Standard Fume Hood	Per Building	67.37	13	\$3,050.87	5%	59%	\$6.93	0.0	0
Other Commercial	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	881.65	15	\$9.34	95%	76%	\$0.00	71.4	714
Other Commercial	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	881.65	15	\$9.34	95%	76%	\$0.00	71.4	18
Other Commercial	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	450.09	15	\$9.34	95%	76%	\$0.00	36.4	354
Other Commercial	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	450.09	15	\$9.34	95%	76%	\$0.00	36.4	9
Other Commercial	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	691.00	15	\$9.34	95%	76%	\$0.00	56.0	553
Other Commercial	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	691.00	15	\$9.34	95%	76%	\$0.00	56.0	14



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	448.22	15	\$9.34	95%	76%	\$0.00	36.3	351
Other Commercial	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	448.22	15	\$9.34	95%	76%	\$0.00	36.3	9
Other Commercial	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	508.47	15	\$9.34	95%	76%	\$0.00	41.2	403
Other Commercial	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	508.47	15	\$9.34	95%	76%	\$0.00	41.2	10
Other Commercial	Ventilation and Circulation	Existing	High Efficiency Ventilation Hoods	High Efficiency Ventilation Hoods	Standard Ventilation Hood	Per Kitchen Exhaust Hood HP	168.23	15	\$74.55	5%	65%	\$0.06	1.7	6
Other Commercial	Ventilation and Circulation	New	High Efficiency Ventilation Hoods	High Efficiency Ventilation Hoods	Standard Ventilation Hood	Per Kitchen Exhaust Hood HP	168.23	15	\$74.55	5%	65%	\$0.06	1.7	0
Other Commercial	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	28293.99	13	\$4,950.02	75%	98%	\$0.03	3.9	22,419
Other Commercial	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	9301.23	13	\$1,635.26	75%	98%	\$0.03	3.8	4,534
Other Commercial	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	33.05	12	\$43.07	5%	95%	\$0.21	0.5	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat GT 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	33.05	12	\$43.07	5%	95%	\$0.21	0.5	0
Other Commercial	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	33.05	12	\$43.07	5%	100%	\$0.21	0.5	0
Other Commercial	Water Heat GT 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	33.05	12	\$43.07	5%	100%	\$0.21	0.5	0
Other Commercial	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	222.10	25	\$4,090.99	5%	100%	\$2.10	0.1	0
Other Commercial	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	96.96	25	\$4,090.99	25%	100%	\$4.80	0.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	37.75	11	\$43.21	100%	34%	\$0.19	0.5	0
Other Commercial	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	37.75	11	\$43.21	100%	34%	\$0.19	0.5	0
Other Commercial	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	74.37	11	\$104.93	100%	95%	\$0.24	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	74.37	11	\$104.93	100%	95%	\$0.24	0.4	0
Other Commercial	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	38.33	11	\$61.72	100%	95%	\$0.27	0.4	0
Other Commercial	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	38.33	11	\$61.72	100%	95%	\$0.27	0.4	0
Other Commercial	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.89	10	\$9.07	100%	25%	\$0.15	0.7	0
Other Commercial	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.89	10	\$9.07	100%	55%	\$0.15	0.7	0
Other Commercial	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	558.58	14	\$4,663.64	50%	95%	\$1.23	0.1	0
Other Commercial	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	243.85	14	\$4,663.64	50%	95%	\$2.81	0.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	33.41	8	\$576.82	50%	75%	\$3.62	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/c Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat GT 55 Gal	Existing	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	133.37	7	\$43.46	5%	80%	\$0.08	1.2	0
Other Commercial	Water Heat GT 55 Gal	New	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	133.37	7	\$43.46	5%	80%	\$0.08	1.2	0
Other Commercial	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	365.24	14	\$106.71	100%	82%	\$0.04	2.5	17
Other Commercial	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	5.55	15	\$224.27	75%	90%	\$5.71	0.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	543.49	7	\$309.76	95%	98%	\$0.13	0.7	0
Other Commercial	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	237.26	7	\$309.76	75%	98%	\$0.30	0.3	0
Other Commercial	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	397.49	7	\$245.45	95%	88%	\$0.14	0.7	0
Other Commercial	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	173.53	7	\$245.45	75%	88%	\$0.33	0.3	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	150.08	12	\$0.00	95%	75%	\$0.00	999.0	7
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	150.08	12	\$0.00	95%	75%	\$0.00	999.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	105.94	12	\$0.00	95%	50%	\$0.00	999.0	0
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	105.94	12	\$0.00	95%	50%	\$0.00	999.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	61.80	12	\$0.00	95%	35%	\$0.00	999.0	0
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	61.80	12	\$0.00	95%	35%	\$0.00	999.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	70.62	12	\$18.91	95%	25%	\$0.04	2.4	1
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-Flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	2.36	5	\$3.16	95%	25%	\$0.40	0.2	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	21.37	5	\$2.26	95%	90%	\$0.03	2.9	1
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	21.37	5	\$2.26	95%	90%	\$0.03	2.9	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	35.48	9	\$7.83	75%	85%	\$0.04	2.2	1
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	35.48	9	\$7.83	75%	85%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	26.61	9	\$5.87	75%	75%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	26.61	9	\$5.87	75%	75%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	17.74	9	\$3.92	75%	50%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	17.74	9	\$3.92	75%	50%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	17.74	9	\$3.92	75%	35%	\$0.04	2.2	0
Other Commercial	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	17.74	9	\$3.92	75%	35%	\$0.04	2.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat GT 55 Gal	Existing	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozoneating Clothes Washer	671.85	10	\$183.89	0%	98%	\$0.05	2.0	0
Other Commercial	Water Heat GT 55 Gal	New	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozoneating Clothes Washer	293.30	10	\$183.89	0%	98%	\$0.11	0.9	0
Other Commercial	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.01	15	\$1.24	100%	100%	\$113.10	0.0	0
Other Commercial	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.01	15	\$1.24	100%	100%	\$113.10	0.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	97.11	12	\$2,289.12	75%	85%	\$3.78	0.0	0
Other Commercial	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	97.11	12	\$2,289.12	75%	85%	\$3.78	0.0	0
Other Commercial	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.00	10	\$0.02	90%	100%	\$1.74	0.1	0
Other Commercial	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.00	10	\$0.02	90%	100%	\$1.74	0.1	0
Other Commercial	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	155.47	2	\$83.45	75%	94%	\$0.36	0.2	0
Other Commercial	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	70.14	12	\$43.07	5%	95%	\$0.10	1.0	1



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat LE 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	70.14	12	\$43.07	5%	95%	\$0.10	1.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	70.14	12	\$43.07	5%	100%	\$0.10	1.0	0
Other Commercial	Water Heat LE 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	70.14	12	\$43.07	5%	100%	\$0.10	1.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	201.86	25	\$4,090.99	5%	100%	\$2.31	0.1	0
Other Commercial	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	201.06	25	\$4,090.99	25%	100%	\$2.31	0.1	0
Other Commercial	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	37.75	11	\$43.21	100%	34%	\$0.19	0.5	0
Other Commercial	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	37.75	11	\$43.21	100%	34%	\$0.19	0.5	0
Other Commercial	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF	Per Residential Clothes Washer	74.37	11	\$104.93	100%	95%	\$0.24	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					8.0 (Electric DHW & Dryer)									
Other Commercial	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	74.37	11	\$104.93	100%	95%	\$0.24	0.4	0
Other Commercial	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	38.33	11	\$61.72	100%	95%	\$0.27	0.4	0
Other Commercial	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	38.33	11	\$61.72	100%	95%	\$0.27	0.4	0
Other Commercial	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.89	10	\$9.07	100%	25%	\$0.15	0.7	0
Other Commercial	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	10.89	10	\$9.07	100%	55%	\$0.15	0.7	0
Other Commercial	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	507.67	14	\$4,663.64	50%	95%	\$1.35	0.1	0
Other Commercial	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	505.66	14	\$4,663.64	50%	95%	\$1.35	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	30.36	8	\$576.82	50%	75%	\$3.99	0.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	133.37	7	\$43.46	5%	80%	\$0.08	1.2	1
Other Commercial	Water Heat LE 55 Gal	New	High-efficiency coin-op washer w/ Electric water heat	High-efficiency coin-op washer w/ Electric water heat	Federal Standard 2013 Coin-op Electric Washer Top-loading, 1.60 MEF and 8.5 WF	Per Commercial Clothes Washer	133.37	7	\$43.46	5%	80%	\$0.08	1.2	0
Other Commercial	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	365.24	14	\$106.71	100%	82%	\$0.04	2.5	45
Other Commercial	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	5.05	15	\$224.27	75%	90%	\$6.28	0.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	488.87	7	\$309.76	95%	98%	\$0.15	0.6	0
Other Commercial	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	486.93	7	\$309.76	75%	98%	\$0.15	0.6	0
Other Commercial	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	354.86	7	\$245.45	95%	88%	\$0.16	0.6	0
Other Commercial	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	353.46	7	\$245.45	75%	88%	\$0.16	0.6	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	318.45	12	\$0.00	95%	75%	\$0.00	999.0	53

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	318.45	12	\$0.00	95%	75%	\$0.00	999.0	1
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	224.79	12	\$0.00	95%	50%	\$0.00	999.0	0
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	224.79	12	\$0.00	95%	50%	\$0.00	999.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	131.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	131.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	149.86	12	\$18.91	95%	25%	\$0.02	5.0	8
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	5.00	5	\$3.16	95%	25%	\$0.19	0.5	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	45.35	5	\$2.26	95%	90%	\$0.02	6.1	9
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	45.35	5	\$2.26	95%	90%	\$0.02	6.1	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	75.28	9	\$7.83	75%	85%	\$0.02	4.8	11
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	75.28	9	\$7.83	75%	85%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	56.46	9	\$5.87	75%	75%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	56.46	9	\$5.87	75%	75%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	37.64	9	\$3.92	75%	50%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	37.64	9	\$3.92	75%	50%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	37.64	9	\$3.92	75%	35%	\$0.02	4.8	2



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Other Commercial	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	37.64	9	\$3.92	75%	35%	\$0.02	4.8	0
Other Commercial	Water Heat LE 55 Gal	Existing	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	610.62	10	\$183.89	0%	98%	\$0.05	1.8	0
Other Commercial	Water Heat LE 55 Gal	New	Ozone commercial laundry system	Ozone commercial laundry system	Standard Commercial Laundry System	Per Ozonating Clothes Washer	608.20	10	\$183.89	0%	98%	\$0.05	1.8	0
Other Commercial	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.02	15	\$0.96	100%	100%	\$19.22	0.0	0
Other Commercial	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.02	15	\$0.96	100%	100%	\$19.22	0.0	0
Other Commercial	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	206.05	12	\$2,289.12	75%	85%	\$1.78	0.1	0
Other Commercial	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	206.05	12	\$2,289.12	75%	85%	\$1.78	0.1	0
Other Commercial	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.02	10	\$0.16	90%	100%	\$1.44	0.1	0
Other Commercial	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.02	10	\$0.16	90%	100%	\$1.44	0.1	0
Other Commercial	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	141.30	2	\$83.45	75%	94%	\$0.40	0.2	0
Restaurant	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.05	4	\$0.83	95%	86%	\$6.37	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.05	4	\$0.83	95%	86%	\$6.13	0.0	0
Restaurant	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.04	4	\$0.00	90%	100%	\$0.00	2,996.0	20
Restaurant	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.04	4	\$0.00	90%	100%	\$0.00	2,996.0	1
Restaurant	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	238.22	5	\$52.94	50%	80%	\$0.07	1.3	41
Restaurant	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	238.22	5	\$52.94	50%	80%	\$0.07	1.3	1
Restaurant	Cooking	Existing	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	1730.10	12	\$0.01	35%	95%	\$0.00	105,979.8	328
Restaurant	Cooking	New	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	1730.10	12	\$0.01	35%	95%	\$0.00	105,979.8	8
Restaurant	Cooking	Existing	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	10612.75	12	\$200.00	20%	95%	\$0.00	32.5	1,151
Restaurant	Cooking	New	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	10612.75	12	\$200.00	20%	95%	\$0.00	32.5	28
Restaurant	Cooking	Existing	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	6367.75	12	\$0.01	90%	90%	\$0.00	390,066.1	2,944
Restaurant	Cooking	New	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	6367.75	12	\$0.01	90%	90%	\$0.00	390,066.1	72



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooking	Existing	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	1937.14	12	\$0.01	40%	55%	\$0.00	118,662.4	0
Restaurant	Cooking	New	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	1937.14	12	\$0.01	40%	55%	\$0.00	118,662.4	0
Restaurant	Cooking	Existing	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	951.66	12	\$210.00	0%	95%	\$0.04	2.8	0
Restaurant	Cooking	New	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	951.66	12	\$210.00	0%	95%	\$0.04	2.8	0
Restaurant	Cooking	Existing	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	954.54	12	\$0.01	75%	95%	\$0.00	116,942.9	388
Restaurant	Cooking	New	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	954.54	12	\$0.01	75%	95%	\$0.00	116,942.9	10
Restaurant	Cooking	Existing	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	5778.55	12	\$2,994.00	95%	95%	\$0.08	1.2	2,977
Restaurant	Cooking	New	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	5778.55	12	\$2,994.00	95%	95%	\$0.08	1.2	73
Restaurant	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	1702.14	10	\$60.96	100%	49%	\$0.01	16.4	0
Restaurant	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	20.96	20	\$2,512.11	95%	95%	\$14.80	0.0	0
Restaurant	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	20.89	20	\$2,512.11	95%	95%	\$14.85	0.0	0
Restaurant	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	9.42	15	\$1,685.00	95%	95%	\$25.29	0.0	0
Restaurant	Cooling Chillers	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	5202.81	15	\$3,152.46	25%	62%	\$0.09	1.4	0
Restaurant	Cooling Chillers	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	3151.39	15	\$1,576.23	25%	95%	\$0.07	1.7	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling Chillers	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	3140.62	15	\$1,576.23	75%	95%	\$0.07	1.6	0
Restaurant	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.43	20	\$1.10	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	New	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.43	20	\$1.10	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	Existing	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.14	20	\$0.37	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	New	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.14	20	\$0.37	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.32	20	\$0.81	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	New	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.32	20	\$0.81	90%	100%	\$0.31	0.4	0
Restaurant	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	1890.83	15	#####	95%	75%	\$1.15	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	1413.28	7	\$5,541.43	75%	85%	\$0.91	0.1	0
Restaurant	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	97.03	20	#####	75%	99%	\$77.40	0.0	0
Restaurant	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	96.69	20	#####	75%	99%	\$77.66	0.0	0
Restaurant	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	1596.70	30	\$157.16	20%	84%	\$0.01	12.8	0
Restaurant	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	1591.25	30	\$157.16	80%	84%	\$0.01	12.8	0
Restaurant	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	1512.67	7	\$1,501.73	75%	75%	\$0.23	0.4	0
Restaurant	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	1701.75	18	\$11,994.90	1%	98%	\$0.91	0.1	0
Restaurant	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	1695.94	18	\$11,994.90	1%	98%	\$0.91	0.1	0
Restaurant	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	3428.00	13	\$1,245.51	75%	98%	\$0.06	2.0	0
Restaurant	Cooling Chillers	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	4767.86	15	\$2,049.20	10%	66%	\$0.06	1.9	0
Restaurant	Cooling Chillers	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	3151.39	15	\$1,024.60	10%	95%	\$0.05	2.5	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling Chillers	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	3140.62	15	\$1,024.60	50%	95%	\$0.05	2.5	0
Restaurant	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	472.71	5	\$1,183.12	50%	95%	\$0.76	0.1	0
Restaurant	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	471.09	5	\$1,183.12	50%	95%	\$0.76	0.1	0
Restaurant	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	2224.63	10	\$60.96	100%	49%	\$0.00	21.5	121
Restaurant	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	177.97	20	\$2,512.11	95%	95%	\$1.74	0.1	0
Restaurant	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	160.63	20	\$2,512.11	95%	95%	\$1.93	0.1	0
Restaurant	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	11.15	15	\$1,685.00	95%	95%	\$21.36	0.0	0
Restaurant	Cooling DX	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	6799.87	15	\$3,152.46	25%	62%	\$0.07	1.8	74
Restaurant	Cooling DX	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	4118.74	15	\$1,576.23	25%	95%	\$0.05	2.2	74
Restaurant	Cooling DX	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	3717.51	15	\$1,576.23	75%	95%	\$0.06	1.9	5
Restaurant	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	2471.25	15	\$3,220.63	95%	95%	\$0.18	0.6	0
Restaurant	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	1047.48	5	\$629.73	95%	45%	\$0.18	0.6	0
Restaurant	Cooling DX	Existing	DX Package 65 to 135 kBtuh - High Efficiency	High Efficiency - 11.5 EER - DX Package 65 to 135 kBtuh	Standard Efficiency - 11.2 EER - DX Package 65 to 135 kBtuh	Per Building	0.05	15	\$0.05	90%	100%	\$0.14	0.8	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling DX	New	DX Package 65 to 135 kBtuh - High Efficiency	High Efficiency - 11.5 EER - DX Package 65 to 135 kBtuh	Standard Efficiency - 11.2 EER - DX Package 65 to 135 kBtuh	Per Building	0.05	15	\$0.05	90%	100%	\$0.14	0.8	0
Restaurant	Cooling DX	Existing	DX Package 65 to 135 kBtuh - Premium Efficiency	Premium Efficiency - 12.0 EER - DX Package 65 to 135 kBtuh	Standard Efficiency - 11.2 EER - DX Package 65 to 135 kBtuh	Per Building	0.13	15	\$0.14	90%	100%	\$0.15	0.8	0
Restaurant	Cooling DX	New	DX Package 65 to 135 kBtuh - Premium Efficiency	Premium Efficiency - 12.0 EER - DX Package 65 to 135 kBtuh	Standard Efficiency - 11.2 EER - DX Package 65 to 135 kBtuh	Per Building	0.13	15	\$0.14	90%	100%	\$0.15	0.8	0
Restaurant	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1285.05	15	\$1,385.36	5%	99%	\$0.15	0.8	0
Restaurant	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1159.86	15	\$738.86	5%	99%	\$0.09	1.3	0
Restaurant	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	213.56	15	\$2,249.04	95%	85%	\$1.49	0.1	0
Restaurant	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	213.56	15	\$1,709.27	45%	80%	\$1.13	0.1	0
Restaurant	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	5834.89	15	\$51,440.13	90%	100%	\$1.25	0.1	0
Restaurant	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	1672.88	7	\$5,541.43	95%	85%	\$0.77	0.1	0
Restaurant	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	823.75	20	#####	75%	99%	\$9.12	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	743.50	20	#####	75%	99%	\$10.10	0.0	0
Restaurant	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	1047.48	10	\$629.73	95%	24%	\$0.11	1.0	0
Restaurant	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2086.83	30	\$157.16	20%	84%	\$0.01	16.7	29
Restaurant	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	1883.54	30	\$157.16	80%	84%	\$0.01	15.1	3
Restaurant	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	2653.56	10	\$2,878.78	10%	45%	\$0.20	0.5	0
Restaurant	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	1977.00	7	\$1,501.73	95%	75%	\$0.18	0.6	0
Restaurant	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2224.12	18	\$11,994.90	1%	98%	\$0.70	0.2	0
Restaurant	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2007.45	18	\$11,994.90	1%	98%	\$0.77	0.2	0
Restaurant	Cooling DX	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	6231.40	15	\$2,049.20	10%	66%	\$0.05	2.5	32
Restaurant	Cooling DX	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	4118.74	15	\$1,024.60	10%	95%	\$0.04	3.3	32
Restaurant	Cooling DX	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	3717.51	15	\$1,024.60	50%	95%	\$0.04	3.0	4
Restaurant	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	617.81	5	\$1,183.12	50%	95%	\$0.58	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	557.63	5	\$1,183.12	50%	95%	\$0.64	0.2	0
Restaurant	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	4
Restaurant	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	0
Restaurant	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	2
Restaurant	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	0
Restaurant	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	2
Restaurant	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	0
Restaurant	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	5121.09	10	\$60.96	100%	49%	\$0.00	45.5	232
Restaurant	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	152.76	20	\$2,512.11	95%	95%	\$2.03	0.1	0
Restaurant	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	143.75	20	\$2,512.11	95%	95%	\$2.16	0.1	0
Restaurant	Heat Pump	Existing	Air Source Heat Pump 65 to 135 kBtuh - High Efficiency	High Efficiency - 11.5 EER, 3.4 COP - Air Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.19	15	\$0.33	90%	100%	\$0.24	0.4	0
Restaurant	Heat Pump	New	Air Source Heat Pump 65 to 135 kBtuh - High Efficiency	High Efficiency - 11.5 EER, 3.4 COP - Air Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.19	15	\$0.33	90%	100%	\$0.24	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Heat Pump	Existing	Air Source Heat Pump 65 to 135 kBtuh - Premium Efficiency	Premium Efficiency - 12.0 EER, 3.8 COP - Air Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.62	15	\$0.66	90%	100%	\$0.15	0.7	0
Restaurant	Heat Pump	New	Air Source Heat Pump 65 to 135 kBtuh - Premium Efficiency	Premium Efficiency - 12.0 EER, 3.8 COP - Air Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.62	15	\$0.66	90%	100%	\$0.15	0.7	0
Restaurant	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	749.36	15	\$1,685.00	95%	95%	\$0.32	0.3	0
Restaurant	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	473.36	15	\$1,685.00	95%	95%	\$0.50	0.2	0
Restaurant	Heat Pump	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	17619.26	15	\$3,152.46	25%	62%	\$0.03	4.2	164
Restaurant	Heat Pump	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	10672.14	15	\$1,576.23	25%	95%	\$0.02	5.1	165
Restaurant	Heat Pump	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	10042.42	15	\$1,576.23	75%	95%	\$0.02	4.8	12
Restaurant	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	2121.23	15	\$3,220.63	95%	95%	\$0.21	0.5	0
Restaurant	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	899.12	5	\$629.73	95%	45%	\$0.21	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2987.14	15	\$1,385.36	5%	99%	\$0.07	1.6	10
Restaurant	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2810.88	15	\$738.86	5%	99%	\$0.04	2.9	0
Restaurant	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	183.32	15	\$2,249.04	95%	85%	\$1.73	0.1	0
Restaurant	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	183.32	15	\$1,709.27	45%	80%	\$1.32	0.1	0
Restaurant	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	4519.09	7	\$5,541.43	95%	85%	\$0.28	0.3	0
Restaurant	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1253.15	20	#####	75%	99%	\$5.99	0.0	0
Restaurant	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1179.21	20	#####	75%	99%	\$6.37	0.0	0
Restaurant	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump 65 to 135 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	1.26	15	\$19.51	90%	100%	\$2.19	0.0	0
Restaurant	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump 65 to 135 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	1.26	15	\$19.51	90%	100%	\$2.19	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	899.12	10	\$629.73	95%	24%	\$0.13	0.8	0
Restaurant	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	1791.26	30	\$157.16	20%	84%	\$0.01	13.1	21
Restaurant	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	1685.57	30	\$157.16	80%	84%	\$0.01	12.3	2
Restaurant	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	2653.56	10	\$2,878.78	10%	45%	\$0.20	0.5	0
Restaurant	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	5122.63	7	\$1,501.73	95%	75%	\$0.07	1.4	241
Restaurant	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	1909.11	18	\$11,994.90	1%	98%	\$0.81	0.1	0
Restaurant	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	1796.46	18	\$11,994.90	1%	98%	\$0.86	0.1	0
Restaurant	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	19017.49	15	#####	50%	95%	\$1.49	0.1	0
Restaurant	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	17895.34	15	#####	95%	95%	\$1.58	0.1	0
Restaurant	Heat Pump	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	16146.29	15	\$2,049.20	10%	66%	\$0.02	5.9	72
Restaurant	Heat Pump	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	10672.14	15	\$1,024.60	10%	95%	\$0.01	7.8	71
Restaurant	Heat Pump	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	10042.42	15	\$1,024.60	50%	95%	\$0.01	7.4	9



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump 65 to 135 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.91	15	\$1.32	90%	100%	\$0.21	0.5	0
Restaurant	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump 65 to 135 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - 65 to 135 kBtuh	Standard Efficiency - 11.0 EER, 3.3 COP - Air Source Heat Pump 65 to 135 kBtuh	Per Building	0.91	15	\$1.32	90%	100%	\$0.21	0.5	0
Restaurant	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1600.82	5	\$1,183.12	50%	95%	\$0.22	0.4	0
Restaurant	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1506.36	5	\$1,183.12	50%	95%	\$0.24	0.4	0
Restaurant	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	321.40	10	\$100.00	85%	45%	\$0.06	1.7	12
Restaurant	Lighting Exterior	Existing	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	1183.62	15	\$17.36	100%	95%	\$0.00	50.3	642
Restaurant	Lighting Exterior	New	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	1183.62	15	\$17.36	100%	95%	\$0.00	50.3	16
Restaurant	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	899.93	8	\$225.00	50%	45%	\$0.05	1.8	20
Restaurant	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	899.93	8	\$225.00	50%	75%	\$0.05	1.8	1
Restaurant	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	771.37	8	\$307.53	10%	100%	\$0.08	1.1	7
Restaurant	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	852.10	10	\$100.00	85%	45%	\$0.02	4.5	11

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	108.39	13	\$6.00	0%	85%	\$0.01	11.9	0
Restaurant	Lighting Interior Fluorescent	Existing	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	535.00	15	\$697.67	50%	95%	\$0.18	0.6	0
Restaurant	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	1860.71	8	\$3,670.26	65%	100%	\$0.41	0.2	0
Restaurant	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	2300.68	10	\$886.63	10%	98%	\$0.07	1.4	105
Restaurant	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.13	13	\$0.09	90%	100%	\$0.11	1.0	0
Restaurant	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.14	13	\$0.34	90%	100%	\$0.37	0.3	0
Restaurant	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.18	13	\$0.19	90%	100%	\$0.16	0.6	0
Restaurant	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.05	13	\$0.08	90%	100%	\$0.22	0.5	0
Restaurant	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.28	20	\$1.13	90%	100%	\$0.49	0.2	0
Restaurant	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	2045.05	8	\$505.77	45%	98%	\$0.05	1.8	127
Restaurant	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	2045.05	8	\$307.53	10%	99%	\$0.03	2.9	29



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	97.81	10	\$100.00	85%	45%	\$0.18	0.5	0
Restaurant	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	213.58	8	\$3,670.26	65%	100%	\$3.61	0.0	0
Restaurant	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	264.09	10	\$886.63	10%	98%	\$0.60	0.2	0
Restaurant	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal Halide - Above Standard	Efficient Metal Halide	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.02	15	\$0.01	90%	100%	\$0.07	1.6	0
Restaurant	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.08	15	\$0.02	90%	100%	\$0.04	2.5	73
Restaurant	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.13	20	\$0.03	90%	100%	\$0.03	4.2	6
Restaurant	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.10	20	-\$0.02	90%	100%	-\$0.02	999.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	234.74	8	\$505.77	45%	98%	\$0.45	0.2	0
Restaurant	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	234.74	8	\$307.53	10%	99%	\$0.28	0.3	0
Restaurant	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	152.07	10	\$38.00	95%	25%	\$0.04	2.1	5
Restaurant	Lighting Interior Other	New	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	535.00	15	\$697.67	50%	95%	\$0.18	0.6	0
Restaurant	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.51	15	\$0.03	100%	100%	\$0.01	14.8	0
Restaurant	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.76	15	\$0.04	100%	100%	\$0.01	13.8	0
Restaurant	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	1.52	15	\$0.17	100%	100%	\$0.02	6.5	122
Restaurant	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	6120.72	8	\$3,670.26	65%	100%	\$0.13	0.7	0
Restaurant	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	112.83	16	\$48.00	95%	50%	\$0.06	1.8	26
Restaurant	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	7568.01	10	\$886.63	30%	98%	\$0.02	4.5	20
Restaurant	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	6727.12	8	\$505.77	45%	98%	\$0.02	5.8	6
Restaurant	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	294.34	30	\$30.00	75%	95%	\$0.01	11.1	102



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	294.34	30	\$30.00	75%	95%	\$0.01	11.1	2
Restaurant	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	653.06	10	\$100.00	85%	45%	\$0.03	3.4	2
Restaurant	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	1426.07	8	\$3,670.26	65%	100%	\$0.54	0.2	0
Restaurant	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	1763.27	10	\$886.63	10%	98%	\$0.09	1.1	20
Restaurant	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	Per Building	0.55	5	\$0.01	90%	100%	\$0.01	14.7	632
Restaurant	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	Per Building	0.45	2	\$0.01	90%	100%	\$0.01	8.3	0
Restaurant	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	Per Building	0.59	12	\$0.07	90%	100%	\$0.03	3.9	982
Restaurant	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	1567.35	8	\$505.77	45%	98%	\$0.07	1.4	24
Restaurant	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	1567.35	8	\$307.53	10%	99%	\$0.04	2.2	5
Restaurant	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	29.12	15	\$2.80	75%	75%	\$0.01	7.7	9
Restaurant	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	29.12	15	\$2.80	75%	75%	\$0.01	7.7	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	5.95	4	\$0.59	100%	20%	\$0.04	2.4	1
Restaurant	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	5.95	4	\$0.59	100%	20%	\$0.04	2.4	0
Restaurant	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	784.09	10	\$0.00	95%	20%	\$0.00	999.0	85
Restaurant	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	784.09	10	\$0.00	95%	20%	\$0.00	999.0	2
Restaurant	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.14	5	\$0.55	95%	20%	\$1.24	0.1	0
Restaurant	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.14	5	\$0.55	95%	20%	\$1.24	0.1	0
Restaurant	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	54.70	5	\$9.26	95%	95%	\$0.05	1.8	8
Restaurant	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	54.70	5	\$9.26	95%	95%	\$0.05	1.8	0
Restaurant	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.01	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Restaurant	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.01	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Restaurant	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.02	5	\$0.00	90%	100%	\$0.00	4,559.7	2
Restaurant	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.02	5	\$0.00	90%	100%	\$0.00	4,559.7	0
Restaurant	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	5406.08	12	\$370.05	50%	67%	\$0.01	9.0	935
Restaurant	Refrigeration	New	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	5406.08	12	\$370.05	50%	67%	\$0.01	9.0	23



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	9950.67	12	\$370.05	50%	67%	\$0.01	16.5	1,893
Restaurant	Refrigeration	New	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	9950.67	12	\$370.05	50%	67%	\$0.01	16.5	47
Restaurant	Refrigeration	Existing	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	577.18	8	\$93.69	95%	80%	\$0.03	2.7	250
Restaurant	Refrigeration	New	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	577.18	8	\$93.69	95%	80%	\$0.03	2.7	6
Restaurant	Refrigeration	Existing	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	1392.81	8	\$93.69	95%	80%	\$0.01	6.5	604
Restaurant	Refrigeration	New	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	1392.81	8	\$93.69	95%	80%	\$0.01	6.5	15
Restaurant	Refrigeration	Existing	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	80.25	12	\$25.00	95%	81%	\$0.05	2.0	35
Restaurant	Refrigeration	New	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	80.25	12	\$25.00	95%	81%	\$0.05	2.0	1
Restaurant	Refrigeration	Existing	Compressor VSD retrofit	Compressor VSD retrofit	Base Refrigeration System - Grocery	Per Refrigerator/Freezer Compressor Motor HP	2249.18	15	\$1,281.46	70%	86%	\$0.08	1.3	457

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	Existing	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	224.03	10	\$1,321.33	60%	50%	\$1.06	0.1	0
Restaurant	Refrigeration	New	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	224.03	10	\$1,321.33	60%	50%	\$1.06	0.1	0
Restaurant	Refrigeration	Existing	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	56.01	10	\$1,321.33	90%	100%	\$4.25	0.0	0
Restaurant	Refrigeration	New	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	56.01	10	\$1,321.33	90%	100%	\$4.25	0.0	0
Restaurant	Refrigeration	Existing	Door Gasket - Cooler	Door Gasket - Cooler	Existing Gasket	Per linear foot of gasket on walk-in or reach-in cooler	216.22	4	\$48.05	95%	90%	\$0.08	1.1	106
Restaurant	Refrigeration	Existing	Door Gasket - Freezer	Door Gasket - Freezer	Existing Gasket	Per linear foot of gasket on walk-in or reach-in freezer	756.76	4	\$48.05	95%	90%	\$0.02	3.8	369
Restaurant	Refrigeration	Existing	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	1653.81	15	\$1,064.16	95%	93%	\$0.09	1.1	831
Restaurant	Refrigeration	New	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	1653.81	15	\$1,064.16	95%	93%	\$0.09	1.1	20
Restaurant	Refrigeration	Existing	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	342.71	15	\$458.73	10%	95%	\$0.19	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	New	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	342.71	15	\$458.73	5%	95%	\$0.19	0.6	0
Restaurant	Refrigeration	Existing	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	760.37	15	\$72.07	90%	100%	\$0.01	7.8	0
Restaurant	Refrigeration	New	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	760.37	15	\$72.07	90%	100%	\$0.01	7.8	0
Restaurant	Refrigeration	Existing	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	1688.08	15	\$780.80	65%	90%	\$0.07	1.6	435
Restaurant	Refrigeration	New	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	1688.08	15	\$780.80	95%	90%	\$0.07	1.6	16
Restaurant	Refrigeration	Existing	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	632.53	10	\$1,408.00	75%	55%	\$0.40	0.2	0
Restaurant	Refrigeration	New	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	632.53	10	\$1,408.00	95%	55%	\$0.40	0.2	0
Restaurant	Refrigeration	Existing	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	396.02	15	\$283.88	50%	85%	\$0.10	1.0	96

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	New	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	396.02	15	\$283.88	95%	92%	\$0.10	1.0	5
Restaurant	Refrigeration	Existing	Insulation for bare suction lines	Insulation for bare suction lines	No Insulation	Per linear feet of walk-in cooler/freezer suction line	591.81	11	\$316.33	95%	50%	\$0.09	1.1	83
Restaurant	Refrigeration	Existing	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	1845.33	8	\$1,406.19	95%	80%	\$0.16	0.6	0
Restaurant	Refrigeration	New	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	1845.33	8	\$1,406.19	95%	80%	\$0.16	0.6	0
Restaurant	Refrigeration	Existing	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	396.02	15	\$283.88	50%	95%	\$0.10	1.0	0
Restaurant	Refrigeration	New	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	396.02	15	\$283.88	95%	95%	\$0.10	1.0	0
Restaurant	Refrigeration	Existing	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	4111.75	15	\$2,207.23	95%	86%	\$0.08	1.4	1,918
Restaurant	Refrigeration	New	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	4111.75	15	\$2,207.23	95%	86%	\$0.08	1.4	47
Restaurant	Refrigeration	Existing	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	634.43	15	\$1,321.61	95%	49%	\$0.29	0.4	0
Restaurant	Refrigeration	New	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	634.43	15	\$1,321.61	0%	49%	\$0.29	0.4	0
Restaurant	Refrigeration	Existing	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	2505.32	15	\$1,321.61	95%	49%	\$0.07	1.4	666



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	New	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	2505.32	15	\$1,321.61	0%	49%	\$0.07	1.4	0
Restaurant	Refrigeration	Existing	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	1870.89	15	\$1,321.61	95%	49%	\$0.10	1.0	497
Restaurant	Refrigeration	New	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	1870.89	15	\$1,321.61	0%	49%	\$0.10	1.0	0
Restaurant	Refrigeration	Existing	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	2193.35	3	\$710.43	10%	85%	\$0.15	0.6	0
Restaurant	Refrigeration	New	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	2193.35	3	\$710.43	5%	90%	\$0.15	0.6	0
Restaurant	Refrigeration	Existing	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	946.71	4	\$95.86	95%	78%	\$0.04	2.4	400
Restaurant	Refrigeration	New	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	1452.73	4	\$95.86	95%	78%	\$0.02	3.7	15
Restaurant	Refrigeration	Existing	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	496.10	15	\$300.30	75%	49%	\$0.09	1.2	104
Restaurant	Refrigeration	New	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	496.10	15	\$300.30	95%	49%	\$0.09	1.2	3
Restaurant	Refrigeration	Existing	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	1327.34	15	\$300.30	75%	49%	\$0.03	3.3	278
Restaurant	Refrigeration	New	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	1327.34	15	\$300.30	95%	49%	\$0.03	3.3	9
Restaurant	Refrigeration	Existing	eCube	eCube	No eCube	Per Walk-in	1467.88	9	\$479.28	95%	95%	\$0.06	1.5	756

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Refrigeration	New	eCube	eCube	No eCube	Per Walk-in	1467.88	9	\$479.28	95%	95%	\$0.06	1.5	19
Restaurant	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.06	12	\$0.04	90%	100%	\$0.10	1.0	0
Restaurant	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.06	12	\$0.04	90%	100%	\$0.10	1.0	0
Restaurant	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.08	12	\$0.05	90%	100%	\$0.10	1.0	92
Restaurant	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.08	12	\$0.05	90%	100%	\$0.10	1.0	5
Restaurant	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.03	12	\$0.02	90%	100%	\$0.10	1.0	0
Restaurant	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.03	12	\$0.02	90%	100%	\$0.10	1.0	0
Restaurant	Room Cooling	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	6252.84	15	\$3,152.46	25%	62%	\$0.07	1.6	31
Restaurant	Room Cooling	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	3787.40	15	\$1,576.23	25%	95%	\$0.06	2.0	31
Restaurant	Room Cooling	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	3780.20	15	\$1,576.23	75%	95%	\$0.06	2.0	2
Restaurant	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.06	12	\$0.01	90%	100%	\$0.04	2.8	1
Restaurant	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.06	12	\$0.01	90%	100%	\$0.04	2.8	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.37	4	\$0.83	95%	86%	\$0.81	0.1	0
Restaurant	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.37	4	\$0.83	95%	86%	\$0.81	0.1	0
Restaurant	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.16	4	\$0.22	90%	100%	\$0.49	0.2	0
Restaurant	Servers	New	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.16	4	\$0.22	90%	100%	\$0.49	0.2	0
Restaurant	Space Heat	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	4002.16	10	\$60.96	100%	49%	\$0.00	33.7	3
Restaurant	Space Heat	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	933.84	15	\$1,685.00	95%	95%	\$0.26	0.4	0
Restaurant	Space Heat	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	613.67	15	\$1,685.00	95%	95%	\$0.39	0.3	0
Restaurant	Space Heat	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	14683.12	15	\$3,152.46	25%	62%	\$0.03	3.3	2
Restaurant	Space Heat	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	8893.70	15	\$1,576.23	25%	95%	\$0.03	4.0	2
Restaurant	Space Heat	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	8893.70	15	\$1,576.23	75%	95%	\$0.03	4.0	0
Restaurant	Space Heat	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2347.94	15	\$1,385.36	5%	99%	\$0.08	1.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Space Heat	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2347.94	15	\$738.86	5%	99%	\$0.04	2.3	0
Restaurant	Space Heat	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	17577.50	15	\$51,440.13	90%	100%	\$0.41	0.2	0
Restaurant	Space Heat	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	4002.16	7	\$5,541.43	95%	85%	\$0.32	0.3	0
Restaurant	Space Heat	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	680.51	20	#####	75%	99%	\$11.04	0.0	0
Restaurant	Space Heat	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	680.51	20	#####	75%	99%	\$11.04	0.0	0
Restaurant	Space Heat	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	4268.97	7	\$1,501.73	95%	75%	\$0.08	1.1	3
Restaurant	Space Heat	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	13455.61	15	\$2,049.20	10%	66%	\$0.02	4.7	1
Restaurant	Space Heat	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	8893.70	15	\$1,024.60	10%	95%	\$0.02	6.2	1
Restaurant	Space Heat	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	8893.70	15	\$1,024.60	50%	95%	\$0.02	6.2	0
Restaurant	Ventilation and Circulation	Existing	Downsizing motor during retrofit	Downsizing motor during retrofit	Larger hp standard motor	Per Motor	122.36	20	\$5,833.08	10%	95%	\$5.89	0.0	0
Restaurant	Ventilation and Circulation	Existing	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	2778.88	15	\$720.02	15%	95%	\$0.04	2.9	144
Restaurant	Ventilation and Circulation	New	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	2778.88	15	\$720.02	15%	95%	\$0.04	2.9	5



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Ventilation and Circulation	Existing	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	205.73	18	\$722.93	75%	95%	\$0.45	0.2	0
Restaurant	Ventilation and Circulation	New	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	205.73	18	\$722.93	75%	95%	\$0.45	0.2	0
Restaurant	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	252.53	15	\$1.76	95%	76%	\$0.00	106.0	104
Restaurant	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	252.53	15	\$1.76	95%	76%	\$0.00	106.0	3
Restaurant	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	128.92	15	\$1.76	95%	76%	\$0.00	54.1	51
Restaurant	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	128.92	15	\$1.76	95%	76%	\$0.00	54.1	1
Restaurant	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	197.93	15	\$1.76	95%	76%	\$0.00	83.1	80
Restaurant	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP,	Per Building	197.93	15	\$1.76	95%	76%	\$0.00	83.1	2

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/c Ratio	Achievable Potential (MWh)
					1200-3600 RPM									
Restaurant	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	128.38	15	\$1.76	95%	76%	\$0.00	53.9	51
Restaurant	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	128.38	15	\$1.76	95%	76%	\$0.00	53.9	1
Restaurant	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	145.64	15	\$1.76	95%	76%	\$0.00	61.1	59
Restaurant	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	145.64	15	\$1.76	95%	76%	\$0.00	61.1	1
Restaurant	Ventilation and Circulation	Existing	High Efficiency Ventilation Hoods	High Efficiency Ventilation Hoods	Standard Ventilation Hood	Per Kitchen Exhaust Hood HP	4486.00	15	\$1,988.00	95%	25%	\$0.06	1.7	608
Restaurant	Ventilation and Circulation	New	High Efficiency Ventilation Hoods	High Efficiency Ventilation Hoods	Standard Ventilation Hood	Per Kitchen Exhaust Hood HP	4486.00	15	\$1,988.00	95%	25%	\$0.06	1.7	15
Restaurant	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	6059.60	13	\$934.13	75%	98%	\$0.02	4.3	2,437
Restaurant	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	1409.14	13	\$308.59	75%	98%	\$0.03	3.0	404
Restaurant	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	881.45	12	\$1,148.46	95%	95%	\$0.21	0.5	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat GT 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	881.45	12	\$1,148.46	95%	95%	\$0.21	0.5	0
Restaurant	Water Heat GT 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	881.45	12	\$1,148.46	95%	33%	\$0.21	0.5	0
Restaurant	Water Heat GT 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	881.45	12	\$1,148.46	95%	33%	\$0.21	0.5	0
Restaurant	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	2420.56	25	\$2,121.25	5%	100%	\$0.10	1.2	1
Restaurant	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	1056.69	25	\$2,121.25	25%	100%	\$0.23	0.5	0
Restaurant	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.12	11	\$8.15	100%	34%	\$0.19	0.5	0
Restaurant	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.12	11	\$8.15	100%	34%	\$0.19	0.5	0
Restaurant	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF	Per Residential Clothes Washer	14.04	11	\$19.80	100%	95%	\$0.24	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					8.0 (Electric DHW & Dryer)									
Restaurant	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	14.04	11	\$19.80	100%	95%	\$0.24	0.4	0
Restaurant	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.23	11	\$11.65	100%	95%	\$0.27	0.4	0
Restaurant	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.23	11	\$11.65	100%	95%	\$0.27	0.4	0
Restaurant	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.00	10	\$7.50	100%	25%	\$0.15	0.6	0
Restaurant	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.00	10	\$7.50	100%	55%	\$0.15	0.6	0
Restaurant	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	6087.72	14	\$2,418.18	50%	95%	\$0.06	1.8	17
Restaurant	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	2657.58	14	\$2,418.18	50%	95%	\$0.13	0.8	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	364.08	8	\$299.09	50%	75%	\$0.17	0.5	0
Restaurant	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	189.38	14	\$55.33	100%	80%	\$0.04	2.4	1
Restaurant	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	60.51	15	\$224.27	75%	90%	\$0.52	0.2	0
Restaurant	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	5923.26	7	\$160.62	95%	94%	\$0.01	14.6	65
Restaurant	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	2585.79	7	\$160.62	75%	94%	\$0.01	6.4	1
Restaurant	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	4332.11	7	\$127.27	95%	84%	\$0.01	13.4	0
Restaurant	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	1891.18	7	\$127.27	75%	84%	\$0.02	5.9	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1180.60	12	\$0.00	95%	75%	\$0.00	999.0	11
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1180.60	12	\$0.00	95%	75%	\$0.00	999.0	1
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	833.36	12	\$0.00	95%	50%	\$0.00	999.0	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	833.36	12	\$0.00	95%	50%	\$0.00	999.0	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	486.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	486.13	12	\$0.00	95%	35%	\$0.00	999.0	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	555.58	12	\$8.92	95%	25%	\$0.00	38.4	2
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	62.88	5	\$84.37	95%	25%	\$0.40	0.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	569.89	5	\$60.26	95%	45%	\$0.03	2.8	3
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	569.89	5	\$60.26	95%	45%	\$0.03	2.8	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.10	9	\$0.89	75%	85%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.10	9	\$0.89	75%	85%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	5.32	9	\$0.67	75%	75%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	5.32	9	\$0.67	75%	75%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	3.55	9	\$0.44	75%	50%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	3.55	9	\$0.44	75%	50%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	3.55	9	\$0.44	75%	35%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	3.55	9	\$0.44	75%	35%	\$0.02	3.9	0
Restaurant	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.33	15	\$3.40	100%	100%	\$5.38	0.0	0
Restaurant	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.33	15	\$3.40	100%	100%	\$5.38	0.0	0
Restaurant	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	763.92	12	\$1,079.97	75%	85%	\$0.23	0.4	0
Restaurant	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	763.92	12	\$1,079.97	75%	85%	\$0.23	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.10	10	\$0.05	90%	100%	\$0.08	1.1	9
Restaurant	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.10	10	\$0.05	90%	100%	\$0.08	1.1	0
Restaurant	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	1694.40	2	\$43.27	75%	94%	\$0.02	4.9	8
Restaurant	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	1870.36	12	\$1,148.46	95%	95%	\$0.10	1.0	35
Restaurant	Water Heat LE 55 Gal	New	Dishwashing - Commercial - High Temp	High Efficiency Dishwasher (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	1870.36	12	\$1,148.46	95%	95%	\$0.10	1.0	1
Restaurant	Water Heat LE 55 Gal	Existing	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	1870.36	12	\$1,148.46	95%	33%	\$0.10	1.0	0
Restaurant	Water Heat LE 55 Gal	New	Dishwashing - Commercial - Low Temp	Low-Temp Commercial Dishwasher (Includes Extra Chemical Cost) - (ENERGY STAR)	Standard High Temp Commercial Dishwasher	Per Commercial Dishwasher	1870.36	12	\$1,148.46	95%	33%	\$0.10	1.0	0
Restaurant	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	2199.96	25	\$2,121.25	5%	100%	\$0.11	1.1	1
Restaurant	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	2191.25	25	\$2,121.25	25%	100%	\$0.11	1.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.12	11	\$8.15	100%	34%	\$0.19	0.5	0
Restaurant	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.12	11	\$8.15	100%	34%	\$0.19	0.5	0
Restaurant	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	14.04	11	\$19.80	100%	95%	\$0.24	0.4	0
Restaurant	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	14.04	11	\$19.80	100%	95%	\$0.24	0.4	0
Restaurant	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.23	11	\$11.65	100%	95%	\$0.27	0.4	0
Restaurant	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	7.23	11	\$11.65	100%	95%	\$0.27	0.4	0
Restaurant	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr	Per Residential Dishwasher	9.00	10	\$7.50	100%	25%	\$0.15	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					and 5.0 gal/cycle									
Restaurant	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.00	10	\$7.50	100%	55%	\$0.15	0.6	0
Restaurant	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	5532.91	14	\$2,418.18	50%	95%	\$0.06	1.6	22
Restaurant	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	5510.99	14	\$2,418.18	50%	95%	\$0.06	1.6	1
Restaurant	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	330.90	8	\$299.09	50%	75%	\$0.19	0.5	0
Restaurant	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	189.38	14	\$55.33	100%	80%	\$0.04	2.4	1
Restaurant	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	55.00	15	\$224.27	75%	90%	\$0.58	0.2	0
Restaurant	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	5327.93	7	\$160.62	95%	94%	\$0.01	13.1	86
Restaurant	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	5306.82	7	\$160.62	75%	94%	\$0.01	13.0	1
Restaurant	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	3867.50	7	\$127.27	95%	84%	\$0.01	12.0	0
Restaurant	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	3852.18	7	\$127.27	75%	84%	\$0.01	11.9	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2505.12	12	\$0.00	95%	75%	\$0.00	999.0	40
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	2505.12	12	\$0.00	95%	75%	\$0.00	999.0	1

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1768.32	12	\$0.00	95%	50%	\$0.00	999.0	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1768.32	12	\$0.00	95%	50%	\$0.00	999.0	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1031.52	12	\$0.00	95%	35%	\$0.00	999.0	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	1031.52	12	\$0.00	95%	35%	\$0.00	999.0	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	1178.88	12	\$8.92	95%	25%	\$0.00	81.4	6
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM (Existing to Code)	Existing Low-flow Pre-Rinse Spray Valve	Per Pre-Rinse Spray Valve	133.42	5	\$84.37	95%	25%	\$0.19	0.5	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	1209.25	5	\$60.26	95%	45%	\$0.02	5.9	12
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 0.6 GPM (Code to high Efficiency)	Low-Flow Pre-Rinse Spray Valves - 1.6 GPM	Per Pre-Rinse Spray Valve	1209.25	5	\$60.26	95%	45%	\$0.02	5.9	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	15.06	9	\$0.89	75%	85%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	15.06	9	\$0.89	75%	85%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	11.29	9	\$0.67	75%	75%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	11.29	9	\$0.67	75%	75%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.53	9	\$0.44	75%	50%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.53	9	\$0.44	75%	50%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	7.53	9	\$0.44	75%	35%	\$0.01	8.2	0
Restaurant	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	7.53	9	\$0.44	75%	35%	\$0.01	8.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Restaurant	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.35	15	\$2.63	100%	100%	\$0.91	0.1	0
Restaurant	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.35	15	\$2.63	100%	100%	\$0.91	0.1	0
Restaurant	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	1620.96	12	\$1,079.97	75%	85%	\$0.11	0.9	0
Restaurant	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	1620.96	12	\$1,079.97	75%	85%	\$0.11	0.9	0
Restaurant	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.12	10	\$0.43	90%	100%	\$0.07	1.4	79
Restaurant	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	1.12	10	\$0.43	90%	100%	\$0.07	1.4	2
Restaurant	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	1539.97	2	\$43.27	75%	94%	\$0.02	4.5	10
Retail	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.10	4	\$0.94	95%	86%	\$3.43	0.0	0
Retail	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.10	4	\$0.94	95%	86%	\$3.31	0.0	0
Retail	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.07	4	\$0.00	90%	100%	\$0.00	2,996.0	236
Retail	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.07	4	\$0.00	90%	100%	\$0.00	2,996.0	7

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	502.18	5	\$111.60	50%	80%	\$0.07	1.3	495
Retail	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	502.18	5	\$111.60	50%	80%	\$0.07	1.3	12
Retail	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	2766.79	10	\$69.26	100%	72%	\$0.00	24.4	0
Retail	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	34.07	20	\$3,188.15	95%	95%	\$11.56	0.0	0
Retail	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	33.96	20	\$3,188.15	95%	95%	\$11.59	0.0	0
Retail	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	15.01	15	\$1,685.00	95%	95%	\$15.88	0.0	0
Retail	Cooling Chillers	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	8287.38	15	\$4,000.81	25%	62%	\$0.07	1.8	0
Retail	Cooling Chillers	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	5019.74	15	\$2,000.41	25%	95%	\$0.06	2.2	0
Retail	Cooling Chillers	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	5002.59	15	\$2,000.41	75%	95%	\$0.06	2.2	0
Retail	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.60	20	\$0.90	90%	100%	\$0.18	0.7	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Cooling Chillers	New	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.60	20	\$0.90	90%	100%	\$0.18	0.7	0
Retail	Cooling Chillers	Existing	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.20	20	\$0.30	90%	100%	\$0.18	0.7	0
Retail	Cooling Chillers	New	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.20	20	\$0.30	90%	100%	\$0.18	0.7	0
Retail	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.45	20	\$0.67	90%	100%	\$0.18	0.7	0
Retail	Cooling Chillers	New	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.45	20	\$0.67	90%	100%	\$0.18	0.7	0
Retail	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3011.85	15	#####	95%	75%	\$0.68	0.2	0
Retail	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2251.17	7	\$6,295.92	75%	85%	\$0.65	0.2	0
Retail	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	154.55	20	#####	75%	99%	\$61.67	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	154.02	20	#####	75%	99%	\$61.88	0.0	0
Retail	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2543.34	30	\$136.85	20%	84%	\$0.01	24.4	0
Retail	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2534.65	30	\$136.85	80%	84%	\$0.01	24.3	0
Retail	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	2409.48	7	\$1,706.19	75%	75%	\$0.16	0.7	0
Retail	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2710.66	18	\$14,851.18	1%	98%	\$0.71	0.2	0
Retail	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2701.40	18	\$14,851.18	1%	98%	\$0.71	0.2	0
Retail	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	216.11	13	\$70.75	75%	98%	\$0.05	2.3	0
Retail	Cooling Chillers	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	7020.35	15	\$1,762.80	10%	66%	\$0.04	3.4	0
Retail	Cooling Chillers	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	5736.85	15	\$1,084.80	10%	95%	\$0.03	4.5	0
Retail	Cooling Chillers	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	5717.25	15	\$1,084.80	50%	95%	\$0.03	4.5	0
Retail	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	752.96	5	\$1,030.23	50%	95%	\$0.41	0.3	0
Retail	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	750.39	5	\$1,030.23	50%	95%	\$0.41	0.3	0
Retail	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	3755.69	10	\$69.26	100%	72%	\$0.00	33.2	924



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	300.46	20	\$3,188.15	95%	95%	\$1.31	0.1	0
Retail	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	291.17	20	\$3,188.15	95%	95%	\$1.35	0.1	0
Retail	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	19.81	15	\$1,685.00	95%	95%	\$12.03	0.0	0
Retail	Cooling DX	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	11249.45	15	\$4,000.81	25%	62%	\$0.05	2.4	360
Retail	Cooling DX	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6813.89	15	\$2,000.41	25%	95%	\$0.04	2.9	364
Retail	Cooling DX	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6603.36	15	\$2,000.41	75%	95%	\$0.04	2.8	25
Retail	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	4088.34	15	\$4,095.31	95%	95%	\$0.14	0.9	0
Retail	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	1768.39	5	\$779.69	95%	45%	\$0.13	0.8	0
Retail	Cooling DX	Existing	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.15	15	\$0.30	90%	100%	\$0.28	0.4	0
Retail	Cooling DX	New	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.15	15	\$0.30	90%	100%	\$0.28	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Cooling DX	Existing	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.24	15	\$0.48	90%	100%	\$0.29	0.4	0
Retail	Cooling DX	New	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.24	15	\$0.48	90%	100%	\$0.29	0.4	0
Retail	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2125.94	15	\$1,573.98	25%	99%	\$0.10	1.2	117
Retail	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2060.25	15	\$839.46	25%	99%	\$0.06	2.1	2
Retail	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	360.55	15	\$2,784.60	95%	64%	\$1.09	0.1	0
Retail	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	360.55	15	\$2,116.29	45%	80%	\$0.83	0.2	0
Retail	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	9653.02	15	#####	90%	100%	\$0.91	0.1	0
Retail	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2971.51	7	\$6,295.92	95%	85%	\$0.49	0.2	0
Retail	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1362.78	20	#####	75%	99%	\$6.99	0.0	0
Retail	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1320.67	20	#####	75%	99%	\$7.22	0.0	0
Retail	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	1768.39	10	\$800.76	95%	24%	\$0.08	1.4	93



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3452.37	30	\$136.85	20%	84%	\$0.00	33.1	144
Retail	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3345.70	30	\$136.85	80%	84%	\$0.00	32.1	16
Retail	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	3014.85	10	\$3,564.28	10%	45%	\$0.21	0.5	0
Retail	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	3270.67	7	\$1,706.19	95%	75%	\$0.12	0.9	0
Retail	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3679.50	18	\$14,851.18	1%	98%	\$0.52	0.2	0
Retail	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3565.82	18	\$14,851.18	1%	98%	\$0.54	0.2	0
Retail	Cooling DX	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	9529.56	15	\$1,762.80	10%	66%	\$0.03	4.6	147
Retail	Cooling DX	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	7787.31	15	\$1,084.80	10%	95%	\$0.02	6.2	178
Retail	Cooling DX	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	7546.70	15	\$1,084.80	50%	95%	\$0.02	6.0	23
Retail	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1022.08	5	\$1,030.23	50%	95%	\$0.30	0.3	0
Retail	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	990.50	5	\$1,030.23	50%	95%	\$0.31	0.3	0
Retail	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	22

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	1
Retail	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.02	4	\$0.00	90%	100%	\$0.00	743.5	29
Retail	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.02	4	\$0.00	90%	100%	\$0.00	743.5	0
Retail	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	2
Retail	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.03	3.2	0
Retail	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	6981.39	10	\$69.26	100%	72%	\$0.00	53.0	2,606
Retail	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	261.38	20	\$3,188.15	95%	95%	\$1.51	0.1	0
Retail	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	252.03	20	\$3,188.15	95%	95%	\$1.56	0.1	0
Retail	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.26	15	\$0.10	90%	100%	\$0.05	2.0	0
Retail	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.26	15	\$0.10	90%	100%	\$0.05	2.0	0
Retail	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.50	15	\$0.19	90%	100%	\$0.05	1.9	675
Retail	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.50	15	\$0.19	90%	100%	\$0.05	1.9	24



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	866.63	15	\$1,685.00	95%	95%	\$0.27	0.4	0
Retail	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	566.29	15	\$1,685.00	95%	95%	\$0.42	0.3	0
Retail	Heat Pump	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	23412.83	15	\$4,000.81	25%	62%	\$0.02	4.3	1,177
Retail	Heat Pump	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	14181.36	15	\$2,000.41	25%	95%	\$0.02	5.2	1,189
Retail	Heat Pump	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	13674.28	15	\$2,000.41	75%	95%	\$0.02	5.0	83
Retail	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3556.63	15	\$3,879.77	95%	95%	\$0.15	0.7	0
Retail	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	1538.41	5	\$779.69	95%	45%	\$0.15	0.6	0
Retail	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	4028.41	15	\$1,573.98	25%	99%	\$0.06	1.9	356
Retail	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	3884.37	15	\$839.46	25%	99%	\$0.03	3.4	7
Retail	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	313.66	15	\$2,784.60	95%	64%	\$1.26	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	313.66	15	\$2,116.29	45%	80%	\$0.95	0.1	0
Retail	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	6153.43	7	\$6,295.92	95%	85%	\$0.24	0.4	0
Retail	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1800.34	20	#####	75%	99%	\$5.29	0.0	0
Retail	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1735.96	20	#####	75%	99%	\$5.49	0.0	0
Retail	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.99	15	\$21.26	90%	100%	\$1.51	0.1	0
Retail	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.99	15	\$21.26	90%	100%	\$1.51	0.1	0
Retail	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	1538.41	10	\$758.61	95%	24%	\$0.09	1.1	109
Retail	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3003.38	30	\$136.85	20%	84%	\$0.00	24.4	193
Retail	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2895.98	30	\$136.85	80%	84%	\$0.01	23.5	21
Retail	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	3014.85	10	\$3,564.28	10%	45%	\$0.21	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	6807.05	7	\$1,706.19	95%	75%	\$0.06	1.6	1,696
Retail	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3200.97	18	\$14,851.18	1%	98%	\$0.60	0.2	0
Retail	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3086.51	18	\$14,851.18	1%	98%	\$0.62	0.2	0
Retail	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	25270.83	15	\$151,102.11	50%	95%	\$1.27	0.1	0
Retail	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	24367.22	15	\$151,102.11	95%	95%	\$1.32	0.1	0
Retail	Heat Pump	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	19833.33	15	\$1,762.80	10%	66%	\$0.01	8.2	479
Retail	Heat Pump	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	16207.27	15	\$1,084.80	10%	95%	\$0.01	10.9	582
Retail	Heat Pump	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	15627.75	15	\$1,084.80	50%	95%	\$0.01	10.5	77
Retail	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.47	15	\$1.97	90%	100%	\$0.19	0.5	0
Retail	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	1.47	15	\$1.97	90%	100%	\$0.19	0.5	0
Retail	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2127.20	5	\$1,030.23	50%	95%	\$0.15	0.6	0
Retail	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2051.14	5	\$1,030.23	50%	95%	\$0.15	0.6	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	365.16	10	\$100.00	85%	45%	\$0.05	2.0	88
Retail	Lighting Exterior	Existing	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	926.78	15	\$17.36	100%	95%	\$0.00	40.3	2,885
Retail	Lighting Exterior	New	LED or equivalent sign lighting	LED or equivalent sign lighting	Replace fluorescent sign lighting	Per Sign	926.78	15	\$17.36	100%	95%	\$0.00	40.3	71
Retail	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	1022.46	8	\$225.00	50%	45%	\$0.05	2.1	154
Retail	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	1022.46	8	\$225.00	50%	75%	\$0.05	2.1	6
Retail	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	876.39	8	\$275.31	10%	100%	\$0.07	1.4	53
Retail	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	1528.19	10	\$100.00	85%	45%	\$0.01	8.3	113
Retail	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	84.87	13	\$6.00	0%	85%	\$0.01	9.5	0
Retail	Lighting Interior Fluorescent	Existing	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	533.90	15	\$696.24	50%	95%	\$0.18	0.6	0
Retail	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	2927.13	8	\$3,905.48	65%	100%	\$0.28	0.3	0
Retail	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	4126.10	10	\$1,125.23	10%	98%	\$0.05	2.0	1,067
Retail	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.18	13	\$0.21	90%	100%	\$0.17	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.19	13	\$0.70	90%	100%	\$0.56	0.2	0
Retail	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.26	13	\$0.37	90%	100%	\$0.22	0.5	0
Retail	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.07	13	\$0.17	90%	100%	\$0.40	0.3	0
Retail	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.42	20	\$2.26	90%	100%	\$0.67	0.2	0
Retail	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	3667.65	8	\$574.63	45%	98%	\$0.03	2.9	1,291
Retail	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	3667.65	8	\$275.31	10%	99%	\$0.02	6.0	296
Retail	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	62.35	10	\$100.00	85%	45%	\$0.29	0.3	0
Retail	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	119.43	8	\$3,905.48	65%	100%	\$6.86	0.0	0
Retail	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	168.36	10	\$1,125.23	10%	98%	\$1.20	0.1	0
Retail	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal Halide - Above Standard	Efficient Metal Halide	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure	Per Building	0.01	15	\$0.02	90%	100%	\$0.17	0.6	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					Sodium, Metal Halide									
Retail	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.04	15	\$0.02	90%	100%	\$0.08	1.4	269
Retail	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.07	20	\$0.03	90%	100%	\$0.05	2.4	23
Retail	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.06	20	\$0.00	90%	100%	-\$0.01	999.0	0
Retail	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	149.65	8	\$574.63	45%	98%	\$0.81	0.1	0
Retail	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	149.65	8	\$275.31	10%	99%	\$0.39	0.2	0
Retail	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	38.02	10	\$9.50	95%	25%	\$0.04	2.2	8
Retail	Lighting Interior Other	New	Fiber Optic Display Lighting	Fiber Optic Display Lighting	Existing Display Lighting	Per Case Door	533.90	15	\$696.24	50%	95%	\$0.18	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.42	15	\$0.20	100%	100%	\$0.07	1.6	0
Retail	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.64	15	\$0.24	100%	100%	\$0.05	2.0	0
Retail	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	1.27	15	\$0.48	100%	100%	\$0.05	2.0	669
Retail	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	5117.40	8	\$3,905.48	65%	100%	\$0.16	0.6	0
Retail	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	28.21	16	\$12.00	95%	50%	\$0.06	1.9	37
Retail	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	7213.52	10	\$1,125.23	30%	98%	\$0.03	3.5	109
Retail	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	6412.02	8	\$574.63	45%	98%	\$0.02	5.0	33
Retail	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	73.58	30	\$7.50	75%	95%	\$0.01	11.3	147
Retail	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	73.58	30	\$7.50	75%	95%	\$0.01	11.3	3
Retail	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	203.82	10	\$100.00	85%	45%	\$0.09	1.1	16
Retail	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	390.40	8	\$3,905.48	65%	100%	\$2.10	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	550.31	10	\$1,125.23	10%	98%	\$0.37	0.3	0
Retail	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	Per Building	0.15	5	\$0.00	90%	100%	\$0.01	11.8	1,175
Retail	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	Per Building	0.12	2	\$0.00	90%	100%	\$0.01	6.7	0
Retail	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	Per Building	0.16	12	\$0.02	90%	100%	\$0.03	3.1	1,886
Retail	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	489.16	8	\$574.63	45%	98%	\$0.25	0.4	0
Retail	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	489.16	8	\$275.31	10%	99%	\$0.12	0.8	0
Retail	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	11
Retail	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	0
Retail	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	5.64	4	\$0.56	100%	20%	\$0.04	2.4	4
Retail	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	5.64	4	\$0.56	100%	20%	\$0.04	2.4	0
Retail	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	701.95	10	\$0.00	95%	20%	\$0.00	999.0	437
Retail	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	701.95	10	\$0.00	95%	20%	\$0.00	999.0	11



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.15	5	\$0.63	95%	20%	\$1.24	0.1	0
Retail	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.15	5	\$0.63	95%	20%	\$1.24	0.1	0
Retail	Other Plug Load	Existing	Escalator Motor Controller	Escalator Motor Controller	Standard Motor	Per Escalator Motor Controller	392.32	15	\$19.00	95%	90%	\$0.01	15.3	1,099
Retail	Other Plug Load	New	Escalator Motor Controller	Escalator Motor Controller	Standard Motor	Per Escalator Motor Controller	392.32	15	\$19.00	95%	90%	\$0.01	15.3	27
Retail	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	115.32	5	\$19.53	95%	95%	\$0.05	1.8	92
Retail	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	115.32	5	\$19.53	95%	95%	\$0.05	1.8	2
Retail	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	2
Retail	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Retail	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.03	5	\$0.00	90%	100%	\$0.00	4,559.7	18
Retail	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.03	5	\$0.00	90%	100%	\$0.00	4,559.7	0
Retail	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	1020.52	12	\$69.86	50%	50%	\$0.01	9.0	786

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigeration	New	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	1020.52	12	\$69.86	50%	50%	\$0.01	9.0	19
Retail	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	1878.42	12	\$69.86	50%	50%	\$0.01	16.5	1,539
Retail	Refrigeration	New	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	1878.42	12	\$69.86	50%	50%	\$0.01	16.5	38
Retail	Refrigeration	Existing	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	307.17	8	\$49.86	95%	80%	\$0.03	2.7	765
Retail	Refrigeration	New	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	307.17	8	\$49.86	95%	80%	\$0.03	2.7	19
Retail	Refrigeration	Existing	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	741.24	8	\$49.86	95%	80%	\$0.01	6.5	1,846
Retail	Refrigeration	New	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	741.24	8	\$49.86	95%	80%	\$0.01	6.5	45
Retail	Refrigeration	Existing	Compressor VSD retrofit	Compressor VSD retrofit	Base Refrigeration System - Grocery	Per Refrigerator/Freezer Compressor Motor HP	426.30	15	\$242.88	70%	86%	\$0.08	1.3	370
Retail	Refrigeration	Existing	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	59.61	10	\$351.60	60%	91%	\$1.06	0.1	0
Retail	Refrigeration	New	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	59.61	10	\$351.60	60%	91%	\$1.06	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigeration	Existing	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	14.90	10	\$351.60	90%	100%	\$4.25	0.0	0
Retail	Refrigeration	New	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	14.90	10	\$351.60	90%	100%	\$4.25	0.0	0
Retail	Refrigeration	Existing	Door Gasket - Cooler	Door Gasket - Cooler	Existing Gasket	Per linear foot of gasket on walk-in or reach-in cooler	95.89	4	\$25.57	95%	90%	\$0.10	0.9	0
Retail	Refrigeration	Existing	Door Gasket - Freezer	Door Gasket - Freezer	Existing Gasket	Per linear foot of gasket on walk-in or reach-in freezer	409.14	4	\$25.57	95%	90%	\$0.02	3.9	1,146
Retail	Refrigeration	Existing	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	312.19	15	\$200.88	95%	93%	\$0.09	1.1	901
Retail	Refrigeration	New	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	312.19	15	\$200.88	95%	93%	\$0.09	1.1	22
Retail	Refrigeration	Existing	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	73.80	15	\$98.78	10%	95%	\$0.19	0.6	0
Retail	Refrigeration	New	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	73.80	15	\$98.78	5%	95%	\$0.19	0.6	0
Retail	Refrigeration	Existing	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	202.33	15	\$19.18	90%	100%	\$0.01	7.8	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigeration	New	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	202.33	15	\$19.18	90%	100%	\$0.01	7.8	0
Retail	Refrigeration	Existing	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	319.95	15	\$147.99	65%	40%	\$0.07	1.6	204
Retail	Refrigeration	New	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	319.95	15	\$147.99	95%	40%	\$0.07	1.6	8
Retail	Refrigeration	Existing	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	74.76	15	\$53.59	50%	85%	\$0.10	1.0	104
Retail	Refrigeration	New	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	74.76	15	\$53.59	95%	92%	\$0.10	1.0	5
Retail	Refrigeration	Existing	Insulation for bare suction lines	Insulation for bare suction lines	No Insulation	Per linear feet of walk-in cooler/freezer suction line	127.44	11	\$68.12	95%	50%	\$0.09	1.1	76
Retail	Refrigeration	Existing	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	348.35	8	\$265.45	95%	80%	\$0.16	0.6	0
Retail	Refrigeration	New	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	348.35	8	\$265.45	95%	80%	\$0.16	0.6	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigeration	Existing	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	74.76	15	\$53.59	50%	95%	\$0.10	1.0	0
Retail	Refrigeration	New	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	74.76	15	\$53.59	95%	95%	\$0.10	1.0	0
Retail	Refrigeration	Existing	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	2188.25	15	\$1,174.67	95%	86%	\$0.08	1.4	5,858
Retail	Refrigeration	New	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	2188.25	15	\$1,174.67	95%	86%	\$0.08	1.4	144
Retail	Refrigeration	Existing	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	119.76	15	\$249.48	95%	49%	\$0.29	0.4	0
Retail	Refrigeration	New	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	119.76	15	\$249.48	0%	49%	\$0.29	0.4	0
Retail	Refrigeration	Existing	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	472.94	15	\$249.48	95%	49%	\$0.07	1.4	721
Retail	Refrigeration	New	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	472.94	15	\$249.48	0%	49%	\$0.07	1.4	0
Retail	Refrigeration	Existing	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	353.17	15	\$249.48	95%	49%	\$0.10	1.0	539
Retail	Refrigeration	New	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	353.17	15	\$249.48	0%	49%	\$0.10	1.0	0
Retail	Refrigeration	Existing	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	472.32	3	\$807.16	10%	85%	\$0.80	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigeration	New	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	472.32	3	\$807.16	5%	90%	\$0.80	0.1	0
Retail	Refrigeration	Existing	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	86.32	4	\$25.51	95%	78%	\$0.11	0.8	0
Retail	Refrigeration	New	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	148.81	4	\$25.51	95%	78%	\$0.06	1.4	9
Retail	Refrigeration	Existing	Vertical night covers	Vertical night covers	No covers present	Per ft of vertical display case width	3.34	5	\$2.86	95%	100%	\$0.26	0.3	0
Retail	Refrigeration	New	Vertical night covers	Vertical night covers	No covers present	Per ft of vertical display case width	3.34	5	\$2.86	95%	100%	\$0.26	0.3	0
Retail	Refrigeration	Existing	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	132.01	15	\$79.91	75%	49%	\$0.09	1.2	159
Retail	Refrigeration	New	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	132.01	15	\$79.91	95%	49%	\$0.09	1.2	5
Retail	Refrigeration	Existing	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	353.20	15	\$79.91	75%	49%	\$0.03	3.3	425
Retail	Refrigeration	New	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	353.20	15	\$79.91	95%	49%	\$0.03	3.3	13
Retail	Refrigeration	Existing	eCube	eCube	No eCube	Per Walk-in	390.60	9	\$127.54	95%	95%	\$0.06	1.5	1,155
Retail	Refrigeration	New	eCube	eCube	No eCube	Per Walk-in	390.60	9	\$127.54	95%	95%	\$0.06	1.5	28
Retail	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0
Retail	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	109
Retail	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.01	90%	100%	\$0.10	1.0	6
Retail	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.00	90%	100%	\$0.09	1.0	0
Retail	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.01	12	\$0.00	90%	100%	\$0.09	1.0	0
Retail	Room Cooling	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	9959.94	15	\$4,000.81	25%	62%	\$0.06	2.1	252
Retail	Room Cooling	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6032.83	15	\$2,000.41	25%	95%	\$0.05	2.6	255
Retail	Room Cooling	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	6021.36	15	\$2,000.41	75%	95%	\$0.05	2.6	19
Retail	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.08	12	\$0.02	90%	100%	\$0.03	3.7	11
Retail	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.08	12	\$0.02	90%	100%	\$0.03	3.7	0
Retail	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.20	4	\$0.94	95%	86%	\$1.68	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.20	4	\$0.94	95%	86%	\$1.69	0.1	0
Retail	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.08	4	\$0.11	90%	100%	\$0.49	0.2	0
Retail	Servers	New	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.08	4	\$0.11	90%	100%	\$0.49	0.2	0
Retail	Space Heat	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	4397.12	10	\$69.26	100%	72%	\$0.00	32.6	571
Retail	Space Heat	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	1025.99	15	\$1,685.00	95%	95%	\$0.23	0.4	0
Retail	Space Heat	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	674.23	15	\$1,685.00	95%	95%	\$0.35	0.3	0
Retail	Space Heat	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	16132.13	15	\$4,000.81	25%	62%	\$0.04	2.9	289
Retail	Space Heat	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	9771.38	15	\$2,000.41	25%	95%	\$0.03	3.5	292
Retail	Space Heat	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	9771.38	15	\$2,000.41	75%	95%	\$0.03	3.5	21
Retail	Space Heat	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2579.64	15	\$1,573.98	25%	99%	\$0.09	1.2	81
Retail	Space Heat	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2579.64	15	\$839.46	25%	99%	\$0.05	2.2	2



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Space Heat	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	19312.15	15	#####	90%	100%	\$0.45	0.2	0
Retail	Space Heat	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	4397.12	7	\$6,295.92	95%	85%	\$0.33	0.3	0
Retail	Space Heat	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	727.84	20	#####	75%	99%	\$13.09	0.0	0
Retail	Space Heat	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	727.84	20	#####	75%	99%	\$13.09	0.0	0
Retail	Space Heat	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	4690.26	7	\$1,706.19	95%	75%	\$0.08	1.1	417
Retail	Space Heat	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	13665.75	15	\$1,762.80	10%	66%	\$0.02	5.5	117
Retail	Space Heat	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	11167.29	15	\$1,084.80	10%	95%	\$0.01	7.3	143
Retail	Space Heat	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	11167.29	15	\$1,084.80	50%	95%	\$0.01	7.3	20
Retail	Vending Machines	Existing	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	223.10	5	\$29.51	100%	50%	\$0.04	2.2	366
Retail	Vending Machines	New	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	223.10	5	\$29.51	100%	50%	\$0.04	2.2	9
Retail	Vending Machines	Existing	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	56.16	5	\$26.23	100%	50%	\$0.14	0.6	0
Retail	Vending Machines	New	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	56.16	5	\$26.23	100%	50%	\$0.14	0.6	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Vending Machines	Existing	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.02	90%	100%	\$0.27	0.4	0
Retail	Vending Machines	New	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.02	90%	100%	\$0.27	0.4	0
Retail	Ventilation and Circulation	Existing	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	1845.65	5	\$268.63	1%	85%	\$0.04	2.1	51
Retail	Ventilation and Circulation	New	CO sensors for parking garage exhaust fans	CO sensors for parking garage exhaust fans	Standard Ventilation	Per Fan Motor HP	1845.65	5	\$268.63	1%	85%	\$0.04	2.1	1
Retail	Ventilation and Circulation	Existing	Downsizing motor during retrofit	Downsizing motor during retrofit	Larger hp standard motor	Per Motor	32.32	20	\$6,627.29	10%	95%	\$25.33	0.0	0
Retail	Ventilation and Circulation	Existing	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	733.90	15	\$891.47	15%	95%	\$0.17	0.6	0
Retail	Ventilation and Circulation	New	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	733.90	15	\$891.47	15%	95%	\$0.17	0.6	0
Retail	Ventilation and Circulation	Existing	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	217.90	18	\$895.08	75%	95%	\$0.53	0.2	0
Retail	Ventilation and Circulation	New	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	217.90	18	\$895.08	75%	95%	\$0.53	0.2	0
Retail	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	66.69	15	\$2.00	95%	76%	\$0.00	24.8	157



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	66.69	15	\$2.00	95%	76%	\$0.00	24.8	4
Retail	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	34.05	15	\$2.00	95%	76%	\$0.01	12.7	78
Retail	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	34.05	15	\$2.00	95%	76%	\$0.01	12.7	2
Retail	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	52.27	15	\$2.00	95%	76%	\$0.01	19.5	122
Retail	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	52.27	15	\$2.00	95%	76%	\$0.01	19.5	3
Retail	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	33.91	15	\$2.00	95%	76%	\$0.01	12.6	77
Retail	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	33.91	15	\$2.00	95%	76%	\$0.01	12.6	2
Retail	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	38.46	15	\$2.00	95%	76%	\$0.01	14.3	89
Retail	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	38.46	15	\$2.00	95%	76%	\$0.01	14.3	2

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					1200-3600 RPM									
Retail	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	281.19	13	\$53.07	75%	98%	\$0.03	3.5	649
Retail	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	78.16	13	\$17.53	75%	98%	\$0.03	3.0	171
Retail	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	155.40	25	\$833.35	5%	100%	\$0.61	0.2	0
Retail	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	67.84	25	\$833.35	25%	100%	\$1.40	0.1	0
Retail	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.09	11	\$9.26	100%	34%	\$0.19	0.5	0
Retail	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.09	11	\$9.26	100%	34%	\$0.19	0.5	0
Retail	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	15.95	11	\$22.50	100%	95%	\$0.24	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	15.95	11	\$22.50	100%	95%	\$0.24	0.4	0
Retail	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.22	11	\$13.23	100%	95%	\$0.27	0.4	0
Retail	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.22	11	\$13.23	100%	95%	\$0.27	0.4	0
Retail	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	8.06	10	\$6.71	100%	25%	\$0.15	0.6	0
Retail	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	8.06	10	\$6.71	100%	55%	\$0.15	0.6	0
Retail	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	390.84	14	\$950.00	50%	95%	\$0.36	0.3	0
Retail	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	170.62	14	\$950.00	50%	95%	\$0.82	0.1	0
Retail	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	23.37	8	\$117.50	50%	75%	\$1.06	0.1	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	95%	\$0.04	2.4	2
Retail	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	3.89	15	\$224.27	75%	90%	\$8.16	0.0	0
Retail	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	380.28	7	\$63.10	95%	81%	\$0.04	2.4	8
Retail	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	166.01	7	\$63.10	75%	81%	\$0.09	1.1	0
Retail	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	278.13	7	\$50.00	95%	73%	\$0.04	2.2	0
Retail	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	121.42	7	\$50.00	75%	73%	\$0.10	1.0	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	81.26	12	\$0.00	95%	75%	\$0.00	999.0	2
Retail	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	81.26	12	\$0.00	95%	75%	\$0.00	999.0	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	57.36	12	\$0.00	95%	50%	\$0.00	999.0	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	57.36	12	\$0.00	95%	50%	\$0.00	999.0	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	33.46	12	\$0.00	95%	35%	\$0.00	999.0	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	33.46	12	\$0.00	95%	35%	\$0.00	999.0	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	38.24	12	\$4.05	95%	25%	\$0.02	5.9	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	19.21	9	\$1.01	75%	85%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	19.21	9	\$1.01	75%	85%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	14.41	9	\$0.76	75%	75%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	14.41	9	\$0.76	75%	75%	\$0.01	9.3	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	9.61	9	\$0.50	75%	50%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	9.61	9	\$0.50	75%	50%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	9.61	9	\$0.50	75%	35%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	9.61	9	\$0.50	75%	35%	\$0.01	9.3	0
Retail	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	15	\$1.18	100%	100%	\$32.92	0.0	0
Retail	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	15	\$1.18	100%	100%	\$32.92	0.0	0
Retail	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	52.58	12	\$490.80	75%	85%	\$1.50	0.1	0
Retail	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	52.58	12	\$490.80	75%	85%	\$1.50	0.1	0
Retail	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.01	10	\$0.02	90%	100%	\$0.51	0.2	0
Retail	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.01	10	\$0.02	90%	100%	\$0.51	0.2	0
Retail	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	108.78	2	\$17.00	75%	94%	\$0.11	0.8	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	141.24	25	\$833.35	5%	100%	\$0.67	0.2	0
Retail	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	140.68	25	\$833.35	25%	100%	\$0.67	0.2	0
Retail	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.09	11	\$9.26	100%	34%	\$0.19	0.5	0
Retail	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.09	11	\$9.26	100%	34%	\$0.19	0.5	0
Retail	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	15.95	11	\$22.50	100%	95%	\$0.24	0.4	0
Retail	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	15.95	11	\$22.50	100%	95%	\$0.24	0.4	0
Retail	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.22	11	\$13.23	100%	95%	\$0.27	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	8.22	11	\$13.23	100%	95%	\$0.27	0.4	0
Retail	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	8.06	10	\$6.71	100%	25%	\$0.15	0.6	0
Retail	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	8.06	10	\$6.71	100%	55%	\$0.15	0.6	0
Retail	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	355.22	14	\$950.00	50%	95%	\$0.39	0.3	0
Retail	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	353.81	14	\$950.00	50%	95%	\$0.39	0.3	0
Retail	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	21.24	8	\$117.50	50%	75%	\$1.16	0.1	0
Retail	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	95%	\$0.04	2.4	99
Retail	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	3.53	15	\$224.27	75%	90%	\$8.98	0.0	0
Retail	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	342.06	7	\$63.10	95%	81%	\$0.04	2.2	334
Retail	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	340.70	7	\$63.10	75%	81%	\$0.04	2.2	7
Retail	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	248.30	7	\$50.00	95%	73%	\$0.05	2.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	247.31	7	\$50.00	75%	73%	\$0.05	2.0	0
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	172.43	12	\$0.00	95%	75%	\$0.00	999.0	229
Retail	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	172.43	12	\$0.00	95%	75%	\$0.00	999.0	6
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	121.72	12	\$0.00	95%	50%	\$0.00	999.0	0
Retail	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	121.72	12	\$0.00	95%	50%	\$0.00	999.0	0
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	71.00	12	\$0.00	95%	35%	\$0.00	999.0	0
Retail	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	71.00	12	\$0.00	95%	35%	\$0.00	999.0	0
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	81.14	12	\$4.05	95%	25%	\$0.01	12.5	36
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	40.76	9	\$1.01	75%	85%	\$0.00	19.8	48
Retail	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	40.76	9	\$1.01	75%	85%	\$0.00	19.8	1
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	30.57	9	\$0.76	75%	75%	\$0.00	19.8	0
Retail	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	30.57	9	\$0.76	75%	75%	\$0.00	19.8	0
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	20.38	9	\$0.50	75%	50%	\$0.00	19.8	0
Retail	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	20.38	9	\$0.50	75%	50%	\$0.00	19.8	0
Retail	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	20.38	9	\$0.50	75%	35%	\$0.00	19.8	10
Retail	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	20.38	9	\$0.50	75%	35%	\$0.00	19.8	0
Retail	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.08	15	\$0.91	100%	100%	\$5.59	0.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Retail	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.08	15	\$0.91	100%	100%	\$5.59	0.0	0
Retail	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	111.57	12	\$490.80	75%	85%	\$0.71	0.1	0
Retail	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	111.57	12	\$490.80	75%	85%	\$0.71	0.1	0
Retail	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.06	10	\$0.15	90%	100%	\$0.42	0.2	0
Retail	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.06	10	\$0.15	90%	100%	\$0.42	0.2	0
Retail	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	98.87	2	\$17.00	75%	94%	\$0.12	0.7	0
Warehouse	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.20	4	\$2.49	95%	86%	\$4.63	0.0	0
Warehouse	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.20	4	\$2.49	95%	86%	\$4.46	0.0	0
Warehouse	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.05	4	\$0.00	90%	100%	\$0.00	2,996.0	207
Warehouse	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	Per Building	0.05	4	\$0.00	90%	100%	\$0.00	2,996.0	6
Warehouse	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	980.05	5	\$217.79	50%	80%	\$0.07	1.3	434

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	980.05	5	\$217.79	50%	80%	\$0.07	1.3	10
Warehouse	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	3632.09	10	\$182.23	100%	76%	\$0.01	12.3	202
Warehouse	Cooling Chillers	New	Active chilled beam cooling	Active chilled beam cooling	Standard Building Design and Cooling System	Per Building	3052.94	15	#####	60%	100%	\$4.12	0.0	0
Warehouse	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	44.73	20	\$7,114.95	95%	95%	\$19.64	0.0	0
Warehouse	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	44.58	20	\$7,114.95	95%	95%	\$19.71	0.0	0
Warehouse	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	15.26	15	\$1,685.00	95%	95%	\$15.61	0.0	0
Warehouse	Cooling Chillers	Existing	Automated control system	Automated control system	Baseline DX	Per Building	765.85	10	\$9,859.56	95%	91%	\$2.32	0.1	0
Warehouse	Cooling Chillers	New	Automated control system	Automated control system	Baseline DX	Per Building	763.23	10	\$9,859.56	95%	91%	\$2.32	0.1	0
Warehouse	Cooling Chillers	Existing	Ceiling Insulation	R-24.4	Average Existing Insulation	Per SqFt of Ceiling Insulation	9671.31	15	#####	25%	62%	\$0.16	0.8	0
Warehouse	Cooling Chillers	Existing	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	5481.88	15	\$6,071.42	25%	95%	\$0.16	0.8	0
Warehouse	Cooling Chillers	New	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	5463.15	15	\$6,071.42	75%	95%	\$0.16	0.8	0
Warehouse	Cooling Chillers	Existing	Chilled Water Reset, Optimizer System for Chiller(s)	Chilled Water Reset, Optimizer System for Chiller(s)	0	Per Building	306.34	10	\$11,287.59	95%	81%	\$6.63	0.0	0
Warehouse	Cooling Chillers	Existing	Chiller Tuneup/Diagnostics	Chiller Tuneup/Diagnostics	Existing Conditions	Per Building	1225.36	10	\$3,334.61	25%	24%	\$0.49	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.23	20	\$0.59	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	New	Chillers < 150 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.58 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.23	20	\$0.59	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	Existing	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.08	20	\$0.20	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	New	Chillers < 150 tons (screw) - High Efficiency	High Efficiency - 0.71 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.08	20	\$0.20	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	Existing	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.17	20	\$0.44	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	New	Chillers < 150 tons (screw) - Premium Efficiency	Premium Efficiency - 0.63 kW/ton (full load) - Chillers < 150 tons (screw)	Standard Efficiency - 0.775 kW/ton (full load) - Chillers < 150 tons (screw)	Per Building	0.17	20	\$0.44	90%	100%	\$0.31	0.4	0
Warehouse	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3063.41	15	#####	95%	75%	\$1.15	0.1	0
Warehouse	Cooling Chillers	Existing	Cooling Tower Optimization	Cooling Tower Optimization	Existing Conditions	Per Building	47.71	8	\$611.35	10%	90%	\$2.69	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	2289.70	7	#####	75%	85%	\$1.68	0.1	0
Warehouse	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	157.19	20	#####	75%	99%	\$135.30	0.0	0
Warehouse	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	156.66	20	#####	75%	99%	\$135.77	0.0	0
Warehouse	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2586.88	30	\$76.88	20%	84%	\$0.00	44.7	27
Warehouse	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	2578.04	30	\$76.88	80%	84%	\$0.00	44.6	3
Warehouse	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	2450.72	7	\$4,489.57	75%	75%	\$0.42	0.3	0
Warehouse	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2757.06	18	#####	1%	98%	\$2.68	0.1	0
Warehouse	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	2747.64	18	#####	1%	98%	\$2.69	0.1	0
Warehouse	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	651.20	13	\$372.36	75%	98%	\$0.09	1.4	27
Warehouse	Cooling Chillers	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	7724.57	15	\$3,322.16	10%	66%	\$0.06	2.0	25
Warehouse	Cooling Chillers	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	5105.68	15	\$1,661.08	10%	95%	\$0.05	2.7	24
Warehouse	Cooling Chillers	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	5088.23	15	\$1,661.08	50%	95%	\$0.05	2.7	3



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	765.85	5	\$578.77	50%	95%	\$0.23	0.5	0
Warehouse	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	763.23	5	\$578.77	50%	95%	\$0.23	0.5	0
Warehouse	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	4930.26	10	\$182.23	100%	76%	\$0.01	16.7	378
Warehouse	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	394.42	20	\$7,114.95	95%	95%	\$2.23	0.1	0
Warehouse	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	382.23	20	\$7,114.95	95%	95%	\$2.30	0.1	0
Warehouse	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	20.15	15	\$1,685.00	95%	95%	\$11.82	0.0	0
Warehouse	Cooling DX	Existing	Automated control system	Automated control system	Baseline DX	Per Building	1039.58	10	\$9,859.56	95%	91%	\$1.71	0.1	0
Warehouse	Cooling DX	New	Automated control system	Automated control system	Baseline DX	Per Building	1007.46	10	\$9,859.56	95%	91%	\$1.76	0.1	0
Warehouse	Cooling DX	Existing	Ceiling Insulation	R-24.4	Average Existing Insulation	Per SqFt of Ceiling Insulation	13128.02	15	#####	25%	62%	\$0.12	1.1	119
Warehouse	Cooling DX	Existing	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	7441.21	15	\$6,071.42	25%	95%	\$0.12	1.1	113
Warehouse	Cooling DX	New	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	7211.30	15	\$6,071.42	75%	95%	\$0.12	1.0	8
Warehouse	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	4158.33	15	\$15,761.40	95%	95%	\$0.54	0.2	0
Warehouse	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	2321.45	5	\$3,000.74	95%	45%	\$0.39	0.3	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling DX	Existing	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.06	15	\$0.44	90%	100%	\$1.05	0.1	0
Warehouse	Cooling DX	New	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.06	15	\$0.44	90%	100%	\$1.05	0.1	0
Warehouse	Cooling DX	Existing	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.09	15	\$0.70	90%	100%	\$1.08	0.1	0
Warehouse	Cooling DX	New	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	Per Building	0.09	15	\$0.70	90%	100%	\$1.08	0.1	0
Warehouse	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2162.33	15	\$4,141.67	5%	99%	\$0.27	0.5	0
Warehouse	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	2095.52	15	\$2,208.89	5%	99%	\$0.15	0.8	0
Warehouse	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	473.31	15	\$10,716.92	95%	87%	\$3.20	0.0	0
Warehouse	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	473.31	15	\$8,144.86	45%	80%	\$2.43	0.1	0
Warehouse	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	9818.27	15	#####	90%	100%	\$3.43	0.0	0
Warehouse	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	3022.38	7	#####	95%	85%	\$1.27	0.1	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1386.11	20	#####	75%	99%	\$15.34	0.0	0
Warehouse	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1343.28	20	#####	75%	99%	\$15.83	0.0	0
Warehouse	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	2321.45	10	\$3,081.84	95%	24%	\$0.24	0.5	0
Warehouse	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3511.47	30	\$76.88	20%	84%	\$0.00	60.7	51
Warehouse	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3402.98	30	\$76.88	80%	84%	\$0.00	58.9	5
Warehouse	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	7933.09	10	\$13,717.65	10%	45%	\$0.31	0.4	0
Warehouse	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	3326.66	7	\$4,489.57	95%	75%	\$0.31	0.3	0
Warehouse	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3742.49	18	#####	1%	98%	\$1.97	0.1	0
Warehouse	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3626.86	18	#####	1%	98%	\$2.04	0.1	0
Warehouse	Cooling DX	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	10485.48	15	\$3,322.16	10%	66%	\$0.04	2.7	46
Warehouse	Cooling DX	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	6930.54	15	\$1,661.08	10%	95%	\$0.03	3.6	45

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Cooling DX	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	6716.41	15	\$1,661.08	50%	95%	\$0.03	3.5	6
Warehouse	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1039.58	5	\$578.77	50%	95%	\$0.17	0.6	0
Warehouse	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1007.46	5	\$578.77	50%	95%	\$0.17	0.6	0
Warehouse	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	12
Warehouse	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	Per Building	0.00	4	\$0.00	90%	100%	\$0.00	379.4	0
Warehouse	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	26
Warehouse	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	Per Building	0.01	4	\$0.00	90%	100%	\$0.00	743.5	0
Warehouse	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.00	3.2	1
Warehouse	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	Per Building	0.00	12	\$0.00	90%	100%	\$0.00	3.2	0
Warehouse	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	7156.71	10	\$182.23	100%	76%	\$0.00	20.6	798
Warehouse	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	349.14	20	\$7,114.95	95%	95%	\$2.52	0.0	0
Warehouse	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	337.48	20	\$7,114.95	95%	95%	\$2.60	0.0	0
Warehouse	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.09	15	\$0.14	90%	100%	\$0.22	0.5	0
Warehouse	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.09	15	\$0.14	90%	100%	\$0.22	0.5	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.17	15	\$0.28	90%	100%	\$0.23	0.4	0
Warehouse	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.17	15	\$0.28	90%	100%	\$0.23	0.4	0
Warehouse	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	651.57	15	\$1,685.00	95%	95%	\$0.37	0.3	0
Warehouse	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	431.67	15	\$1,685.00	95%	95%	\$0.55	0.2	0
Warehouse	Heat Pump	Existing	Automated control system	Automated control system	Baseline DX	Per Building	1851.05	10	\$9,859.56	95%	91%	\$0.96	0.1	0
Warehouse	Heat Pump	New	Automated control system	Automated control system	Baseline DX	Per Building	1789.24	10	\$9,859.56	95%	91%	\$0.99	0.1	0
Warehouse	Heat Pump	Existing	Ceiling Insulation	R-24.4	Average Existing Insulation	Per SqFt of Ceiling Insulation	23375.39	15	#####	25%	62%	\$0.07	1.6	321
Warehouse	Heat Pump	Existing	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	13249.62	15	\$6,071.42	25%	95%	\$0.06	1.6	306
Warehouse	Heat Pump	New	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	12807.21	15	\$6,071.42	75%	95%	\$0.07	1.5	23
Warehouse	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	3680.95	15	\$14,931.85	95%	95%	\$0.57	0.2	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/c Ratio	Achievable Potential (MWh)
Warehouse	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	2054.95	5	\$3,000.74	95%	45%	\$0.44	0.2	0
Warehouse	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	3552.32	15	\$4,141.67	5%	99%	\$0.16	0.6	0
Warehouse	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	3433.71	15	\$2,208.89	5%	99%	\$0.09	1.1	0
Warehouse	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	418.97	15	\$10,716.92	95%	87%	\$3.62	0.0	0
Warehouse	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	418.97	15	\$8,144.86	45%	80%	\$2.75	0.0	0
Warehouse	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	5367.73	7	#####	95%	85%	\$0.71	0.1	0
Warehouse	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1764.72	20	#####	75%	99%	\$12.05	0.0	0
Warehouse	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	1705.80	20	#####	75%	99%	\$12.47	0.0	0
Warehouse	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.70	15	\$31.10	90%	100%	\$6.30	0.0	0
Warehouse	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.70	15	\$31.10	90%	100%	\$6.30	0.0	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	2054.95	10	\$2,919.64	95%	24%	\$0.26	0.4	0
Warehouse	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3108.36	30	\$76.88	20%	84%	\$0.00	44.8	65
Warehouse	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	3004.57	30	\$76.88	80%	84%	\$0.00	43.3	6
Warehouse	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	7933.09	10	\$13,717.65	10%	45%	\$0.31	0.3	0
Warehouse	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	5923.36	7	\$4,489.57	95%	75%	\$0.18	0.5	0
Warehouse	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3312.86	18	#####	1%	98%	\$2.23	0.1	0
Warehouse	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	3202.24	18	#####	1%	98%	\$2.31	0.1	0
Warehouse	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	21990.15	15	#####	50%	95%	\$3.85	0.0	0
Warehouse	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	21255.90	15	#####	95%	95%	\$3.98	0.0	0
Warehouse	Heat Pump	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	18670.15	15	\$3,322.16	10%	66%	\$0.03	4.1	124
Warehouse	Heat Pump	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	12340.33	15	\$1,661.08	10%	95%	\$0.02	5.4	122

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Heat Pump	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	11928.28	15	\$1,661.08	50%	95%	\$0.02	5.2	17
Warehouse	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.48	15	\$2.88	90%	100%	\$0.84	0.1	0
Warehouse	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	Per Building	0.48	15	\$2.88	90%	100%	\$0.84	0.1	0
Warehouse	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1851.05	5	\$578.77	50%	95%	\$0.09	0.9	0
Warehouse	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	1789.24	5	\$578.77	50%	95%	\$0.10	0.9	0
Warehouse	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	960.87	10	\$100.00	85%	45%	\$0.02	5.2	137
Warehouse	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	2690.43	8	\$225.00	50%	45%	\$0.02	5.4	240
Warehouse	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	2690.43	8	\$225.00	50%	75%	\$0.02	5.4	10
Warehouse	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	2306.08	8	\$324.61	10%	100%	\$0.03	3.2	82
Warehouse	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	2281.05	10	\$100.00	85%	45%	\$0.01	12.4	0
Warehouse	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	69.48	13	\$6.00	0%	85%	\$0.01	7.8	0
Warehouse	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	2528.35	8	\$7,817.51	65%	100%	\$0.65	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	6158.84	10	\$2,511.16	10%	98%	\$0.07	1.3	644
Warehouse	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.09	13	\$0.15	90%	100%	\$0.25	0.4	0
Warehouse	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.08	13	\$0.50	90%	100%	\$0.97	0.1	0
Warehouse	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.13	13	\$0.30	90%	100%	\$0.36	0.3	0
Warehouse	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.03	13	\$0.13	90%	100%	\$0.76	0.1	0
Warehouse	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	Per Building	0.21	20	\$1.58	90%	100%	\$0.93	0.1	0
Warehouse	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	5474.53	8	\$1,512.04	90%	98%	\$0.06	1.6	1,298
Warehouse	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	5474.53	8	\$324.61	10%	99%	\$0.01	7.6	191
Warehouse	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	372.70	10	\$100.00	85%	45%	\$0.05	2.0	34
Warehouse	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	413.11	8	\$7,817.51	65%	100%	\$3.97	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	1006.29	10	\$2,511.16	10%	98%	\$0.45	0.2	0
Warehouse	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal Halide - Above Standard	Efficient Metal Halide	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.03	15	\$0.03	90%	100%	\$0.14	0.8	0
Warehouse	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.10	15	\$0.05	90%	100%	\$0.08	1.4	711
Warehouse	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.16	20	\$0.06	90%	100%	\$0.05	2.4	62
Warehouse	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	Per Building	0.13	20	-\$0.02	90%	100%	-\$0.02	999.0	0
Warehouse	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	894.48	8	\$1,512.04	90%	98%	\$0.35	0.3	0
Warehouse	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	894.48	8	\$324.61	10%	99%	\$0.08	1.2	22
Warehouse	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	15.21	10	\$3.80	95%	25%	\$0.04	2.2	1



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.19	15	\$0.12	100%	100%	\$0.09	1.1	0
Warehouse	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.28	15	\$0.12	100%	100%	\$0.06	1.7	0
Warehouse	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	Per Building	0.56	15	\$0.25	100%	100%	\$0.06	1.7	323
Warehouse	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	3402.25	8	\$7,817.51	65%	100%	\$0.48	0.2	0
Warehouse	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	11.28	16	\$4.80	95%	50%	\$0.06	1.9	7
Warehouse	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	8287.57	10	\$2,511.16	30%	98%	\$0.05	1.8	57
Warehouse	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	7366.73	8	\$1,512.04	90%	98%	\$0.04	2.2	15
Warehouse	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	29.43	30	\$3.00	75%	95%	\$0.01	11.3	26
Warehouse	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	29.43	30	\$3.00	75%	95%	\$0.01	11.3	0
Warehouse	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	52.88	10	\$100.00	85%	45%	\$0.34	0.3	0
Warehouse	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	58.61	8	\$7,817.51	65%	100%	\$28.00	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	142.78	10	\$2,511.16	10%	98%	\$3.17	0.0	0
Warehouse	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	Per Building	0.01	5	\$0.00	90%	100%	\$0.01	9.6	164
Warehouse	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	Per Building	0.01	2	\$0.00	90%	100%	\$0.01	5.5	0
Warehouse	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	Per Building	0.02	12	\$0.00	90%	100%	\$0.04	2.6	236
Warehouse	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	126.91	8	\$1,512.04	90%	98%	\$2.50	0.0	0
Warehouse	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	126.91	8	\$324.61	10%	99%	\$0.54	0.2	0
Warehouse	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	5
Warehouse	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	5.82	15	\$0.56	75%	75%	\$0.01	7.7	0
Warehouse	Other Plug Load	Existing	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	75%	90%	\$6.49	0.0	0
Warehouse	Other Plug Load	New	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	100%	90%	\$6.49	0.0	0
Warehouse	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	6.71	4	\$0.67	100%	20%	\$0.04	2.4	2
Warehouse	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	6.71	4	\$0.67	100%	20%	\$0.04	2.4	0
Warehouse	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	827.65	10	\$0.00	95%	20%	\$0.00	999.0	232
Warehouse	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	827.65	10	\$0.00	95%	20%	\$0.00	999.0	6



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.40	5	\$1.66	95%	20%	\$1.24	0.1	0
Warehouse	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	0.40	5	\$1.66	95%	20%	\$1.24	0.1	0
Warehouse	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	225.05	5	\$38.11	95%	95%	\$0.05	1.8	81
Warehouse	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	225.05	5	\$38.11	95%	95%	\$0.05	1.8	2
Warehouse	Other Plug Load	Existing	VFD on Process	VFD on Process	Standard Motor	Per Process Motor VFD	3319.25	15	\$11,000.00	55%	98%	\$0.47	0.2	0
Warehouse	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	1
Warehouse	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	Per Building	0.00	6	\$0.00	90%	100%	\$0.00	1,630.0	0
Warehouse	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.02	5	\$0.00	90%	100%	\$0.00	4,559.7	12
Warehouse	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	Per Building	0.02	5	\$0.00	90%	100%	\$0.00	4,559.7	0
Warehouse	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.10	1.0	0
Warehouse	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.10	1.0	0
Warehouse	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.10	1.0	36
Warehouse	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.10	1.0	2

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.09	1.0	0
Warehouse	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	Per Building	0.00	12	\$0.00	90%	100%	\$0.09	1.0	0
Warehouse	Room Cooling	Existing	Ceiling Insulation	R-24.4	Average Existing Insulation	Per SqFt ofCeiling Insulation	11623.18	15	#####	25%	62%	\$0.13	0.9	0
Warehouse	Room Cooling	Existing	Ceiling Insulation	R-38	R-24.4	Per SqFt ofCeiling Insulation	6588.24	15	\$6,071.42	25%	95%	\$0.13	0.9	0
Warehouse	Room Cooling	New	Ceiling Insulation	R-38	R-24.4	Per SqFt ofCeiling Insulation	6575.71	15	\$6,071.42	75%	95%	\$0.13	0.9	0
Warehouse	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.03	12	\$0.02	90%	100%	\$0.12	1.0	0
Warehouse	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	Per Building	0.03	12	\$0.02	90%	100%	\$0.12	1.0	0
Warehouse	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.17	4	\$2.49	95%	86%	\$5.45	0.0	0
Warehouse	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.17	4	\$2.49	95%	86%	\$5.47	0.0	0
Warehouse	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.02	4	\$0.03	90%	100%	\$0.49	0.2	0
Warehouse	Servers	New	Server - High Efficiency	High Efficiency Server	Standard Server	Per Building	0.02	4	\$0.03	90%	100%	\$0.49	0.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Space Heat	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	3248.95	10	\$182.23	100%	76%	\$0.01	9.1	6
Warehouse	Space Heat	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	758.09	15	\$1,685.00	95%	95%	\$0.31	0.3	0
Warehouse	Space Heat	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	498.17	15	\$1,685.00	95%	95%	\$0.48	0.2	0
Warehouse	Space Heat	Existing	Automated control system	Automated control system	Baseline DX	Per Building	1082.98	10	\$9,859.56	95%	91%	\$1.64	0.1	0
Warehouse	Space Heat	New	Automated control system	Automated control system	Baseline DX	Per Building	1082.98	10	\$9,859.56	95%	91%	\$1.64	0.1	0
Warehouse	Space Heat	Existing	Ceiling Insulation	R-24.4	Average Existing Insulation	Per SqFt of Ceiling Insulation	13676.13	15	#####	25%	62%	\$0.11	0.9	0
Warehouse	Space Heat	Existing	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	7751.89	15	\$6,071.42	25%	95%	\$0.11	0.9	0
Warehouse	Space Heat	New	Ceiling Insulation	R-38	R-24.4	Per SqFt of Ceiling Insulation	7751.89	15	\$6,071.42	75%	95%	\$0.11	0.9	0
Warehouse	Space Heat	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1906.05	15	\$4,141.67	5%	99%	\$0.31	0.3	0
Warehouse	Space Heat	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	1906.05	15	\$2,208.89	5%	99%	\$0.16	0.6	0
Warehouse	Space Heat	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	14269.40	15	#####	90%	100%	\$2.36	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Space Heat	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	3248.95	7	#####	95%	85%	\$1.18	0.1	0
Warehouse	Space Heat	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	625.65	20	#####	75%	99%	\$33.99	0.0	0
Warehouse	Space Heat	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	625.65	20	#####	75%	99%	\$33.99	0.0	0
Warehouse	Space Heat	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	3465.55	7	\$4,489.57	95%	75%	\$0.30	0.3	0
Warehouse	Space Heat	Existing	Wall Insulation	R-14	Average Existing Insulation	Per SqFt of Wall Insulation	10923.26	15	\$3,322.16	10%	66%	\$0.04	2.3	1
Warehouse	Space Heat	Existing	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	7219.90	15	\$1,661.08	10%	95%	\$0.03	3.1	1
Warehouse	Space Heat	New	Wall Insulation	R-21	R-14	Per SqFt of Wall Insulation	7219.90	15	\$1,661.08	50%	95%	\$0.03	3.2	0
Warehouse	Vending Machines	Existing	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	311.61	5	\$41.22	100%	50%	\$0.04	2.2	230
Warehouse	Vending Machines	New	Beverage machine control	Beverage machine control	Vending machine with no sensor	Per Beverage Vending Machine	311.61	5	\$41.22	100%	50%	\$0.04	2.2	6
Warehouse	Vending Machines	Existing	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	78.44	5	\$36.64	100%	50%	\$0.14	0.6	0
Warehouse	Vending Machines	New	Non-cooled snack control	Non-cooled snack control	Vending machine with no sensor	Per Snack Vending Machine	78.44	5	\$36.64	100%	50%	\$0.14	0.6	0
Warehouse	Vending Machines	Existing	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.01	90%	100%	\$0.27	0.4	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Vending Machines	New	Vending Machines - ENERGY STAR - High Efficiency	ENERGY STAR Vending Machines - High Efficiency	Standard Vending Machines	Per Building	0.01	14	\$0.01	90%	100%	\$0.27	0.4	0
Warehouse	Ventilation and Circulation	Existing	Downsizing motor during retrofit	Downsizing motor during retrofit	Larger hp standard motor	Per Motor	64.78	20	#####	10%	95%	\$33.25	0.0	0
Warehouse	Ventilation and Circulation	Existing	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	1471.14	15	\$3,430.96	15%	95%	\$0.33	0.3	0
Warehouse	Ventilation and Circulation	New	ECM Motors for split systems	ECM Motors for split systems	Standard Motor	Per Building	1471.14	15	\$3,430.96	15%	95%	\$0.33	0.3	0
Warehouse	Ventilation and Circulation	Existing	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	1423.66	18	\$3,444.85	75%	95%	\$0.31	0.4	0
Warehouse	Ventilation and Circulation	New	Electronically Commutated Motors (ECM) on an Air Handler Unit	Electronically Commutated Motors (ECM) on an Air Handler Unit	Assumes 67% eff. .35 HP PSC motor operating 2000 hours per year is replaced with 85% eff. ECPM motor	Per Air Handler Recirculating Fan Motor (1 HP or less)	1423.66	18	\$3,444.85	75%	95%	\$0.31	0.4	0
Warehouse	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	133.69	15	\$5.27	95%	76%	\$0.01	19.1	142
Warehouse	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 1-15 HP, 1200-3600 RPM	Standard (NEMA) Motor 1-15 HP, 1200-3600 RPM	Per Building	133.69	15	\$5.27	95%	76%	\$0.01	19.1	3
Warehouse	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	68.25	15	\$5.27	95%	76%	\$0.01	9.8	70

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MW/h)
Warehouse	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 125-200 HP, 1200-3600 RPM	Standard (NEMA) Motor 125-200 HP, 1200-3600 RPM	Per Building	68.25	15	\$5.27	95%	76%	\$0.01	9.8	2
Warehouse	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	104.78	15	\$5.27	95%	76%	\$0.01	15.0	110
Warehouse	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 20-40 HP, 1200-3600 RPM	Standard (NEMA) Motor 20-40 HP, 1200-3600 RPM	Per Building	104.78	15	\$5.27	95%	76%	\$0.01	15.0	3
Warehouse	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	67.97	15	\$5.27	95%	76%	\$0.01	9.7	70
Warehouse	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 250-500 HP, 1200-3600 RPM	Standard (NEMA) Motor 250-500 HP, 1200-3600 RPM	Per Building	67.97	15	\$5.27	95%	76%	\$0.01	9.7	2
Warehouse	Ventilation and Circulation	Existing	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	77.10	15	\$5.27	95%	76%	\$0.01	11.0	80
Warehouse	Ventilation and Circulation	New	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Enhanced (Ultra-PE) Motor 50-100 HP, 1200-3600 RPM	Standard (NEMA) Motor 50-100 HP, 1200-3600 RPM	Per Building	77.10	15	\$5.27	95%	76%	\$0.01	11.0	2
Warehouse	Ventilation and Circulation	Existing	VFD on HVAC Fan	VFD on HVAC Fan	Standard Motor	Per HVAC Fan Motor VFD (assuming 50 HP average)	1371.12	13	\$279.27	75%	98%	\$0.03	3.3	1,424
Warehouse	Ventilation and Circulation	Existing	VFD on HVAC Pump	VFD on HVAC Pump	Standard Motor	Per HVAC Pump Motor VFD (assuming 50 HP average)	224.01	13	\$92.26	75%	98%	\$0.06	1.6	204



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat GT 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	1121.58	25	\$833.35	5%	100%	\$0.08	1.4	1
Warehouse	Water Heat GT 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	489.63	25	\$833.35	25%	100%	\$0.19	0.6	0
Warehouse	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.30	11	\$24.38	100%	34%	\$0.19	0.5	0
Warehouse	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.30	11	\$24.38	100%	34%	\$0.19	0.5	0
Warehouse	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	41.96	11	\$59.20	100%	95%	\$0.24	0.4	0
Warehouse	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	41.96	11	\$59.20	100%	95%	\$0.24	0.4	0
Warehouse	Water Heat GT 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.62	11	\$34.82	100%	95%	\$0.27	0.4	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat GT 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.62	11	\$34.82	100%	95%	\$0.27	0.4	0
Warehouse	Water Heat GT 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.50	10	\$7.92	100%	25%	\$0.15	0.7	0
Warehouse	Water Heat GT 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.50	10	\$7.92	100%	55%	\$0.15	0.7	0
Warehouse	Water Heat GT 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	2820.78	14	\$950.00	50%	95%	\$0.05	2.1	21
Warehouse	Water Heat GT 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	1231.41	14	\$950.00	50%	95%	\$0.11	0.9	0
Warehouse	Water Heat GT 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	168.70	8	\$117.50	50%	75%	\$0.15	0.7	0
Warehouse	Water Heat GT 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	100%	\$0.04	2.4	1
Warehouse	Water Heat GT 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	28.04	15	\$224.27	75%	90%	\$1.13	0.1	0
Warehouse	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	2744.58	7	\$63.10	95%	92%	\$0.01	17.6	74
Warehouse	Water Heat GT 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	1198.14	7	\$63.10	75%	92%	\$0.01	7.7	1
Warehouse	Water Heat GT 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	2007.31	7	\$50.00	95%	83%	\$0.01	16.2	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat GT 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	876.29	7	\$50.00	75%	83%	\$0.01	7.1	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	335.17	12	\$0.00	95%	75%	\$0.00	999.0	8
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	335.17	12	\$0.00	95%	75%	\$0.00	999.0	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	236.59	12	\$0.00	95%	50%	\$0.00	999.0	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	236.59	12	\$0.00	95%	50%	\$0.00	999.0	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	138.01	12	\$0.00	95%	35%	\$0.00	999.0	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	138.01	12	\$0.00	95%	35%	\$0.00	999.0	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	157.73	12	\$2.13	95%	25%	\$0.00	46.6	1
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.10	9	\$2.65	75%	85%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.10	9	\$2.65	75%	85%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	5.32	9	\$1.99	75%	75%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	5.32	9	\$1.99	75%	75%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	3.55	9	\$1.33	75%	50%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	3.55	9	\$1.33	75%	50%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	3.55	9	\$1.33	75%	35%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	3.55	9	\$1.33	75%	35%	\$0.07	1.3	0
Warehouse	Water Heat GT 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.05	15	\$0.45	100%	100%	\$4.56	0.0	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat GT 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.05	15	\$0.45	100%	100%	\$4.56	0.0	0
Warehouse	Water Heat GT 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	216.87	12	\$258.29	75%	85%	\$0.19	0.5	0
Warehouse	Water Heat GT 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	216.87	12	\$258.29	75%	85%	\$0.19	0.5	0
Warehouse	Water Heat GT 55 Gal	Existing	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	10	\$0.01	90%	100%	\$0.07	1.4	10
Warehouse	Water Heat GT 55 Gal	New	Water Heater GT 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater GT 55 Gal - EF 2.2	Federal Standard 2015 Heat Pump Water Heater GT 55 Gal - EF 1.97	Per Building	0.02	10	\$0.01	90%	100%	\$0.07	1.4	0
Warehouse	Water Heat GT 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	785.11	2	\$17.00	75%	94%	\$0.01	5.9	10
Warehouse	Water Heat LE 55 Gal	Existing	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	1019.37	25	\$833.35	5%	100%	\$0.09	1.3	8
Warehouse	Water Heat LE 55 Gal	New	Drainwater Heat Recovery Water Heater	Drainwater Heat Recovery Water Heater	No Heat Exchanger	Per Water Heater	1015.33	25	\$833.35	25%	100%	\$0.09	1.3	1
Warehouse	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.30	11	\$24.38	100%	34%	\$0.19	0.5	0
Warehouse	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.30	11	\$24.38	100%	34%	\$0.19	0.5	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	41.96	11	\$59.20	100%	95%	\$0.24	0.4	0
Warehouse	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2016 Clothes Washer - MEF 1.72 and WF 8.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	41.96	11	\$59.20	100%	95%	\$0.24	0.4	0
Warehouse	Water Heat LE 55 Gal	Existing	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.62	11	\$34.82	100%	95%	\$0.27	0.4	0
Warehouse	Water Heat LE 55 Gal	New	ENERGY STAR Clothes Washers (Electric Water Heating)	ENERGY STAR Most Efficient Clothes Washer - MEF 2.4 and WF 4.5 (Electric DHW & Dryer)	Federal Standard 2018 Clothes Washer - MEF 2.0 and WF 6.0 (Electric DHW & Dryer)	Per Residential Clothes Washer	21.62	11	\$34.82	100%	95%	\$0.27	0.4	0
Warehouse	Water Heat LE 55 Gal	Existing	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.50	10	\$7.92	100%	25%	\$0.15	0.7	0
Warehouse	Water Heat LE 55 Gal	New	ENERGY STAR Dishwashers (Electric Water Heating)	ENERGY STAR Dishwasher - 295 kWh/yr and 4.25 gal/cycle	Federal Standard 2014 Dishwasher - 307 kWh/yr and 5.0 gal/cycle	Per Residential Dishwasher	9.50	10	\$7.92	100%	55%	\$0.15	0.7	0
Warehouse	Water Heat LE 55 Gal	Existing	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	2563.71	14	\$950.00	50%	95%	\$0.05	1.9	253

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat LE 55 Gal	New	Heat Recovery Unit	Heat Recovery Unit (De-superheater)	Base Water Heating	Per Water Heater	2553.55	14	\$950.00	50%	95%	\$0.05	1.9	6
Warehouse	Water Heat LE 55 Gal	Existing	Heat Trap	Heat Trap	No Heat Trap on Water Heater	Per Water Heater	153.32	8	\$117.50	50%	75%	\$0.16	0.6	0
Warehouse	Water Heat LE 55 Gal	Existing	Hot Water (DHW) Pipe Insulation	Hot Water (DHW) Pipe Insulation	No insulation present	Per Linear Foot of Hot Water Pipe Insulation	74.40	14	\$21.74	100%	100%	\$0.04	2.4	16
Warehouse	Water Heat LE 55 Gal	Existing	Hot Water Circulation Pump Time-Clock	Hot Water Circulation Pump Time-Clock	No Time Clock	Per 1000 sqft	25.48	15	\$224.27	75%	90%	\$1.24	0.1	0
Warehouse	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	2468.73	7	\$63.10	95%	92%	\$0.01	15.8	885
Warehouse	Water Heat LE 55 Gal	New	Insulating Blanket (R=11)	Insulating Blanket (R=11)	No Insulating Blanket on Water Heater	Per Tank Wrap	2458.95	7	\$63.10	75%	92%	\$0.01	15.8	14
Warehouse	Water Heat LE 55 Gal	Existing	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	1792.03	7	\$50.00	95%	83%	\$0.01	14.5	0
Warehouse	Water Heat LE 55 Gal	New	Insulating Blanket (R=6.7)	Insulating Blanket (R=6.7)	No Insulating Blanket on Water Heater	Per Tank Wrap	1784.93	7	\$50.00	75%	83%	\$0.01	14.4	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	711.20	12	\$0.00	95%	75%	\$0.00	999.0	234
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	0.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	711.20	12	\$0.00	95%	75%	\$0.00	999.0	4
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	502.02	12	\$0.00	95%	50%	\$0.00	999.0	0
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.0 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	502.02	12	\$0.00	95%	50%	\$0.00	999.0	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	292.85	12	\$0.00	95%	35%	\$0.00	999.0	0
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Faucet Aerators	1.5 GPM	2.2 GPM (Federal Code)	Per Faucet Aerator	292.85	12	\$0.00	95%	35%	\$0.00	999.0	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Faucet Aerators	2.2 GPM (Federal Code)	3.0 GPM	Per Faucet Aerator	334.68	12	\$2.13	95%	25%	\$0.00	98.9	37
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	15.06	9	\$2.65	75%	85%	\$0.03	2.8	4



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.5 GPM	2.5 GPM (Federal Code)	Per Showerhead	15.06	9	\$2.65	75%	85%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	11.29	9	\$1.99	75%	75%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Showerheads	1.75 GPM	2.5 GPM (Federal Code)	Per Showerhead	11.29	9	\$1.99	75%	75%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.53	9	\$1.33	75%	50%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.0 GPM	2.5 GPM (Federal Code)	Per Showerhead	7.53	9	\$1.33	75%	50%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	Existing	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	7.53	9	\$1.33	75%	35%	\$0.03	2.8	1
Warehouse	Water Heat LE 55 Gal	New	Low-Flow Showerheads	2.5 GPM (Federal Code)	3.0 GPM	Per Showerhead	7.53	9	\$1.33	75%	35%	\$0.03	2.8	0
Warehouse	Water Heat LE 55 Gal	Existing	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.21	15	\$0.35	100%	100%	\$0.78	0.1	0
Warehouse	Water Heat LE 55 Gal	New	Solar Water Heater	Solar Water Heater	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.21	15	\$0.35	100%	100%	\$0.78	0.1	0
Warehouse	Water Heat LE 55 Gal	Existing	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	460.19	12	\$258.29	75%	85%	\$0.09	1.1	136
Warehouse	Water Heat LE 55 Gal	New	Ultrasonic Faucet Control	Ultrasonic Faucet Control	Manual Faucet Control	Per Faucet Aerator	460.19	12	\$258.29	75%	85%	\$0.09	1.1	3
Warehouse	Water Heat LE 55 Gal	Existing	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.17	10	\$0.06	90%	100%	\$0.06	1.7	779
Warehouse	Water Heat LE 55 Gal	New	Water Heater LE 55 Gal - Heat Pump - ENERGY STAR	ENERGY STAR Heat Pump Water Heater LE 55 Gal - EF 2.2	Federal Standard 2015 Storage Water Heater LE 55 Gal - EF 0.95	Per Building	0.17	10	\$0.06	90%	100%	\$0.06	1.7	17
Warehouse	Water Heat LE 55 Gal	Existing	Water Heater Thermostat Setback	Water Heater Thermostat Setback	Constant setpoint	Per Building	713.56	2	\$17.00	75%	94%	\$0.02	5.4	119



GNI Measure Details

Table 7. GNI Measure Details

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Computers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	1.89	4	\$7.32	95%	86%	\$1.40	0.06	0
Education	Computers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	1.97	4	\$7.32	95%	86%	\$1.35	0.06	0
Education	Computers	Existing	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	0	0.18	4	\$0.00	90%	100%	\$0.00	2,928.64	341
Education	Computers	New	Computer - ENERGY STAR	ENERGY STAR Computer	Standard Computer	0	0.18	4	\$0.00	90%	100%	\$0.00	2,928.64	10
Education	Computers	Existing	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	9509.99	5	\$2,113.33	50%	80%	\$0.07	1.30	716
Education	Computers	New	Network PC Power Management	Network PC Power Management	No Network PC Power Management System	Per PC Workstation Managed by Network PC Power Management	9509.99	5	\$2,113.33	50%	80%	\$0.07	1.30	17
Education	Cooking	Existing	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	64.88	12	\$0.00	75%	95%	\$0.00	99,995.18	12
Education	Cooking	New	Commercial Hot Food Holding Cabinets (Energy Star)	ENERGY STAR Hot Food Holding Cabinet	Standard Hot Food Holding Cabinet	Per Hot Food Holding Cabinet	64.88	12	\$0.00	75%	95%	\$0.00	99,995.18	0
Education	Cooking	Existing	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	397.98	12	\$7.50	5%	95%	\$0.00	30.67	5
Education	Cooking	New	Electric Steam cooker (Energy Star)	ENERGY STAR Steam Cooker	Standard Steam Cooker	Per Steam Cooker	397.98	12	\$7.50	5%	95%	\$0.00	30.67	0
Education	Cooking	Existing	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	238.79	12	\$0.00	90%	90%	\$0.00	368,039.29	48

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Cooking	New	Electric combination oven (Energy Star)	ENERGY STAR Combination Oven	Standard Combination Oven	Per Combination Oven	238.79	12	\$0.00	90%	90%	\$0.00	368,039.29	1
Education	Cooking	Existing	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	72.64	12	\$0.00	20%	55%	\$0.00	111,961.58	0
Education	Cooking	New	Electric convection oven (Energy Star)	ENERGY STAR Convection Oven	Standard Convection Oven	Per Convection Oven	72.64	12	\$0.00	20%	55%	\$0.00	111,961.58	0
Education	Cooking	Existing	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	35.69	12	\$7.88	0%	95%	\$0.04	2.62	0
Education	Cooking	New	High Efficiency Fryers (Energy Star)	ENERGY STAR Fryer	Standard Fryer	Per Fryer	35.69	12	\$7.88	0%	95%	\$0.04	2.62	0
Education	Cooking	Existing	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	35.80	12	\$0.00	95%	95%	\$0.00	110,339.19	8
Education	Cooking	New	High Efficiency Griddle (Energy Star)	ENERGY STAR Griddle	Standard Griddle	Per Griddle	35.80	12	\$0.00	95%	95%	\$0.00	110,339.19	0
Education	Cooking	Existing	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	118.66	12	\$112.28	95%	95%	\$0.15	0.61	0
Education	Cooking	New	High Efficiency Induction Cooking	High Efficiency Induction Cooking	Standard Stovetop	Per Induction Stovetop	118.66	12	\$112.28	95%	95%	\$0.15	0.61	0
Education	Cooling Chillers	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	9748.31	10	\$536.49	100%	67%	\$0.01	11.88	66
Education	Cooling Chillers	New	Active chilled beam cooling	Active chilled beam cooling	Standard Building Design and Cooling System	Per Building	8581.50	15	#####	60%	100%	\$4.32	0.03	0
Education	Cooling Chillers	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	120.05	20	\$18,951.18	95%	95%	\$19.50	0.01	0
Education	Cooling Chillers	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	101.90	20	\$18,951.18	95%	95%	\$22.97	0.01	0
Education	Cooling Chillers	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	42.91	15	\$1,685.00	95%	95%	\$5.55	0.02	0
Education	Cooling Chillers	Existing	Automated control system	Automated control system	Baseline DX	Per Building	2527.60	10	#####	95%	65%	\$1.32	0.09	0
Education	Cooling Chillers	New	Automated control system	Automated control system	Baseline DX	Per Building	2145.37	10	#####	95%	65%	\$1.56	0.08	0
Education	Cooling Chillers	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	12637.99	15	#####	25%	62%	\$0.27	0.49	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Cooling Chillers	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	16850.66	15	\$11,890.94	25%	95%	\$0.10	1.30	38
Education	Cooling Chillers	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	14302.50	15	\$11,890.94	75%	95%	\$0.12	1.10	2
Education	Cooling Chillers	Existing	Chilled Water Reset, Optimizer System for Chiller(s)	Chilled Water Reset, Optimizer System for Chiller(s)	0	Per Building	1011.04	10	#####	95%	81%	\$5.91	0.02	0
Education	Cooling Chillers	Existing	Chiller Tuneup/Diagnostics	Chiller Tuneup/Diagnostics	Existing Conditions	Per Building	4044.16	10	\$14,816.28	25%	24%	\$0.66	0.16	0
Education	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.52 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	0	0.21	20	\$0.81	90%	100%	\$0.48	0.25	0
Education	Cooling Chillers	New	Chillers 150-300 tons (screw) - Advanced Efficiency	Advanced Efficiency - 0.52 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	0	0.21	20	\$0.81	90%	100%	\$0.48	0.25	0
Education	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - High Efficiency	High Efficiency - 0.63 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	0	0.07	20	\$0.25	90%	100%	\$0.48	0.25	0
Education	Cooling Chillers	New	Chillers 150-300 tons (screw) - High Efficiency	High Efficiency - 0.63 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	0	0.07	20	\$0.25	90%	100%	\$0.48	0.25	0
Education	Cooling Chillers	Existing	Chillers 150-300 tons (screw) - Premium Efficiency	Premium Efficiency - 0.58 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-	0	0.13	20	\$0.51	90%	100%	\$0.48	0.25	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					300 tons (screw)									
Education	Cooling Chillers	New	Chillers 150-300 tons (screw) - Premium Efficiency	Premium Efficiency - 0.58 kW/ton (full load) - Chillers 150-300 tons (screw)	Standard Efficiency - 0.68 kW/ton (full load) - Chillers 150-300 tons (screw)	0	0.13	20	\$0.51	90%	100%	\$0.48	0.25	0
Education	Cooling Chillers	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	10110.39	15	\$111,122.14	95%	75%	\$1.55	0.08	0
Education	Cooling Chillers	Existing	Cooling Tower Optimization	Cooling Tower Optimization	Existing Conditions	Per Building	157.47	8	\$2,716.32	10%	90%	\$3.62	0.03	0
Education	Cooling Chillers	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	6436.12	7	#####	75%	85%	\$1.75	0.06	0
Education	Cooling Chillers	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	518.80	20	#####	75%	99%	\$109.20	0.00	0
Education	Cooling Chillers	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	440.35	20	#####	75%	99%	\$128.65	0.00	0
Education	Cooling Chillers	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	8537.67	30	\$765.97	20%	84%	\$0.01	12.10	21
Education	Cooling Chillers	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	7246.60	30	\$765.97	80%	84%	\$0.01	10.27	2
Education	Cooling Chillers	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	14934.31	10	#####	90%	100%	\$0.31	0.34	0
Education	Cooling Chillers	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	8088.32	7	\$13,217.06	75%	75%	\$0.38	0.30	0
Education	Cooling Chillers	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	9099.35	18	#####	1%	98%	\$1.53	0.09	0
Education	Cooling Chillers	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	7723.35	18	#####	1%	98%	\$1.80	0.08	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Cooling Chillers	Existing	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	10027.41	13	\$2,740.51	75%	98%	\$0.04	2.72	80
Education	Cooling Chillers	New	VFD on cooling tower fans	VFD on cooling tower fans	Base single-speed fan	Per Cooling Tower Motor VFD	10027.41	13	\$2,740.51	90%	100%	\$0.04	2.72	2
Education	Cooling Chillers	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	11665.84	15	\$4,225.62	10%	66%	\$0.05	2.53	5
Education	Cooling Chillers	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	19257.89	15	\$2,600.38	10%	95%	\$0.02	6.79	25
Education	Cooling Chillers	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	16345.71	15	\$2,600.38	50%	95%	\$0.02	5.76	3
Education	Cooling Chillers	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2527.60	5	\$5,766.39	50%	95%	\$0.69	0.15	0
Education	Cooling Chillers	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2145.37	5	\$5,766.39	50%	95%	\$0.81	0.12	0
Education	Cooling DX	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	10812.01	10	\$536.49	100%	67%	\$0.01	11.97	346
Education	Cooling DX	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	864.96	20	\$18,951.18	95%	95%	\$2.71	0.05	0
Education	Cooling DX	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	838.24	20	\$18,951.18	95%	95%	\$2.79	0.04	0
Education	Cooling DX	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	54.34	15	\$1,685.00	95%	95%	\$4.38	0.03	0
Education	Cooling DX	Existing	Automated control system	Automated control system	Baseline DX	Per Building	2803.40	10	#####	95%	65%	\$1.19	0.09	0
Education	Cooling DX	New	Automated control system	Automated control system	Baseline DX	Per Building	2716.78	10	#####	95%	65%	\$1.23	0.09	0
Education	Cooling DX	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	14017.00	15	#####	25%	62%	\$0.24	0.49	0
Education	Cooling DX	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	18689.33	15	\$11,890.94	25%	95%	\$0.09	1.31	229
Education	Cooling DX	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	18111.88	15	\$11,890.94	75%	95%	\$0.09	1.27	15
Education	Cooling DX	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	11213.60	15	#####	95%	95%	\$0.37	0.32	0
Education	Cooling DX	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System,	Per Building	5090.91	5	\$5,648.18	95%	45%	\$0.33	0.30	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
					EER=10.3, 10 tons									
Education	Cooling DX	Existing	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	0	0.05	15	\$0.28	90%	100%	\$0.74	0.16	0
Education	Cooling DX	New	DX Package 240 to 760 kBtuh - High Efficiency	High Efficiency - 10.5 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	0	0.05	15	\$0.28	90%	100%	\$0.74	0.16	0
Education	Cooling DX	Existing	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	0	0.08	15	\$0.45	90%	100%	\$0.76	0.16	0
Education	Cooling DX	New	DX Package 240 to 760 kBtuh - Premium Efficiency	Premium Efficiency - 10.8 EER - DX Package 240 to 760 kBtuh	Standard Efficiency - 10.0 EER - DX Package 240 to 760 kBtuh	0	0.08	15	\$0.45	90%	100%	\$0.76	0.16	0
Education	Cooling DX	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	5831.07	15	\$12,192.86	25%	99%	\$0.30	0.40	0
Education	Cooling DX	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	5650.91	15	\$6,502.86	25%	99%	\$0.16	0.72	0
Education	Cooling DX	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	1037.95	15	#####	95%	64%	\$2.75	0.04	0
Education	Cooling DX	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	1037.95	15	#####	45%	80%	\$2.09	0.06	0
Education	Cooling DX	Existing	Ductless Heat Pump	Ductless Heat Pump - SEER/EER 18/12.5, HSPF 10.0	Existing HVAC system	Per Ductless Heat Pump Cooling Ton	2.15	15	#####	90%	100%	#####	0.00	0
Education	Cooling DX	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	8150.35	7	#####	95%	85%	\$1.39	0.07	0
Education	Cooling DX	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	3737.87	20	#####	75%	99%	\$15.16	0.01	0
Education	Cooling DX	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	3622.38	20	#####	75%	99%	\$15.64	0.01	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Cooling DX	Existing	HVAC Diagnostic/Air Conditioner Tune Up	HVAC Diagnostic/Air Conditioner Tune Up	No Tune Up	Per Building	5090.91	10	\$5,800.84	95%	24%	\$0.21	0.52	0
Education	Cooling DX	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	9469.26	30	\$765.97	20%	84%	\$0.01	12.21	110
Education	Cooling DX	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	9176.69	30	\$765.97	80%	84%	\$0.01	11.83	11
Education	Cooling DX	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	14934.31	10	#####	10%	45%	\$0.31	0.34	0
Education	Cooling DX	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	8970.88	7	\$13,217.06	95%	75%	\$0.34	0.30	0
Education	Cooling DX	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	10092.24	18	#####	1%	98%	\$1.38	0.09	0
Education	Cooling DX	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	9780.41	18	#####	1%	98%	\$1.42	0.09	0
Education	Cooling DX	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	12938.77	15	\$4,225.62	10%	66%	\$0.05	2.55	28
Education	Cooling DX	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	21359.24	15	\$2,600.38	10%	95%	\$0.02	6.85	130
Education	Cooling DX	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	20699.29	15	\$2,600.38	50%	95%	\$0.02	6.63	16
Education	Cooling DX	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2803.40	5	\$5,766.39	50%	95%	\$0.62	0.16	0
Education	Cooling DX	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	2716.78	5	\$5,766.39	50%	95%	\$0.64	0.16	0
Education	Fax	Existing	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	0	0.00	4	\$0.00	90%	100%	\$0.00	370.90	7
Education	Fax	New	Fax - ENERGY STAR	ENERGY STAR Fax	Standard Fax	0	0.00	4	\$0.00	90%	100%	\$0.00	370.90	0
Education	Flat Screen Monitors	Existing	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	0	0.04	4	\$0.00	90%	100%	\$0.00	726.82	42
Education	Flat Screen Monitors	New	Monitor - ENERGY STAR	ENERGY STAR Monitor	Standard Monitor	0	0.04	4	\$0.00	90%	100%	\$0.00	726.82	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Freezer	Existing	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	0	0.00	12	\$0.00	90%	100%	\$0.00	3.13	1
Education	Freezer	New	Freezer (Residential) - ENERGY STAR	ENERGY STAR Freezer	Federal Standard 2015 Freezer	0	0.00	12	\$0.00	90%	100%	\$0.00	3.13	0
Education	Heat Pump	Existing	7 day, two stage setback thermostat	Setback Thermostat with 7 day, two stage	Manual Thermostat	Per Building	32779.53	10	\$536.49	100%	67%	\$0.00	31.42	387
Education	Heat Pump	Existing	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	720.74	20	\$18,951.18	95%	95%	\$3.25	0.03	0
Education	Heat Pump	New	Adding reflective roof treatment	Adding reflective roof treatment	Standard Roofing	Per Building	690.62	20	\$18,951.18	95%	95%	\$3.39	0.03	0
Education	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.15	15	\$0.09	90%	100%	\$0.09	1.16	0
Education	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - High Efficiency	High Efficiency - 10.0 EER, 3.3 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.15	15	\$0.09	90%	100%	\$0.09	1.16	0
Education	Heat Pump	Existing	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.28	15	\$0.18	90%	100%	\$0.09	1.11	151
Education	Heat Pump	New	Air Source Heat Pump > 240 kBtuh - Premium Efficiency	Premium Efficiency - 10.5 EER, 3.4 COP - Air Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.28	15	\$0.18	90%	100%	\$0.09	1.11	5
Education	Heat Pump	Existing	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	5546.39	15	\$1,685.00	95%	95%	\$0.04	2.35	107
Education	Heat Pump	New	Air curtain technology	Air curtain technology	No Air Curtain	Per air curtain installed on entrance to building	3537.17	15	\$1,685.00	95%	95%	\$0.07	1.50	1
Education	Heat Pump	Existing	Automated control system	Automated control system	Baseline DX	Per Building	10259.39	10	#####	95%	65%	\$0.33	0.28	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Heat Pump	New	Automated control system	Automated control system	Baseline DX	Per Building	9830.53	10	#####	95%	65%	\$0.34	0.27	0
Education	Heat Pump	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	51296.97	15	#####	25%	62%	\$0.07	1.54	111
Education	Heat Pump	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	68395.96	15	\$11,890.94	25%	95%	\$0.02	4.11	312
Education	Heat Pump	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	65536.84	15	\$11,890.94	75%	95%	\$0.03	3.93	21
Education	Heat Pump	Existing	Commercial energy recovery ventilation systems	Commercial energy recovery ventilation systems	No energy recovery ventilation system	Per Building	9343.94	15	#####	95%	95%	\$0.43	0.24	0
Education	Heat Pump	Existing	DX Coil Cleaning	DX Coil Cleaning	Base DX Packaged System, EER=10.3, 10 tons	Per Building	4242.10	5	\$5,648.18	95%	45%	\$0.40	0.22	0
Education	Heat Pump	Existing	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	18804.05	15	\$12,192.86	25%	99%	\$0.09	1.10	90
Education	Heat Pump	New	Demand controlled Ventilation and Circulating Systems	Demand controlled Ventilation and Circulating Systems	Standard Circulating System	Per Building	18017.99	15	\$6,502.86	25%	99%	\$0.05	1.98	2
Education	Heat Pump	Existing	Duct Insulation, Add R8	R-8	No Insulation	Per Building	864.89	15	#####	95%	64%	\$3.30	0.03	0
Education	Heat Pump	Existing	Duct Testing & Sealing	Duct Testing & Sealing	Existing Conditions	Per Building	864.89	15	#####	45%	80%	\$2.51	0.04	0
Education	Heat Pump	New	Facility Commissioning (New Construction)	Facility Commissioning	No Commissioning	Per Building	29491.58	7	#####	95%	85%	\$0.38	0.23	0
Education	Heat Pump	Existing	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	9274.30	20	#####	75%	99%	\$6.11	0.02	0
Education	Heat Pump	New	Green Roof (New construction or roof replacement)	Green Roof	Standard Roofing	Per Building	8886.61	20	#####	75%	99%	\$6.37	0.02	0
Education	Heat Pump	Existing	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh -	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	1.05	15	\$19.88	90%	100%	\$2.67	0.04	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
			Advanced Efficiency											
Education	Heat Pump	New	Ground Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh - Advanced Efficiency	Advanced Efficiency - 16.2 EER 4.0 COP - Ground Source Heat Pump > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	1.05	15	\$19.88	90%	100%	\$2.67	0.04	0
Education	Heat Pump	Existing	HVAC Diagnostic/Heat Pump Tune Up	HVAC Diagnostic/Heat Pump Tune Up	No Tune Up	Per Building	4242.10	10	\$5,495.53	95%	24%	\$0.23	0.40	0
Education	Heat Pump	Existing	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	7890.44	30	\$765.97	20%	84%	\$0.01	8.67	29
Education	Heat Pump	New	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	High Efficiency Energy Star Windows & Skylights, .32 U-Factor	0	Per Building	7560.60	30	\$765.97	80%	84%	\$0.01	8.31	3
Education	Heat Pump	Existing	Outside Air Economizer	Outside Air Economizer	No Economizer	Per Building Sqft for Outside Economizer	14934.31	10	#####	10%	45%	\$0.31	0.30	0
Education	Heat Pump	Existing	Re-commissioning (Existing Construction)	Re-commissioning (Existing Construction)	No Re-commissioning	Per Building	32830.06	7	\$13,217.06	95%	75%	\$0.09	0.95	0
Education	Heat Pump	Existing	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	8409.54	18	#####	1%	98%	\$1.65	0.06	0
Education	Heat Pump	New	Solid-state temperature controls	Solid-state temperature controls	0	Per Building	8058.01	18	#####	1%	98%	\$1.73	0.06	0
Education	Heat Pump	Existing	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	121879.85	15	#####	50%	95%	\$2.04	0.05	0
Education	Heat Pump	New	Variable Refrigerant Flow Heat Pump	Variable Refrigerant Flow Heat Pump	Existing HVAC system	Per Building	116784.98	15	#####	95%	95%	\$2.13	0.05	0
Education	Heat Pump	Existing	Wall Insulation	R-13	Average Existing Insulation	Per SqFt of Wall Insulation	47351.05	15	\$4,225.62	10%	66%	\$0.01	8.00	38
Education	Heat Pump	Existing	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	78166.81	15	\$2,600.38	10%	95%	\$0.00	21.46	178



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Heat Pump	New	Wall Insulation	R-21	R-13	Per SqFt of Wall Insulation	74899.25	15	\$2,600.38	50%	95%	\$0.00	20.56	24
Education	Heat Pump	Existing	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.94	15	\$1.84	90%	100%	\$0.28	0.36	0
Education	Heat Pump	New	Water Source Heat Pump Replacing Air Source Heat Pump > 240 kBtuh	Water Source Heat Pump - 12 EER, 4.2 COP - > 240 kBtuh	Standard Efficiency - 9.5 EER, 3.2 COP - Air Source Heat Pump > 240 kBtuh	0	0.94	15	\$1.84	90%	100%	\$0.28	0.36	0
Education	Heat Pump	Existing	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	10259.39	5	\$5,766.39	50%	95%	\$0.17	0.51	0
Education	Heat Pump	New	Window Shade	Window Shade - Film or Screen	No Shade	Per Building	9830.53	5	\$5,766.39	50%	95%	\$0.18	0.49	0
Education	Lighting Exterior	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	2828.74	10	\$100.00	85%	45%	\$0.01	14.64	73
Education	Lighting Exterior	Existing	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	7920.48	8	\$300.49	50%	45%	\$0.01	11.35	116
Education	Lighting Exterior	New	Photocell Controls (outdoor)	Photocell Controls (outdoor)	No Outdoor Photocell Lighting Control	Per Building	7920.48	8	\$300.49	50%	75%	\$0.01	11.35	5
Education	Lighting Exterior	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	6788.98	8	\$358.78	10%	100%	\$0.01	8.15	21
Education	Lighting Interior Fluorescent	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	12124.63	10	\$100.00	85%	45%	\$0.00	62.82	0
Education	Lighting Interior Fluorescent	Existing	Delamping fixtures	Delamping fixtures	0	Per Delamped Fixture	70.44	13	\$6.00	0%	85%	\$0.01	7.57	0
Education	Lighting Interior Fluorescent	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	6040.03	8	#####	65%	100%	\$0.54	0.17	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Lighting Interior Fluorescent	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	32736.50	10	\$6,688.65	10%	98%	\$0.04	2.54	658
Education	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent High Performance - Above Standard	Above Standard Fluorescent High Performance T-8	Standard Fluorescent EISA T12 Interior Lighting	0	0.23	13	\$0.22	90%	100%	\$0.14	0.68	0
Education	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent Reduced Wattage - Above Standard	Above Standard Fluorescent Reduced Wattage T-8	Standard Fluorescent EISA T12 Interior Lighting	0	0.23	13	\$0.92	90%	100%	\$0.63	0.16	0
Education	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T5 - Above Standard	Above Standard Fluorescent T-5	Standard Fluorescent EISA T12 Interior Lighting	0	0.28	13	\$0.43	90%	100%	\$0.23	0.43	0
Education	Lighting Interior Fluorescent	Existing	Lighting Interior - Fluorescent T8 - Above Standard	Above Standard Fluorescent T8 Interior Lighting	Standard Fluorescent EISA T12 Interior Lighting	0	0.07	13	\$0.16	90%	100%	\$0.34	0.29	0
Education	Lighting Interior Fluorescent	Existing	Lighting Interior - LED Tube - Above Standard	Above Standard LED Tube	Standard Fluorescent EISA T12 Interior Lighting	0	0.46	20	\$2.91	90%	100%	\$0.78	0.13	0
Education	Lighting Interior Fluorescent	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	29099.11	8	\$4,451.37	90%	98%	\$0.03	2.82	1,045
Education	Lighting Interior Fluorescent	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	29099.11	8	\$358.78	10%	99%	\$0.00	34.99	94
Education	Lighting Interior HID	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	69.93	10	\$100.00	85%	45%	\$0.26	0.36	0
Education	Lighting Interior HID	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	34.84	8	#####	65%	100%	\$92.98	0.00	0
Education	Lighting Interior HID	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	188.81	10	\$6,688.65	10%	98%	\$6.38	0.01	0
Education	Lighting Interior HID	Existing	Lighting Interior - Efficient Metal	Efficient Metal Halide	Standard HID Baseline - represents a	0	0.00	15	\$0.00	90%	100%	\$0.08	1.29	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
			Halide - Above Standard		mix of Mercury Vapor, High Pressure Sodium, Metal Halide									
Education	Lighting Interior HID	Existing	Lighting Interior - High Bay Fluorescent High Output - Above Standard	High Bay Fluorescent High Output (HO)	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	0	0.01	15	\$0.00	90%	100%	\$0.06	1.80	22
Education	Lighting Interior HID	Existing	Lighting Interior - High Bay LED - Above Standard	High Bay LED	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	0	0.01	20	\$0.00	90%	100%	\$0.04	2.83	2
Education	Lighting Interior HID	Existing	Lighting Interior - Induction - Above Standard	Induction	Standard HID Baseline - represents a mix of Mercury Vapor, High Pressure Sodium, Metal Halide	0	0.01	20	\$0.00	90%	100%	-\$0.04	999.00	0
Education	Lighting Interior HID	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	167.83	8	\$4,451.37	90%	98%	\$5.57	0.02	0
Education	Lighting Interior HID	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	167.83	8	\$358.78	10%	99%	\$0.45	0.20	0
Education	Lighting Interior Other	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	52.54	10	\$100.00	90%	100%	\$0.34	0.27	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Lighting Interior Other	Existing	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Exit Sign Retrofit: Compact Fluorescent, replacing incandescent	Incandescent Exit Sign	Per Exit Sign	76.04	10	\$19.00	95%	25%	\$0.04	2.07	1
Education	Lighting Interior Other	New	HE Lighting Fixtures/Design 10% better than code (New Construction)	HE Lighting Fixtures/Design 10% better than code (New Construction)	Standard Lighting Power Density (LPD)	0	0.28	15	\$0.13	100%	100%	\$0.06	1.61	0
Education	Lighting Interior Other	New	HE Lighting Fixtures/Design 15% better than code (New Construction)	HE Lighting Fixtures/Design 15% better than code (New Construction)	Standard Lighting Power Density (LPD)	0	0.42	15	\$0.19	100%	100%	\$0.06	1.61	0
Education	Lighting Interior Other	New	HE Lighting Fixtures/Design 30% better than code (New Construction)	HE Lighting Fixtures/Design 30% better than code (New Construction)	Standard Lighting Power Density (LPD)	0	0.85	15	\$0.38	100%	100%	\$0.06	1.61	287
Education	Lighting Interior Other	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	26.17	8	#####	90%	100%	\$123.75	0.00	0
Education	Lighting Interior Other	New	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	6845.66	8	#####	65%	100%	\$0.47	0.19	0
Education	Lighting Interior Other	Existing	LED exit sign	LED exit sign	CFL Exit Sign	Per Exit Sign	56.41	16	\$24.00	95%	50%	\$0.06	1.79	6
Education	Lighting Interior Other	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	141.85	10	\$6,688.65	90%	100%	\$8.49	0.01	0
Education	Lighting Interior Other	New	Light Pipes	Light Pipes	Standard lighting system	Per Building	37102.96	10	\$6,688.65	30%	98%	\$0.03	2.87	47
Education	Lighting Interior Other	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	126.09	8	\$4,451.37	90%	100%	\$7.41	0.01	0
Education	Lighting Interior Other	New	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	32980.41	8	\$4,451.37	90%	98%	\$0.03	3.20	4
Education	Lighting Interior Other	Existing	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	147.17	30	\$15.00	75%	95%	\$0.01	8.39	22



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Lighting Interior Other	New	Photoluminescent Exit Sign	Photoluminescent Exit Sign	Incandescent exit sign	Per Exit Sign	147.17	30	\$15.00	75%	95%	\$0.01	8.39	0
Education	Lighting Interior Other	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	126.09	8	\$358.78	90%	100%	\$0.60	0.15	0
Education	Lighting Interior Screw Base	Existing	Central lighting control system	Central lighting control system	Replace manual switches or no control	Per Building	135.70	10	\$100.00	85%	45%	\$0.13	0.70	0
Education	Lighting Interior Screw Base	Existing	Indoor Daylight Sensors	Indoor Daylight Sensors	No Indoor Daylighting Controls	Per Building	67.60	8	#####	65%	100%	\$47.91	0.00	0
Education	Lighting Interior Screw Base	Existing	Light Pipes	Light Pipes	Standard lighting system	Per Building	366.38	10	\$6,688.65	10%	98%	\$3.29	0.03	0
Education	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base CFL - Above Standard	CFL	EISA Standard Incandescent	0	0.02	5	\$0.00	90%	100%	\$0.01	9.46	8
Education	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base Incandescent - Backstop EISA Standard	Backstop EISA Standard Incandescent	EISA Standard Incandescent	0	0.01	2	\$0.00	90%	100%	\$0.01	5.37	0
Education	Lighting Interior Screw Base	Existing	Lighting Interior - Screw Base LED - Above Standard	LED	EISA Standard Incandescent	0	0.02	12	\$0.00	90%	100%	\$0.04	2.51	82
Education	Lighting Interior Screw Base	Existing	Occupancy sensor, wall or ceiling mounted	Occupancy sensor, wall or ceiling mounted	Manual Wall Switch	Per Occupancy Sensor	325.67	8	\$4,451.37	90%	98%	\$2.87	0.03	0
Education	Lighting Interior Screw Base	Existing	Time clock control	Time clock control	No Time Clock	Per Time Clock	325.67	8	\$358.78	10%	99%	\$0.23	0.39	0
Education	Other Plug Load	Existing	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	58.23	15	\$5.60	75%	75%	\$0.01	7.52	8
Education	Other Plug Load	New	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	15HP irrigation pump 91% efficient operates 12hrs/day, 3 days/week	Standard Irrigation Pump	Per Commercial Irrigation Pump Motor	58.23	15	\$5.60	75%	75%	\$0.01	7.52	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Other Plug Load	Existing	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	75%	90%	\$6.49	0.02	0
Education	Other Plug Load	New	Elevators	Elevators	Standard Elevator	Per Elevator Cab	6960.00	16	#####	100%	90%	\$6.49	0.02	0
Education	Other Plug Load	Existing	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	24.35	4	\$2.42	100%	20%	\$0.04	2.39	1
Education	Other Plug Load	New	Energy Star - Scanners	Energy Star - Scanners	Standard Scanner	Per Scanner	24.35	4	\$2.42	100%	20%	\$0.04	2.39	0
Education	Other Plug Load	Existing	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	914.78	10	\$0.00	95%	20%	\$0.00	0.00	0
Education	Other Plug Load	New	Energy Star - Water Cooler	Energy Star - Water Cooler	Std Water Cooler	Per Water Cooler	914.78	10	\$0.00	95%	20%	\$0.00	0.00	0
Education	Other Plug Load	Existing	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	1.19	5	\$4.88	95%	20%	\$1.24	0.07	0
Education	Other Plug Load	New	Energy Star Battery Charging System (for small cordless products)	Energy Star Battery Charging System (for small cordless products)	Standard Battery Charger	Per Battery Charger	1.19	5	\$4.88	95%	20%	\$1.24	0.07	0
Education	Other Plug Load	Existing	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	2183.77	5	\$369.83	95%	95%	\$0.05	1.71	133
Education	Other Plug Load	New	Occupancy sensor controls/Smart Strip	Occupancy sensor controls/Smart Strip	Computers, other plug loads	Per Advanced Power Strip	2183.77	5	\$369.83	95%	95%	\$0.05	1.71	3
Education	Photo Copiers	Existing	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	0	0.00	6	\$0.00	90%	100%	\$0.00	1,593.40	1
Education	Photo Copiers	New	Copiers - ENERGY STAR	ENERGY STAR Copiers	Standard Copiers	0	0.00	6	\$0.00	90%	100%	\$0.00	1,593.40	0
Education	Pool Pump	Existing	Pool Pump - Two Speed	Pool Pump - Two Speed	Pool Pump - Constant Speed	0	0.01	10	\$0.00	100%	100%	\$0.00	0.00	0
Education	Pool Pump	New	Pool Pump - Two Speed	Pool Pump - Two Speed	Pool Pump - Constant Speed	0	0.01	10	\$0.00	100%	100%	\$0.00	0.00	0
Education	Pool Pump	Existing	Pool Pump - VSD	Pool Pump - VSD	Pool Pump - Constant Speed	0	0.03	10	\$0.00	100%	100%	\$0.00	0.00	0
Education	Pool Pump	New	Pool Pump - VSD	Pool Pump - VSD	Pool Pump - Constant Speed	0	0.03	10	\$0.00	100%	100%	\$0.00	0.00	0
Education	Printers	Existing	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	0	0.05	5	\$0.00	90%	100%	\$0.00	4,457.26	17



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Printers	New	Printers - ENERGY STAR	ENERGY STAR Printers	Standard Printers	0	0.05	5	\$0.00	90%	100%	\$0.00	4,457.26	0
Education	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	2359.11	12	\$161.48	50%	100%	\$0.01	8.78	238
Education	Refrigeration	New	Anti-sweat heat (ASH) controls - Cooler	Anti-sweat heat (ASH) controls - Cooler	ASH without controls	Per refrigerated/freezer case unit door	2359.11	12	\$161.48	50%	100%	\$0.01	8.78	6
Education	Refrigeration	Existing	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	4342.28	12	\$161.48	50%	100%	\$0.01	16.16	462
Education	Refrigeration	New	Anti-sweat heat (ASH) controls - Freezer	Anti-sweat heat (ASH) controls - Freezer	ASH without controls	Per refrigerated/freezer case unit door	4342.28	12	\$161.48	50%	100%	\$0.01	16.16	12
Education	Refrigeration	Existing	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	614.05	8	\$99.68	95%	80%	\$0.03	2.64	117
Education	Refrigeration	New	Auto-closer: Walk-In Cooler	Auto-closer: Walk-In Cooler	No Auto-closer on Walk-in Cooler	Per Walk-in Cooler Door	614.05	8	\$99.68	95%	80%	\$0.03	2.64	3
Education	Refrigeration	Existing	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	1481.78	8	\$99.68	95%	80%	\$0.01	6.36	282
Education	Refrigeration	New	Auto-closer:Walk-In Freezer	Auto-closer:Walk-In Freezer	No Auto-closer on Walk-in Freezer	Per Walk-in Freezer Door	1481.78	8	\$99.68	95%	80%	\$0.01	6.36	7
Education	Refrigeration	Existing	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	3.01	12	\$0.94	95%	81%	\$0.05	1.93	1
Education	Refrigeration	New	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Commercial Solid Door Refrigerator & Freezer (Energy Star)	Standard Solid Door Refrigerator & Freezer	Per Solid Door Commercial Refrigerator/Freezer Energy Star	3.01	12	\$0.94	95%	81%	\$0.05	1.93	0
Education	Refrigeration	Existing	Compressor VSD retrofit	Compressor VSD retrofit	Base Refrigeration System - Grocery	Per Refrigerator/Freezer Compressor Motor HP	238.70	15	\$136.00	70%	86%	\$0.08	1.26	23
Education	Refrigeration	Existing	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	238.34	10	\$1,405.74	60%	80%	\$1.06	0.09	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Refrigeration	New	Demand Defrost Electric	Demand Defrost Electric	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Fan	238.34	10	\$1,405.74	60%	80%	\$1.06	0.09	0
Education	Refrigeration	Existing	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	59.59	10	\$1,405.74	90%	100%	\$4.25	0.02	0
Education	Refrigeration	New	Demand Hot Gas Defrost	Demand Hot Gas Defrost	Base Refrigeration System - Grocery	Per Walk-in Refrigerator/Freezer Evaporator Coil	59.59	10	\$1,405.74	90%	100%	\$4.25	0.02	0
Education	Refrigeration	Existing	Door Gasket - Cooler	Door Gasket - Cooler	Existing Gasket	Per linear foot of gasket on walk-in or reach-in cooler	230.03	4	\$51.12	95%	90%	\$0.08	1.06	49
Education	Refrigeration	Existing	Door Gasket - Freezer	Door Gasket - Freezer	Existing Gasket	Per linear foot of gasket on walk-in or reach-in freezer	805.11	4	\$51.12	95%	90%	\$0.02	3.72	172
Education	Refrigeration	Existing	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	721.69	15	\$464.38	95%	93%	\$0.09	1.12	131
Education	Refrigeration	New	ECM Case Motors	ECM Case Motors	Standard Case Motor	Per Refrigerator/Freezer Case Motor	721.69	15	\$464.38	95%	93%	\$0.09	1.12	3
Education	Refrigeration	Existing	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	320.10	15	\$428.47	10%	95%	\$0.19	0.54	0
Education	Refrigeration	New	Economizer for Walk-in Coolers	Economizer for Walk-in Coolers	No Economizer	Per Walk-in	320.10	15	\$428.47	5%	95%	\$0.19	0.54	0
Education	Refrigeration	Existing	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	808.94	15	\$76.68	90%	100%	\$0.01	7.59	0
Education	Refrigeration	New	Efficient compressor motor	Efficient compressor motor	Standard Compressor Motor	Per Refrigeration Equipment Compressor Motor	808.94	15	\$76.68	90%	100%	\$0.01	7.59	0
Education	Refrigeration	Existing	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	179.15	15	\$82.86	65%	75%	\$0.07	1.56	23
Education	Refrigeration	New	Floating head pressure controller	Floating head pressure controller	Standard head pressure control	Per Refrigerator/Freezer Rated Horsepower of Compressor	179.15	15	\$82.86	95%	75%	\$0.07	1.56	1
Education	Refrigeration	Existing	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	23.72	10	\$52.80	75%	55%	\$0.40	0.23	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Refrigeration	New	High Efficiency Ice Makers	High Efficiency Ice Makers	Standard Ice Maker	Per Air-cooled Ice Maker	23.72	10	\$52.80	95%	55%	\$0.40	0.23	0
Education	Refrigeration	Existing	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	172.82	15	\$123.88	50%	85%	\$0.10	1.00	18
Education	Refrigeration	New	High R-Value Glass Doors	High R-Value Glass Doors	Standard Glass Door	Per low-temperature (below 0°F) glass display case door	172.82	15	\$123.88	95%	92%	\$0.10	1.00	1
Education	Refrigeration	Existing	Insulation for bare suction lines	Insulation for bare suction lines	No Insulation	Per linear feet of walk-in cooler/freezer suction line	552.77	11	\$295.47	95%	50%	\$0.09	1.04	41
Education	Refrigeration	Existing	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	805.27	8	\$613.63	95%	80%	\$0.16	0.56	0
Education	Refrigeration	New	LED Refrigerated Case Door Lighting	LED Refrigerated Case Door Lighting	Standard Case Door Lighting	Per cooler or freezer display case door	805.27	8	\$613.63	95%	80%	\$0.16	0.56	0
Education	Refrigeration	Existing	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	172.82	15	\$123.88	50%	95%	\$0.10	1.00	0
Education	Refrigeration	New	No-heat glass doors	No-heat glass doors	Standard low-temp reach-in	Per low-temperature (below 0°F) glass display case door	172.82	15	\$123.88	95%	95%	\$0.10	1.00	0
Education	Refrigeration	Existing	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	4374.42	15	\$2,348.23	95%	86%	\$0.08	1.34	896
Education	Refrigeration	New	Quick acting freezer doors	Quick acting freezer doors	Standard Freezer Doors	Per Sqft of Freezer Door	4374.42	15	\$2,348.23	95%	86%	\$0.08	1.34	22
Education	Refrigeration	Existing	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	276.86	15	\$576.72	95%	49%	\$0.29	0.35	0
Education	Refrigeration	New	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC to ECM Evaporator Fan Motor	Reach-in PSC Motor	Per Evaporator Fan Motor	276.86	15	\$576.72	0%	49%	\$0.29	0.35	0
Education	Refrigeration	Existing	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole to ECM Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	1093.28	15	\$576.72	95%	49%	\$0.07	1.36	128
Education	Refrigeration	New	Reach-in Shaded Pole to ECM	Reach-in Shaded Pole to ECM	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	1093.28	15	\$576.72	0%	49%	\$0.07	1.36	0

Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
			Evaporator Fan Motor	Evaporator Fan Motor										
Education	Refrigeration	Existing	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	816.42	15	\$576.72	95%	49%	\$0.10	1.02	95
Education	Refrigeration	New	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole to PSC Evaporator Fan Motor	Reach-in Shaded Pole Motor	Per Evaporator Fan Motor	816.42	15	\$576.72	0%	49%	\$0.10	1.02	0
Education	Refrigeration	Existing	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	2048.67	3	\$6,252.70	10%	85%	\$1.42	0.06	0
Education	Refrigeration	New	Refrigeration Commissioning	Refrigeration Commissioning	Base Refrigeration System - Grocery	Per 1000 Building Sqft	2048.67	3	\$6,252.70	5%	90%	\$1.42	0.06	0
Education	Refrigeration	Existing	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	1007.19	4	\$101.98	95%	78%	\$0.04	2.33	187
Education	Refrigeration	New	Strip curtains for walk-ins	Strip curtains for walk-ins	Base Refrigeration System - Grocery	Per square foot of strip curtain area	1545.54	4	\$101.98	95%	78%	\$0.02	3.58	7
Education	Refrigeration	Existing	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	527.79	15	\$319.49	75%	49%	\$0.09	1.19	49
Education	Refrigeration	New	Walk-in PSC to ECM	Walk-in PSC to ECM	Walk-in PSC Motor	Per walk-in cooler or freezer motor	527.79	15	\$319.49	95%	49%	\$0.09	1.19	2
Education	Refrigeration	Existing	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	1412.13	15	\$319.49	75%	49%	\$0.03	3.18	130
Education	Refrigeration	New	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole to ECM	Walk-in Shaded Pole Motor	Per walk-in cooler or freezer motor	1412.13	15	\$319.49	95%	49%	\$0.03	3.18	4
Education	Refrigeration	Existing	eCube	eCube	No eCube	Per Walk-in	1561.65	9	\$509.90	95%	95%	\$0.06	1.44	353
Education	Refrigeration	New	eCube	eCube	No eCube	Per Walk-in	1561.65	9	\$509.90	95%	95%	\$0.06	1.44	9
Education	Refrigerator	Existing	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	0	0.01	12	\$0.00	90%	100%	\$0.09	1.02	0
Education	Refrigerator	New	Refrigerator - CEE Tier 2	CEE Tier 2 Refrigerator	Federal Standard 2015 Refrigerator	0	0.01	12	\$0.00	90%	100%	\$0.09	1.02	0



Segment	End Use	Construction Vintage	Measure Name	Measure Description	Baseline Description	Unit Description	Savings per Unit (kWh)	Measure Life	Incremental Cost (\$)	Technical Feasibility	Incomplete Factor	Levelized Cost (\$/kWh)	TRC B/C Ratio	Achievable Potential (MWh)
Education	Refrigerator	Existing	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	0	0.01	12	\$0.00	90%	100%	\$0.10	1.02	78
Education	Refrigerator	New	Refrigerator - CEE Tier 3	CEE Tier 3 Refrigerator	Federal Standard 2015 Refrigerator	0	0.01	12	\$0.00	90%	100%	\$0.10	1.02	5
Education	Refrigerator	Existing	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	0	0.00	12	\$0.00	90%	100%	\$0.09	1.02	0
Education	Refrigerator	New	Refrigerator - ENERGY STAR	ENERGY STAR Refrigerator	Federal Standard 2015 Refrigerator	0	0.00	12	\$0.00	90%	100%	\$0.09	1.02	0
Education	Room Cooling	Existing	Ceiling Insulation	R-20	Average Existing Insulation	Per SqFt of Ceiling Insulation	12410.25	15	#####	25%	62%	\$0.27	0.49	0
Education	Room Cooling	Existing	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	16547.00	15	\$11,890.94	25%	95%	\$0.10	1.30	83
Education	Room Cooling	New	Ceiling Insulation	R-30	R-20	Per SqFt of Ceiling Insulation	16515.55	15	\$11,890.94	75%	95%	\$0.10	1.30	6
Education	Room Cooling	Existing	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	0	0.03	12	\$0.01	90%	100%	\$0.08	1.36	5
Education	Room Cooling	New	ENERGY STAR Room Air Conditioner	ENERGY STAR Room AC - CEER/EER 11.2/11.3 (8,000-13,999 Btuh)	Federal Standard 2014 Room AC - CEER/EER 10.9/11.0 (8,000-13,999 Btuh)	0	0.03	12	\$0.01	90%	100%	\$0.08	1.36	0
Education	Servers	Existing	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.66	4	\$7.32	95%	86%	\$4.00	0.02	0
Education	Servers	New	80 Plus	80 Plus - Server/Desktop	Standard personal computer, desktop	Per Building	0.66	4	\$7.32	95%	86%	\$4.02	0.02	0
Education	Servers	Existing	Server - High Efficiency	High Efficiency Server	Standard Server	0	0.03	4	\$0.00	90%	100%	\$0.00	0.00	0