



Corporate Counsel
800 Hershey Park Drive
Hershey PA 17033
P (717) 531-3208
F (717) 531-3399
susan.marsh@amwater.com

Susan S. Marsh
Corporate Counsel

May 26, 2015

Rosemary Chiavetta, Secretary
Pennsylvania Public Utility
Commission
Commonwealth Keystone Building
400 North Street
Harrisburg, PA 17105-3265

In re: Application of Pennsylvania-American Water Company for Approval of (1) the transfer, by sale, of the water works property and rights of the Abbey Woods Homeowner Association to Pennsylvania-American Water Company; (2) the rights of Pennsylvania-American Water Company to furnish water service to the public in an additional portion of Jackson Township, Butler County, Pennsylvania. Docket No. A-2015-2470483

Dear Ms. Chiavetta:

In response to Sean Donnelly's request for additional responses to data requests issued on March 30, 2015, attached for e-filing is Pennsylvania-American Water Company's supplemental answers to the data requests A-4 and A-12 regarding the above referenced docket number.

Respectfully,

Susan Simms Marsh

blg
Enclosure

cc: S. Donnelley
S. Nahf
S. Fogelsanger

Bureau of Technical Utility Services Water/Wastewater Division

Supplemental Responses to Data Request 1

Application of Pennsylvania-American Water Company (PAWC) Abbey Woods Homeowners Association at Docket No. A-2015-2470483

May 26, 2015

Note: Restate the data request prior to providing a response. In addition, provide the name of the person(s) providing the response and/or information for each data response.

A-4. Please provide an itemized cost estimate for the construction of an interconnection between PAWC's existing water system to the Abbey Woods water distribution system.

Response: See below the itemized cost estimate for the construction of the interconnection.

Material & supplies	\$24,619
1,100 feet of 12" pipe installation	15,950
315 cu. yds. of premium backfill	11,340
2 hydrants	2,136
Temporary paving	2,000
Permanent paving	12,030
Restoration	6,300
Thrust Restraint	1,500
Total Estimated Cost	<u>\$75,875</u>

A-12. Please state the physical, operational and managerial improvements that will occur after closing along with the associated costs and anticipated improvements schedule.

Response: Currently, Abbey Woods has approximately 1,100' of 2" PVC pipe installed within their system. To improve the system we will be replacing this pipe with 12" ductile iron pipe so the entire development will be looped and fed by 8" and 12" ductile iron pipe. The New Castle Ellwood Distribution System is managed by a group of 3 supervisors and 21 bargaining unit employees. The replacement of the 1,100 feet of 2" pipe should take approximately 2 weeks and be completed around the anticipated closing date at the end of June. The estimated cost associated with the 2" PVC pipe replacement project is \$56,782 as follows:

Material & supplies	\$23,784
1,100 feet of 12" pipe installation	15,950
104 cu. yds. of premium backfill	3,742
Temporary paving	400
Permanent paving	2,406
Restoration	9,000
Thrust Restraint	1,500
Total Estimated Cost	<u>\$56,782</u>

VERIFICATION

SCOTT D. FOGELSANGER, subject to the penalties of 18 Pa. Cons. Stat. § 4904 relating to unsworn falsification to authorities, hereby avers that he is Senior Business Development Manager, for PENNSYLVANIA-AMERICAN WATER COMPANY, that as such he is authorized to sign this Verification its behalf; and that the facts set forth in the foregoing Responses to Data Requests are true and correct to the best of his knowledge, information or belief.



Scott D. Fogelsanger, Senior Business Development
Manager

Dated: 5-26-15