



Line Size: 12 " Manhole Depth: 0 "


M-3 March 1, 2013 through March 31, 2013






M-3 March 1, 2013 through March 31, 2013



M-3 March 1, 2013 through March 31, 2013




Line Size: 12 " Manhole Depth: 0 "




Line Size: 12 "      Manhole Depth: 0 "


M-3      May 1, 2013 through May 31, 2013






M-3      May 1, 2013 through May 31, 2013






M-3      May 1, 2013 through May 31, 2013






Line Size: 12 " Manhole Depth: 0 "






Line Size: 8 " Manhole Depth: 0 "






Line Size: 8 " Manhole Depth: 0 "



Line Size: 8" Manhole Depth: 0"






Line Size: 8 " Manhole Depth: 0 "








Line Size: 8 " Manhole Depth: 0 "



Line Size: 8 " Manhole Depth: 0 "




Line Size: 15 "

Manhole Depth: 0 "

M-5

January 1, 2013 through January 31, 2013


Scatter Plot (Head Vs Velocity)



M-5

January 1, 2013 through January 31, 2013


Scatter Plot (Free Flow)



M-5

January 1, 2013 through January 31, 2013

Scatter Plot (Head Vs Flow)




Line Size: 15 "

Manhole Depth: 0 "

M-5

February 1, 2013 through February 28, 2013


Scatter Plot (Head Vs Velocity)



M-5

February 1, 2013 through February 28, 2013


Scatter Plot (Free Flow)






M-5

February 1, 2013 through February 28, 2013

Scatter Plot (Head Vs Flow)






Line Size: 15 " Manhole Depth: 0 "






Line Size: 15 "

Manhole Depth: 0 "






Line Size: 15 "

Manhole Depth: 0 "






Line Size: 15 "

Manhole Depth: 0 "








Line Size: 12 " Manhole Depth: 0 "






Line Size: 12 "




Manhole Depth: 0 "






Line Size: 12 " Manhole Depth: 0 "






Line Size: 12 " Manhole Depth: 0 "



Line Size: 12 " Manhole Depth: 0 "






Line Size: 12 " Manhole Depth: 0 "






Line Size: 12 "

Manhole Depth: 0 "






Line Size: 12 "

Manhole Depth: 0 "











Line Size: 12 " Manhole Depth: 0 "






Line Size: 12 " Manhole Depth: 0 "



Line Size: 12 "      Manhole Depth: 0 "




Line Size: 12 " Manhole Depth: 0 "



APPENDIX E


---

DRAVOSBURG MODEL SYSTEM MAP



Sources: Esri, DeLorme, NAVTEQ, USGS, Intermap, iPC, NRCAN, Esri Japan, METI, Esri China (Hong Kong), Esri (Thailand), TomTom, 2013

**220-53**  
**Exhibit**



**CITY OF DRAVOSBURG**  
**ALLEGHENY COUNTY, PENNSYLVANIA**  
**MODEL SYSTEM MAP**



5175 Cambridge Run Road  
Pittsburgh, PA 15205  
Phone: 412-484-0010  
Fax: 412-484-0008  
www.klhengineers.com



APPENDIX F

---

DRAVOSBURG MODEL PHYSICAL CHARACTERISTICS (LIST)

# MODEL HYDRAULIC CHARACTERISTICS

## Storage Nodes

Storage ID	Invert Elevation (ft)	Maximum Depth (ft)
DV100	725.65	14.25
REGULATOR PIT	725.643	14.82
METWELL	720.735	24.42

## Outfall Nodes

Outfall ID	TYPE	Invert Elevation (ft)
DV300	0: Free	723.852
DUMMY_OUTFALL	0: Free	715

## Conduits

Conduit ID	LENGTH (ft)	Manhole's N	Upstream Offset (ft)	Downstream Offset (ft)	Minimum Loss Coeff	Flow Entry Method	Shape	Material	Diameter (ft)	Walls
DV100-DV101	869.89	0.013	0	0	0.05	No	0: Circular		6	
DV102-DV101	28.827	0.013	0	0.14	0.05	No	0: Circular		3	
DV100-DV102	23.555	0.013	0	0	0.05	No	0: Circular		6	
DV103-DV102	77.943	0.013	0.04	0.17	0.05	No	0: Circular		1.5	
DV105-DV102	127.445	0.013	0	0.25	0.05	No	0: Circular		1	
DV_CHAM-DV103	84.148	0.013	0	0.64	0.05	No	0: Circular		2	
DV104-DV103	24.294	0.013	0	0	0.05	No	0: Circular		0.657	
DV105-DV_CHAM	75.444	0.013	0	0.47	0.05	No	0: Circular		6	
DV107-DV105	242.876	0.013	0	0.54	0.05	No	0: Circular		6	
DV173-DV174	103.178	0.013	0	0.57	0.05	No	0: Circular		6	
DV107-DV173	26.479	0.013	0	0.22	0.05	No	0: Circular		6	
DV434-DV171	444.357	0.013	0	0.32	0.05	No	2: Rect-Closed		4	3
DV104-DV171	427.835	0.013	0	0	0.05	No	0: Circular		2	
DV416-DV414	300.414	0.013	0.41	0.62	0.05	No	0: Circular		2	
DV409-DV414	31.747	0.013	0	0	0.05	No	0: Circular		1	
DV408-DV409	271.638	0.013	0.2	0.64	0.05	No	0: Circular		2	
DV407-DV409	249.924	0.013	0	0	0.05	No	0: Circular		1.5	
DV406-DV407	37.691	0.013	0	0.19	0.05	No	0: Circular		1.5	
DV405-DV406	269.476	0.013	0	0.22	0.05	No	0: Circular		1.5	
DV403-DV405	330.934	0.013	0	0.14	0.05	No	0: Circular		1.5	
DV402-DV403	437.244	0.013	0	0.23	0.05	No	0: Circular		1.5	
DV351-DV402	144.37	0.013	0	0.7	0.05	No	0: Circular		0.667	
DV142-DV351	249.744	0.013	0	0.24	0.05	No	0: Circular		0.667	
DV144-DV107	244.914	0.013	0	0.24	0.05	No	0: Circular		2	
DV116-DV144	252.35	0.013	0	0.2	0.05	No	0: Circular		1	
DV156-DV108	179.84	0.013	0	0.16	0.05	No	0: Circular		1.5	
DV107-DV156	25.957	0.013	0	0	0.05	No	0: Circular		1.5	
DV_CHAM-DV176	111.652	0.013	1.74	0.09	0.05	No	0: Circular		6	
DV107-DV_CHAM	21.257	0.013	0	0.22	0.05	No	2: Rect-Closed		1	
DV107-DV_DUMMY	310.255	0.013	0	0	0.05	No	0: Circular		2	
DV109-DV107	127.522	0.013	0	0	0.05	No	0: Circular		1	
DV230-DV300	5.482	0.013	0	0	0.05	No	0: Circular		1	
METWELL-DV300-DUMMY	1.433	0.013	0	0	0	No	0: Circular		6	



Manholes

Junction ID	Invert Elevation (ft)	Max Depth (ft)
DV352	980.275	6.55
<b>DV351</b>	<b>977.567</b>	<b>10.35</b>
DV201	721.89	18.93
<b>DV103</b>	<b>721.677</b>	<b>18.52</b>
DV157	830.341	11.77
<b>DV156</b>	<b>829.875</b>	<b>11.31</b>
DV108	823.894	10.22
<b>DV144</b>	<b>797.003</b>	<b>8.84</b>
DV107	774.089	6.63
<b>DV402</b>	<b>952.878</b>	<b>6.12</b>
DV403	947.717	7.92
<b>DV405</b>	<b>924.804</b>	<b>14.84</b>
DV406	915.654	9.22
<b>DV407</b>	<b>914.833</b>	<b>8.54</b>
DV408	910.669	9.37
<b>DV409</b>	<b>899.298</b>	<b>8.72</b>
DV416	894.838	11.32
<b>DV414</b>	<b>854.103</b>	<b>11.03</b>
DV434	783.08	30.96
<b>DV171</b>	<b>742.859</b>	<b>12.03</b>
DV173	733.376	17.72
<b>DV174</b>	<b>732.656</b>	<b>13.3</b>
DV105	728.304	11.14
<b>DV102</b>	<b>721.402</b>	<b>21.12</b>
DV101	720.905	21.53
<b>DV176</b>	<b>726.774</b>	<b>15.06</b>
DV_DUMMY	746.176	4
<b>DV300</b>	<b>722.133</b>	<b>20.01</b>
DV230	722.17	19.97
<b>DV229</b>	<b>722.402</b>	<b>17.05</b>

APPENDIX G


---

MONITORED VS. MODELED HYDROGRAPHS

Meter M-3  
SUMMER MODEL  
RAIN EVENTS

No.	Start Date	End Date	Total Rain	Max Int	Peak MOD Flow	Peak MON Flow	% Difference	Modeled Volume	Monitored Volume	% Difference
1	1/28/13 3:00	1/29/13 13:00	0.55	0.20	1.07	1.72	37.88%	0.236	0.334	29.25%
2	1/30/13 10:15	1/31/13 10:30	1.08	0.32	1.60	1.87	14.69%	0.408	0.451	9.55%
3	2/26/13 12:30	2/27/13 15:15	1.01	0.44	1.87	1.92	2.16%	0.362	0.453	20.15%
4	3/25/13 8:30	3/26/13 8:30	0.78	0.44	1.81	0.00	100.00%	0.275	0.000	100.00%
5	4/10/13 15:45	4/11/13 7:30	0.58	0.88	3.03	2.23	26.34%	0.099	0.106	6.61%
6	4/16/13 20:00	4/17/13 6:45	1.13	2.40	3.43	2.97	13.50%	0.204	0.090	55.65%
7	5/10/13 9:15	5/11/13 16:45	0.79	0.52	1.765	2.164	18.45%	0.254	0.255	0.35%
8	5/22/13 16:00	5/24/13 11:30	1.13	1.08	2.466	2.477	0.44%	0.272	0.360	24.48%
						No Monitored Flow				


# Meter M-3 Rain Event 1




**Meter M-4A  
SUMMER MODEL  
RAIN EVENTS**

No.	Start Date	End Date	Total Rain	Max Int	Peak MOD Flow	Peak MON Flow	% Difference		Modeled Volume	Monitored Volume	% Difference	
1	1/28/13 3:00	1/28/13 20:00	0.53	0.20	0.09	0.09	3.33%	Mod HIGH	0.029	0.024	15.20%	Mod HIGH
2	1/30/13 10:15	1/31/13 8:30	1.08	0.32	0.13	0.21	36.59%	Mod LOW	0.057	0.088	34.88%	Mod LOW
3	2/26/13 12:30	2/27/13 13:15	1.01	0.44	0.14	0.10	24.75%	Mod HIGH	0.047	0.030	35.23%	Mod HIGH
4	3/25/13 15:15	3/26/13 6:30	0.77	0.44	0.13	0.06	58.33%	Mod HIGH	0.038	0.016	58.94%	Mod HIGH
5	4/10/13 15:45	4/11/13 5:30	0.58	0.88	0.11	0.07	30.86%	Mod HIGH	0.014	0.011	23.23%	Mod HIGH
6	4/16/13 20:00	4/17/13 4:45	1.13	2.40	0.21	0.23	9.70%	Mod LOW	0.024	0.032	25.32%	Mod LOW
7	5/22/13 23:15	5/23/13 14:30	0.52	0.72	0.125	0.069	44.53%	Mod HIGH	0.019	0.009	52.55%	Mod HIGH
8	5/10/13 9:15	5/11/13 20:45	0.79	0.52	0.191	0.071	63.00%	Mod HIGH	0.045	0.020	56.00%	Mod HIGH
9	5/22/13 16:00	5/24/13 15:30	1.13	1.08	0.281	0.094	66.43%	Mod HIGH	0.049	0.017	65.14%	Mod HIGH


# Meter M-4A Rain Event 1



# Meter M-4A Rain Event 2




# Meter M-4A Rain Event 3







# Meter M-3 Rain Event 2




# Meter M-3 Rain Event 3




# Meter M-3 Rain Event 4




# Meter M-3 Rain Event 5




# Meter M-3 Rain Event 6




# Meter M-3 Rain Event 7



# Meter M-3 Rain Event 8




# Meter M-4A Rain Event 4







# Meter M-4A Rain Event 5




# Meter M-4A Rain Event 6



# Meter M-4A Rain Event 7




# Meter M-4A Rain Event 8




**Meter 5  
SUMMER MODEL  
RAIN EVENTS**

No.	Start Date	End Date	Total Rain	Max Int	Peak MOD Flow	Peak MON Flow	% Difference		Modeled Volume	Monitored Volume	% Difference	
1	1/28/13 3:00	1/28/13 20:00	0.53	0.20	0.04	0.04	4.55%	Mod HIGH	0.007	0.002	67.11%	Mod HIGH
2	1/30/13 10:15	1/31/13 8:30	1.08	0.32	0.07	0.11	33.64%	Mod LOW	0.015	0.018	16.34%	Mod LOW
3	2/26/13 12:30	2/27/13 13:15	1.01	0.44	0.09	0.07	23.08%	Mod HIGH	0.014	0.008	45.71%	Mod HIGH
4	3/25/13 15:15	3/26/13 6:30	0.77	0.44	0.08	0.01	82.46%	Mod HIGH	0.011	0.002	81.77%	Mod HIGH
5	4/10/13 15:45	4/11/13 5:30	0.58	0.88	0.15	0.14	7.16%	Mod HIGH	0.006	0.002	62.53%	Mod HIGH
6	4/16/13 20:00	4/17/13 4:45	1.13	2.40	0.40	0.36	10.17%	Mod HIGH	0.014	0.014	3.03%	Mod LOW
7	5/22/13 23:15	5/23/13 14:30	0.52	0.72	0.129	0.093	27.91%	Mod HIGH	0.007	0.003	60.39%	Mod HIGH
8	5/10/13 9:15	5/11/13 20:45	0.79	0.52	0.064	0.095	32.87%	Mod LOW	0.007	0.004	46.53%	Mod HIGH
9	5/22/13 16:00	5/24/13 15:30	1.13	1.08	0.122	0.187	34.64%	Mod LOW	0.011	0.006	44.62%	Mod HIGH


# Meter 5 Rain Event 1



# Meter 5 Rain Event 2




# Meter 5 Rain Event 3







# Meter 5 Rain Event 4




# Meter 5 Rain Event 5




# Meter 5 Rain Event 6



# Meter 5 Rain Event 7




# Meter 5 Rain Event 8




**Meter M-6A  
SUMMER MODEL  
RAIN EVENTS**

No.	Start Date	End Date	Total Rain	Max Int	Peak MOD Flow	Peak MON Flow	% Difference		Modeled Volume	Monitored Volume	% Difference	
1	1/28/13 3:00	1/28/13 20:00	0.53	0.20	0.20	0.37	45.84%	Mod LOW	0.046	0.054	14.41%	Mod LOW
2	1/30/13 10:15	1/31/13 8:30	1.08	0.32	0.30	0.50	39.40%	Mod LOW	0.086	0.088	3.11%	Mod LOW
3	2/26/13 12:30	2/27/13 13:15	1.01	0.44	0.34	0.44	23.58%	Mod LOW	0.075	0.073	2.61%	Mod HIGH
4	3/25/13 15:15	3/26/13 6:30	0.77	0.44	0.30	0.16	47.81%	Mod HIGH	0.057	0.000	100.00%	Mod HIGH
5	4/10/13 15:45	4/11/13 5:30	0.58	0.88	0.55	0.61	10.33%	Mod LOW	0.029	0.018	38.09%	Mod HIGH
6	4/16/13 20:00	4/17/13 4:45	1.13	2.40	1.39	1.01	27.20%	Mod HIGH	0.053	0.037	29.14%	Mod HIGH
7	5/22/13 23:15	5/23/13 14:30	0.52	0.72	0.463	0.722	35.90%	Mod LOW	0.032	0.038	14.50%	Mod LOW
8	5/22/13 16:00	5/24/13 15:30	1.13	1.08	0.779	0.931	16.33%	Mod LOW	0.071	0.081	12.44%	Mod LOW

# Meter M-6A Rain Event 1




# Meter M-6A Rain Event 2







# Meter M-6A Rain Event 3




# Meter M-6A Rain Event 4




# Meter M-6A Rain Event 5




# Meter M-6A Rain Event 6



# Meter M-6A Rain Event 7




# Meter M-6A Rain Event 8



Meter M-7  
SUMMER MODEL  
RAIN EVENTS


No.	Start Date	End Date	Total Rain	Max Int	Peak MOD Flow	Peak MON Flow	% Difference		Modeled Volume	Monitored Volume	% Difference	
1	1/28/13 3:00	1/29/13 13:00	0.55	0.20	0.20	0.59	66.55%	Mod LOW	0.050	0.043	15.74%	Mod HIGH
2	1/30/13 10:15	1/31/13 10:30	1.08	0.32	0.30	0.51	41.83%	Mod LOW	0.085	0.062	26.76%	Mod HIGH
3	2/26/13 12:30	2/27/13 15:15	1.01	0.44	0.42	0.67	37.82%	Mod LOW	0.076	0.073	4.69%	Mod HIGH
4	3/25/13 8:30	3/26/13 8:30	0.78	0.44	0.35	0.23	35.05%	Mod HIGH	0.059	0.023	61.10%	Mod HIGH
5	4/10/13 15:45	4/11/13 7:30	0.58	0.88	0.59	0.00	100.00%	Mod HIGH	0.034	0.000	100.00%	Mod HIGH
6	4/16/13 20:00	4/17/13 6:45	1.13	2.40	1.54	1.43	6.83%	Mod HIGH	0.060	0.051	14.91%	Mod HIGH
7	5/10/13 9:15	5/11/13 16:45	0.79	0.52	0.378	0.191	49.47%	Mod HIGH	0.057	0.019	66.89%	Mod HIGH
8	5/22/13 16:00	5/24/13 11:30	1.13	1.08	0.724	0.665	8.20%	Mod HIGH	0.070	0.051	26.82%	Mod HIGH
		No Monitored Flow										

# Meter M-7 Rain Event 1







# Meter M-7 Rain Event 2




# Meter M-7 Rain Event 3




# Meter M-7 Rain Event 4




# Meter M-7 Rain Event 5




# Meter M-7 Rain Event 6



# Meter M-7 Rain Event 7



# Meter M-7 Rain Event 8



APPENDIX H


---

MONITORED VS. MODELED REGRESSION PLOTS




### Peak Flow Comparison M-3

$$y = 0.4496x + 1.2147$$
$$R^2 = 0.7826$$




### Total Volume Comparison M-3

$$y = 1.3087x - 0.0502$$
$$R^2 = 0.7928$$




### Peak Flow Comparison M-4A

$$y = 0.2319x + 0.0744$$
$$R^2 = 0.0466$$




### Total Volume Comparison M-4A

$$y = 0.9629x - 0.007$$
$$R^2 = 0.3634$$



### Peak Flow Comparison M-5


$y = 0.8753x + 0.0113$   
 $R^2 = 0.8553$



- ◆ Peak Flow
- Perfect Match
- Linear (Peak Flow)



### Total Volume Comparison M-5

$$y = 1.4022x - 0.0079$$
$$R^2 = 0.7028$$




### Peak Flow Comparison M-6A

$$y = 0.6259x + 0.2552$$
$$R^2 = 0.7128$$



### Total Volume Comparison M-6A

$$y = 1.0973x - 0.0129$$
$$R^2 = 0.5085$$





- ◆ Total Volume
- Perfect Match
- Linear (Total Volume)




### Peak Flow Comparison Meter M-7

$$y = 0.7767x + 0.1795$$
$$R^2 = 0.761$$



### Total Volume Comparison Meter M-7

$$y = 1.164x - 0.0301$$
$$R^2 = 0.5244$$




◆ Total Volume    — Perfect Match    — Linear (Total Volume)

APPENDIX I


---

TYPICAL YEAR RAIN HYETOGRAPH

# Typical Year Rainfall (Jan - June)



# Typical Year Rainfall (June - Dec)



APPENDIX J

---

INFOSWMM TYPICAL YEAR MODEL REPORT

-----  
 Comprehensive Storm Water Management Model: based on EPA-SWMM 5.0.022  
 -----

Warning 08: elevation drop 5.735 exceeds length 5.186 for Conduit WETWELL-DUMMY\_OUTFALL

Needed length: 5.735000 ft

Warning 02: maximum depth 4.320 increased for Node DV\_DUMMY

\*\*\*\*\*

Rainfall File Summary

\*\*\*\*\*

Station	First	Last	Recording	Periods	Periods
Periods					
ID	Date	Date	Frequency	w/Precip	Missing
Malfunc.					

-----  
 RG-274385S001 DEC-21-2002 DEC-30-2003 15 min 1497 0  
 0

	Volume	Volume
Rainfall Dependent I/I	acre-feet	10 <sup>6</sup> gal
Sewershed Rainfall .....	666.662	217.242
RDII Produced .....	47.369	15.436
RDII Ratio .....	0.071	

\*\*\*\*\*  
 NOTE: The summary statistics displayed in this report are based on results found at every computational time step, not just on results from each reporting time step.  
 \*\*\*\*\*

\*\*\*\*\*

Analysis Options

\*\*\*\*\*

Flow Units ..... MGD  
 Process Models:  
 Rainfall/Runoff ..... YES  
 Snowmelt ..... NO  
 Groundwater ..... NO  
 Flow Routing ..... YES  
 Ponding Allowed ..... YES  
 Water Quality ..... NO  
 Flow Routing Method ..... DYNWAVE  
 Starting Date ..... DEC-25-2002 00:00:00  
 Ending Date ..... JAN-05-2004 11:45:00  
 Antecedent Dry Days ..... 5.0  
 Report Time Step ..... 00:15:00  
 Routing Time Step ..... 15.00 sec

```

*****
Flow Routing Continuity
*****

```

	Volume acre-feet	Volume 10 <sup>6</sup> gal
Dry Weather Inflow .....	346.968	113.065
Wet Weather Inflow .....	0.000	0.000
Groundwater Inflow .....	0.000	0.000
RDII Inflow .....	47.369	15.436
External Inflow .....	0.000	0.000
External Outflow .....	388.744	126.678
Internal Outflow .....	0.000	0.000
Storage Losses .....	0.000	0.000
Initial Stored Volume ....	0.000	0.000
Final Stored Volume .....	0.005	0.002
Continuity Error (%) .....	1.417	

```

*****
Highest Continuity Errors
*****

```

Node WETWELL	5.26%	7.0270
Node DV101	-4.05%	-5.1935
Node DV176	-0.32%	-0.0005
Node DV102	-0.01%	-0.0157
Node DV156	0.01%	0.0001
Node DV108	-0.01%	-0.0001
Node DV107	-0.00%	-0.0000
Node DV300	0.00%	0.0004
Node DV103	0.00%	0.0022
Node DV408	0.00%	0.0002
Node DV405	0.00%	0.0002
Node DV144	-0.00%	-0.0000
Node REGULATOR_PIT	0.00%	0.0010
Node DV416	0.00%	0.0001
Node DV434	0.00%	0.0001
Node DV_DUMMY	0.00%	0.0001
Node DV406	-0.00%	-0.0001
Node DV171	0.00%	0.0001
Node DV351	0.00%	0.0001
Node DV105	0.00%	0.0003
		1.8220 Mgal

```

*****
Time-Step Critical Elements
*****

```

```

Link DV101-DV_WETWELL (94.73%)
Link DV230-DV300 (5.26%)
Link DV102-DV101 (0.01%)
Link DV103-DV102 (0.00%)
Link DV201-DV103 (0.00%)
Link DV_CHAM-DV103 (0.00%)
Link DV156-DV108 (0.00%)
Node DV105 (0.00%)
Link CDT-13 (0.00%)
Link DV414-DV434 (0.00%)
Link DV351-DV402 (0.00%)
Link DV105-DV_CHAM (0.00%)

```



Link DV144-DV107 (0.00%)  
 Node DV103 (0.00%)  
 Node DV402 (0.00%)  
 Link DV171-DV173 (0.00%)  
 Link DV300-DV102 (0.00%)  
 Link DV352-DV351 (0.00%)  
 Link DV176-DV100 (0.00%)  
 Link DV157-DV156 (0.00%)

\*\*\*\*\*

Highest Flow Instability Indexes

\*\*\*\*\*

Link WETWELL-DUMMY\_OUTFALL (0)  
 Link DV101-DV\_WETWELL (0)  
 Link DV102-DV101 (0)  
 Link DV\_CHAM-DV103 (0)  
 Link DV230-DV300 (0)  
 Link DV351-DV402 (0)  
 Link DV406-DV407 (0)  
 Link DV300-DV102 (0)  
 Link DV103-DV102 (0)  
 Link DV201-DV103 (0)  
 Link DV173-DV174 (0)  
 Link DV229-DV230 (0)  
 Link DV171-DV173 (0)  
 Link DV176-DV100 (0)  
 Link DV105-DV\_CHAM (0)  
 Link DV157-DV156 (0)  
 Link IN\_VAULT (0)  
 Link DV\_CHAM-DV176 (0)  
 Link DV409-DV416 (0)  
 Link DV416-DV414 (0)

\*\*\*\*\*

Routing Time Step Summary

\*\*\*\*\*

Minimum Time Step : 0.10 sec  
 Average Time Step : 1.93 sec  
 Maximum Time Step : 2.36 sec  
 Percent in Steady State : 0.00  
 Average Iterations per Step : 1.97  
 Total Steps : 16520888  
 Total Iterations : 32536306  
 Minimum Possible Steps : 13800891

\*\*\*\*\*

Node Depth Summary

\*\*\*\*\*

Maximum Time of Max	Average	Maximum	Maximum	Time of Max
Output HGL Occurrence	Depth	Depth	Run HGL	Occurrence

Node Feet	days	hr:min	Type	Feet	Feet	Feet	days	hr:min
DV101			JUNCTION	0.41	7.32	728.23	329	08:32
725.69	157	11:45						
DV102			JUNCTION	0.26	6.13	727.54	157	11:37
726.92	157	11:45						
DV103			JUNCTION	0.38	5.94	727.62	157	11:36
727.17	157	11:45						
DV105			JUNCTION	0.13	0.61	728.92	157	11:50
728.86	157	11:45						
DV107			JUNCTION	0.01	0.14	774.23	157	11:48
774.23	157	11:45						
DV108			JUNCTION	0.01	0.12	824.01	157	11:50
824.01	157	11:45						
DV144			JUNCTION	0.01	0.12	797.12	157	11:50
797.12	157	11:45						
DV156			JUNCTION	0.01	0.16	830.04	157	11:50
830.04	157	11:45						
DV157			JUNCTION	0.01	0.26	830.60	157	11:35
830.55	157	11:45						
DV171			JUNCTION	0.02	0.08	742.94	329	13:20
742.94	329	13:15						
DV173			JUNCTION	0.23	1.05	734.43	157	11:50
734.33	157	11:45						
DV174			JUNCTION	0.12	0.57	733.23	157	11:50
733.18	157	11:45						
DV176			JUNCTION	0.00	0.57	727.34	157	11:50
727.26	157	11:45						
DV201			JUNCTION	0.19	13.42	735.31	136	08:05
728.90	157	11:45						
DV229			JUNCTION	0.17	41.60	764.00	157	11:37
727.98	157	11:45						
DV230			JUNCTION	0.12	10.78	732.95	157	11:36
727.28	157	11:45						
DV300			JUNCTION	0.12	12.16	734.29	157	11:36
727.25	157	11:45						
DV351			JUNCTION	0.05	0.15	977.71	157	12:15
977.71	157	12:15						
DV352			JUNCTION	0.09	0.30	980.58	157	12:14
980.58	157	12:15						
DV402			JUNCTION	0.05	0.15	953.03	157	12:15
953.03	157	12:15						
DV403			JUNCTION	0.05	0.14	947.86	157	12:15
947.86	157	12:15						
DV405			JUNCTION	0.06	0.17	924.97	157	12:15
924.97	157	12:15						
DV406			JUNCTION	0.07	0.22	915.88	157	12:16
915.88	157	12:15						
DV407			JUNCTION	0.07	0.20	915.03	157	12:16
915.03	157	12:15						
DV408			JUNCTION	0.25	0.35	911.02	157	12:17
911.02	157	12:15						
DV409			JUNCTION	0.04	0.11	899.41	157	12:17
899.41	157	12:15						

DV414		JUNCTION	0.04	0.12	854.23	157	12:18
854.22	157	12:15					
DV416		JUNCTION	0.44	0.52	895.36	157	12:18
895.36	157	12:15					
DV434		JUNCTION	0.01	0.04	783.12	157	12:20
783.12	157	12:15					
DV_DUMMY		JUNCTION	0.01	0.05	746.23	329	13:20
746.23	329	13:15					
DUMMY_OUTFALL		OUTFALL	0.05	0.19	715.19	195	03:52
715.16	157	11:45					
DV100		OUTFALL	0.00	0.58	724.43	157	11:50
724.34	157	11:45					
DV VAULT		STORAGE	0.26	2.26	728.94	157	11:50
728.87	157	11:45					
REGULATOR_PIT		STORAGE	0.16	2.50	728.14	157	11:50
728.06	157	11:45					
WETWELL		STORAGE	0.04	0.40	721.14	195	03:52
721.07	157	11:45					

\*\*\*\*\*  
Node Inflow Summary  
\*\*\*\*\*

Total Inflow Volume Node 10 <sup>6</sup> gal	Type	Maximum	Maximum	Time of Max		Lateral
		Lateral Inflow MGD	Total Inflow MGD	Occurrence	days hr:min	Inflow Volume 10 <sup>6</sup> gal
128.363	JUNCTION	0.000	4.743	157	11:37	0.000
128.348	JUNCTION	0.000	4.717	157	11:50	0.000
111.037	JUNCTION	0.000	4.146	157	11:36	0.000
91.985	JUNCTION	0.000	7.387	157	11:50	0.000
0.778	JUNCTION	0.000	0.315	157	11:50	0.000
0.778	JUNCTION	0.000	0.315	157	11:50	0.000
0.778	JUNCTION	0.000	0.315	157	11:50	0.000
0.778	JUNCTION	0.000	0.327	157	11:35	0.000
0.778	JUNCTION	0.315	0.315	157	11:45	0.758
13.491	JUNCTION	0.000	0.409	329	13:20	0.000

DV173	JUNCTION	6.997	7.391	157	11:50	76.966
91.985						
DV174	JUNCTION	0.000	7.389	157	11:50	0.000
91.985						
DV176	JUNCTION	0.000	5.015	157	11:50	0.000
0.139						
DV201	JUNCTION	1.093	1.093	157	11:45	18.817
19.192						
DV229	JUNCTION	1.256	2.678	157	11:37	16.971
17.312						
DV230	JUNCTION	0.000	3.386	157	11:37	0.000
17.313						
DV300	JUNCTION	0.000	13.311	157	11:36	0.000
17.314						
DV351	JUNCTION	0.000	0.330	157	12:14	0.000
12.714						
DV352	JUNCTION	0.331	0.331	157	12:10	12.462
12.714						
DV402	JUNCTION	0.000	0.330	157	12:15	0.000
12.714						
DV403	JUNCTION	0.000	0.330	157	12:15	0.000
12.714						
DV405	JUNCTION	0.000	0.330	157	12:15	0.000
12.714						
DV406	JUNCTION	0.000	0.330	157	12:15	0.000
12.713						
DV407	JUNCTION	0.000	0.330	157	12:16	0.000
12.714						
DV408	JUNCTION	0.000	0.330	157	12:16	0.000
12.714						
DV409	JUNCTION	0.000	0.329	157	12:17	0.000
12.713						
DV414	JUNCTION	0.000	0.329	157	12:18	0.000
12.713						
DV416	JUNCTION	0.000	0.329	157	12:17	0.000
12.713						
DV434	JUNCTION	0.000	0.329	157	12:18	0.000
12.713						
DV_DUMMY	JUNCTION	0.000	0.409	329	13:20	0.000
13.491						
DUMMY_OUTFALL	OUTFALL	0.000	6.487	195	03:52	0.000
126.529						
DV100	OUTFALL	0.000	5.014	157	11:50	0.000
0.139						
DV_VAULT	STORAGE	0.000	7.387	157	11:50	0.000
91.985						
REGULATOR_PIT	STORAGE	0.000	3.284	101	02:50	0.000
91.846						
WETWELL	STORAGE	0.000	4.763	157	11:37	0.000
133.556						

\*\*\*\*\*  
Node Surcharge Summary  
\*\*\*\*\*

Surcharging occurs when water rises above the top of the highest conduit.

Node	Type	Hours Surcharged	Max. Height Above Crown Feet	Min. Depth Below Rim Feet
DV101	JUNCTION	30.69	6.184	14.206
DV102	JUNCTION	12.51	4.463	14.987
DV103	JUNCTION	10.60	4.302	12.578
DV201	JUNCTION	27.74	12.750	0.513
DV229	JUNCTION	9.82	40.596	0.000
DV230	JUNCTION	11.67	9.775	9.195
DV300	JUNCTION	12.12	11.162	7.848
REGULATOR_PIT	STORAGE	3.83	1.499	12.321

\*\*\*\*\*  
Node Flooding Summary  
\*\*\*\*\*

No nodes were flooded.

\*\*\*\*\*  
Storage Volume Summary  
\*\*\*\*\*

Time of Max Occurrence	Maximum Outflow Storage Unit	Average Volume 1000 ft3	Avg Pcnt Full	E&I Pcnt Loss	Maximum Volume 1000 ft3	Max Pcnt Full
0 00:00	DV_VAULT	0.000	0.00	0.00	0.000	0
0 00:00	REGULATOR_PIT	0.000	0.00	0.00	0.000	0
0 00:00	WETWELL	0.000	0.00	0.00	0.000	0
0 00:00	6.487					

\*\*\*\*\*  
Outfall Loading Summary  
\*\*\*\*\*

Outfall Node	Flow Freq. Pcnt.	Avg. Flow MGD	Max. Flow MGD	Total Volume 10^6 gal
DUMMY_OUTFALL	98.12	0.367	6.487	126.529
DV100	0.14	0.780	5.014	0.139
System	49.13	1.146	9.960	126.669

\*\*\*\*\*  
 Link Flow Summary  
 \*\*\*\*\*

Time of Max Occurrence Link	Max/ Full Flow	Maximum  Veloc  Type	Maximum Time of Max  Run Flow  Occurrence	Maximum Time of Max Max/ Full Occurrence	Maximum Time of Max Max/ Full Occurrence	Maximum  Output Flow  Top Width
days hr:min		ft/sec	days hr:min	days hr:min	days hr:min	MGD
CDT-13		CONDUIT	0.409	329 13:20		0.399
329 13:15	0.00	4.14	329 13:20	0.01	329 13:20	3.00
DV101-DV_WETWELL		CONDUIT	4.763	157 11:37		4.686
157 11:45	1.98	13.19	157 11:37	0.69	195 03:52	1.00
DV102-DV101		CONDUIT	4.743	157 11:37		4.683
157 11:45	1.85	9.34	157 11:37	1.00	7 12:13	1.00
DV103-DV102		CONDUIT	4.115	157 11:36		3.461
157 11:45	1.40	3.60	157 11:36	1.00	100 21:10	1.50
DV105-DV_CHAM		CONDUIT	7.387	157 11:50		6.023
157 11:45	0.02	4.83	195 03:51	0.20	157 11:50	5.04
DV107-DV_DUMMY		CONDUIT	0.315	157 11:50		0.311
157 11:45	0.01	8.89	157 11:42	0.05	157 11:50	0.84
DV108-DV144		CONDUIT	0.315	157 11:50		0.311
157 11:45	0.01	6.30	157 11:50	0.06	157 11:50	0.95
DV144-DV107		CONDUIT	0.315	157 11:50		0.311
157 11:45	0.01	6.34	157 11:50	0.06	157 11:50	0.98
DV156-DV108		CONDUIT	0.315	157 11:50		0.311
157 11:45	0.03	4.46	157 11:50	0.11	157 11:50	0.87
DV157-DV156		CONDUIT	0.327	157 11:35		0.311
157 11:45	0.04	4.10	157 11:35	0.12	157 11:45	0.99
DV171-DV173		CONDUIT	0.409	329 13:20		0.399
329 13:15	0.00	6.20	209 00:34	0.08	157 11:50	3.36
DV173-DV174		CONDUIT	7.389	157 11:50		6.027
157 11:45	0.07	3.89	157 11:50	0.16	157 11:50	3.94
DV174-DV105		CONDUIT	7.387	157 11:50		6.023
157 11:45	0.02	8.20	157 11:50	0.10	157 11:50	3.42
DV176-DV100		CONDUIT	5.014	157 11:50		3.645
157 11:45	0.02	5.64	157 11:50	0.10	157 11:50	3.28
DV201-DV103		CONDUIT	1.180	157 11:36		1.089
157 11:45	3.01	5.23	157 11:36	1.00	7 11:02	0.67
DV229-DV230		CONDUIT	1.490	157 11:37		1.234
157 11:45	1.52	3.09	157 11:35	1.00	100 21:11	1.00
DV230-DV300		CONDUIT	13.101	157 11:36		1.223
157 11:45	6.93	25.81	157 11:36	1.00	100 21:10	1.00
DV300-DV102		CONDUIT	1.728	157 11:37		1.214
157 11:45	0.97	3.40	157 11:37	1.00	100 21:10	1.00
DV351-DV402		CONDUIT	0.330	157 12:15		0.330
157 12:15	0.10	9.04	157 12:15	0.22	157 12:15	0.56
DV352-DV351		CONDUIT	0.330	157 12:14		0.330
157 12:15	0.42	3.33	157 12:14	0.45	157 12:14	0.63

DV402-DV403	CONDUIT	0.330	157	12:15	0.330
157 12:15 0.02	5.26	157	12:15	0.10	157 12:15 0.89
DV403-DV405	CONDUIT	0.330	157	12:15	0.330
157 12:15 0.02	5.97	157	12:15	0.10	157 12:15 0.91
DV405-DV406	CONDUIT	0.330	157	12:15	0.330
157 12:15 0.03	4.11	157	12:13	0.12	157 12:15 1.01
DV406-DV407	CONDUIT	0.330	157	12:16	0.330
157 12:15 0.05	3.16	157	12:16	0.15	157 12:16 1.04
DV407-DV408	CONDUIT	0.330	157	12:16	0.329
157 12:15 0.04	2.31	157	12:16	0.18	157 12:17 1.16
DV408-DV409	CONDUIT	0.329	157	12:17	0.326
157 12:15 0.01	4.79	157	12:17	0.07	157 12:17 1.27
DV409-DV416	CONDUIT	0.329	157	12:17	0.326
157 12:15 0.01	1.60	157	12:17	0.16	157 12:18 1.46
DV414-DV434	CONDUIT	0.329	157	12:18	0.323
157 12:15 0.01	11.39	157	12:17	0.04	157 12:19 0.79
DV416-DV414	CONDUIT	0.329	157	12:18	0.324
157 12:15 0.01	7.30	157	12:18	0.06	157 12:18 1.47
DV434-DV171	CONDUIT	0.329	157	12:20	0.317
157 12:15 0.00	3.95	157	12:20	0.01	157 12:20 3.00
DV_CHAM-DV103	CONDUIT	3.709	101	02:50	2.943
157 12:00 0.81	8.88	195	03:51	1.00	100 21:18 1.00
DV_CHAM-DV176	CONDUIT	5.015	157	11:50	3.646
157 11:45 0.02	6.43	157	11:50	0.09	157 11:50 5.00
WETWELL-DUMMY_OUTFALL	CONDUIT	6.487	195	03:52	4.901
157 11:45 0.00	27.33	329	10:46	0.05	195 03:52 2.39
IN_VAULT	ORIFICE	3.284	101	02:50	2.943
157 12:00				1.00	100 21:07

\*\*\*\*\*  
Flow Classification Summary  
\*\*\*\*\*

Avg. Froude Number	Avg. Flow Conduit Change	Adjusted /Actual Length	--- Fraction of Time in Flow Class ---						
			Up Dry	Down Dry	Sub Crit	Sup Crit	Up Crit	Down Crit	
2.52	0.0000	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
1.56	0.0000	1.00	0.00	0.00	0.00	0.00	0.98	0.00	0.00
1.34	0.0000	1.00	0.00	0.00	0.00	0.02	0.69	0.00	0.27
0.72	0.0000	1.00	0.00	0.00	0.00	0.01	0.00	0.00	0.97
1.80	0.0000	1.00	0.00	0.00	0.00	0.00	0.01	0.00	0.97
0.96	0.0000	1.00	0.00	0.13	0.00	0.54	0.32	0.00	0.00

DV108-DV144	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.00 0.0000									
DV144-DV107	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.01 0.0000									
DV156-DV108	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
1.45 0.0000									
DV157-DV156	1.00	0.00	0.00	0.00	0.63	0.35	0.00	0.00	0.00
0.89 0.0000									
DV171-DV173	1.00	0.00	0.00	0.00	0.02	0.30	0.00	0.00	0.66
3.78 0.0000									
DV173-DV174	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
0.88 0.0000									
DV174-DV105	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
1.98 0.0000									
DV176-DV100	1.00	0.25	0.00	0.00	0.73	0.00	0.00	0.00	0.00
0.00 0.0000									
DV201-DV103	1.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00	0.00
0.22 0.0000									
DV229-DV230	1.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00	0.00
0.61 0.0000									
DV230-DV300	1.00	0.00	0.00	0.00	0.91	0.07	0.00	0.00	0.00
0.95 0.0000									
DV300-DV102	1.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00	0.00
0.66 0.0000									
DV351-DV402	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
4.33 0.0000									
DV352-DV351	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
1.18 0.0000									
DV402-DV403	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.46 0.0000									
DV403-DV405	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.87 0.0000									
DV405-DV406	1.00	0.00	0.00	0.00	0.00	0.11	0.00	0.00	0.87
2.07 0.0000									
DV406-DV407	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
1.21 0.0000									
DV407-DV408	1.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00	0.00
0.27 0.0000									
DV408-DV409	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.23 0.0000									
DV409-DV416	1.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00	0.00
0.10 0.0000									
DV414-DV434	1.00	0.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00
7.18 0.0000									
DV416-DV414	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
3.90 0.0000									
DV434-DV171	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.98
2.65 0.0000									
DV_CHAM-DV103	1.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.97
2.50 0.0000									
DV_CHAM-DV176	1.00	0.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00
0.00 0.0000									
WETWELL-DUMMY_OUTFALL	1.00	0.00	0.00	0.00	0.00	0.98	0.00	0.00	0.00
12.28 0.0000									

\*\*\*\*\*



Conduit Surcharge Summary  
 \*\*\*\*\*


Capacity Conduit Limited	Hours Full			Hours Above Full	Hours
	Both Ends	Upstream	Dnstream	Normal Flow	
DV101-DV_WETWELL	0.01	0.01	0.01	13.40	0.01
DV102-DV101	25.22	25.22	25.23	10.41	11.57
DV103-DV102	11.70	11.70	11.70	5.70	6.23
DV201-DV103	27.70	27.70	27.72	6.57	6.57
DV229-DV230	9.81	9.81	9.83	0.47	0.46
DV230-DV300	11.67	11.67	11.68	0.01	0.15
DV300-DV102	12.11	12.11	12.12	0.01	0.03
DV_CHAM-DV103	3.83	3.83	3.83	0.01	0.01

Analysis begun on: Thu May 22 08:45:38 2014  
 Analysis ended on: Thu May 22 09:11:52 2014  
 Total elapsed time: 00:26:14

APPENDIX K

---

EXISTING PROCESS FLOW DIAGRAM



**DRAVOSBURG EXISTING WASTEWATER TREATMENT PLANT  
PROCESS FLOW DIAGRAM  
N.T.S.**

Scale: As Shown	Revisions
Date: August 2014	Date
Drawn By: EHD	Revisions
Checked By: BNC	Date
Approved By: SPO	
Order No: 220-53	
Drawing No: EX3	
Sheet No: 1 of 1	

5173 Campbelle Run Road Pittsburgh, PA 15205 Phone: 412.944.0918 Fax: 412.944.0408 info@klh-engineers.com
<b>KLH</b> ENGINEERS, INC.

**BOROUGH OF DRAVOSBURG  
ALLEGHENY COUNTY, PENNSYLVANIA  
EXISTING WASTEWATER TREATMENT PLANT  
PROCESS FLOW DIAGRAM**

APPENDIX L

---

EXISTING SITE PLAN



APPENDIX M

---

EXISTING PROCESS CALCULATIONS

### Dravosburg WWTP Capacity Analysis

Tank Description	Surface Area	Depth Max	Depth @ Q <sub>av</sub>	Vol Max	Vol Avg	
	[FT <sup>2</sup> ]	[FT]	[FT]	[FT <sup>3</sup> ]	[MGAL]	[MGAL]
Aeration Tank No. 1	2,700.00	15.00	15.00	40,500.00	302.94	302.94
Aeration Tank No. 2	2,700.00	15.00	15.00	40,500.00	302.94	302.94
Final Clarifier No. 1	408.00	10.67	9.50	4,353.36	32.56	28.99
Final Clarifier No. 2	408.00	10.67	9.50	4,353.36	32.56	28.99
CL Contact Tank No. 1	116.33	6.75	4.25	785.19	5.87	3.70
CL Contact Tank No. 2	116.32	6.75	4.25	785.16	5.87	3.70
Grit Chamber				700.00	5.24	5.24

\*For capacity analysis, assume depth @ Q<sub>av</sub> in all volume calculations

#### Chlorine Contact Tank Capacity

Design Criteria			
T <sub>D</sub> ≥	30.00	min	[MMAF]
T <sub>D</sub> ≥	15.00	min	[PHF]
Method			
Q =	V / T <sub>D</sub>		
Assumptions			
T <sub>D</sub> ≥	26.888	min	[MMAF]
Analysis			
V <sub>Qav</sub> =	7,395.78	gallons	
Q <sub>av</sub> =	275.06	gpm	
	396,090.30	gpd	
V <sub>Qav</sub> =	7,395.78	gallons	
Q <sub>max</sub> =	493.05	gpm	
	709,995.32	gpd	

#### Final Clarifier Capacity

Design Criteria			
Surface Overflow Rate =	800.00	gpd/ft <sup>2</sup>	[MMAF]
Surface Overflow Rate =	1,200.00	gpd/ft <sup>2</sup>	[PHF]
Weir Loading =	10,000.00	gpd/ft	[MMAF]
Method			
Q =	(SOR) x (A)		
Q =	(WL) x (L)		
Analysis			
A =	816.00	ft <sup>2</sup>	
Q <sub>av</sub> =	652,800.00	gpd	
Q <sub>max</sub> =	979,200.00	gpd	
Total Weir Length =	68.00	ft	
Q <sub>av</sub> =	680,000.00	gpd	

#### Aeration Capacity

Design Criteria			
T <sub>D</sub> ≥	6.00	hr	[MMAF]
Method			
Q =	V / T <sub>D</sub>		
Analysis			
V <sub>Qav</sub> =	605,880.00	gallons	
Q <sub>av</sub> =	100,980.00	gpm	
	2.42	mgd	

#### Grit Chamber Capacity


Design Criteria			
T <sub>D</sub> ≥	3.00	min	[MMAF]
Method			
Q =	V / T <sub>D</sub>		
Analysis			
V <sub>Qav</sub> =	5,236.00	gallons	
Q <sub>av</sub> =	1,745.33	gpm	
	2.51	mgd	

APPENDIX N

---

ALTERNATIVE 1  
PROCESS FLOW DIAGRAM






FROM SYSTEM

WET WEATHER OVERFLOW  
FLOW > 5.24 MGD

FLOW < 5.24 MGD

**DRAVOSBURG WASTEWATER TREATMENT PLANT UPGRADE**  
**PROCESS FLOW DIAGRAM**  
N.T.S.



Scale:	As Shown
Date:	August 2014
Drawn By:	EHO
Checked By:	BMC
Approved By:	SHG
Order No.:	240-53
Drawing No.:	EXS
Sheet No.:	1 of 1

**BOROUGH OF DRAVOSBURG**  
**ALLEGHENY COUNTY, PENNSYLVANIA**  
**WASTEWATER TREATMENT PLANT UPGRADE**  
**PROCESS FLOW DIAGRAM**




6173 Campbells Run Road  
Pittsburgh, PA 15205  
Phone: 412.494.0510  
Fax: 412.494.0428  
Info@klhengineers.com

Date	Revisions	Date	Revisions


APPENDIX O

---

ALTERNATIVE 1  
SITE PLAN




**ALTERNATIVE 1  
SITE PLAN EX2-A**



Date	Revisions	Date	Revisions

8173 Campbell Run Road  
Pittsburgh, PA 15205  
Phone: 412.484.0810  
Fax: 412.484.0458  
info@klhinc.com



**BOROUGH OF DRAVOBSBURG  
ALLEGHENY COUNTY, PENNSYLVANIA  
LONG TERM CONTROL PLAN  
ALTERNATIVE 1 SITE PLAN**

Scale: As Shown  
Date: July 2014  
Drawn By: EHD  
Checked By: BNC  
Approved By: SHG

Order No.  
**220-53**  
Drawing No.  
**EX2**  
Sheet No.  
**1 of 1**

Plotter: D:\DWG\2014\07\20140720\220-53-EX2-A.dwg Plot Date: 7/20/2014 10:00:00 AM Plotter: HP DesignJet T1100e

APPENDIX P

---

ALTERNATIVE 1  
PROCESS CALCULATIONS



**SANITAIRE ICEAS Detailed Design Calculations**  
**BOD Removal, Nitrification, and De-Nitrification Process**

**SANITAIRE Project #24970-14a**  
**Dravosburg, PA**

**Design Parameters**

**A. Flow**

Average Daily Flow                      600,000 GPD  
 Peak Dry Weather Flow                  1,100,000 GPD  
 Peak Wet Weather Flow                  2,200,000 GPD

**B. Treatment**

	Influent Quality	Effluent Requirement
BOD <sub>5</sub> (20°C), mg/l	190	10
Suspended Solids, mg/l	210	10
TKN, mg/l	40	
NH <sub>3</sub> -N, mg/l		1
TN, mg/l		
Phosphorus	7	1

**C. Environment**

Alkalinity (Minimum Requirement)    180 mg/l  
 Max Wastewater Temperature        20 °C  
 Min Wastewater Temperature        10 °C  
 Ambient Air Temperature            20 - 90 °F  
 Site Elevation                            740 ft

**D. ICEAS Process Design Criteria**

F / M                                        0.042 BOD<sub>5</sub> / MLSS / day  
 SVI (after 30 minutes settling)      150 ml/g  
 Number of ICEAS Basins                2  
 Top Water Level                          16.25 ft

**E. Cycle Timing**

		Normal	Storm
Air-On	min	96	48
Air-Off	min	72	24
Settle	min	48	36
Decant	min	72	36
Total	hrs	4.8	2.4

## F. Detailed Calculations

### Mass of Biomass

$$\text{BODL} = \frac{Q \times \text{BODin} \times 8.34}{1,000,000} = \frac{300,000 \times 190 \times 8.34}{1,000,000} = 475 \text{ lb/day/basin}$$

where: BODL = BOD Load (lb/day/basin)

Q = Average Dry Weather Flow per basin (gal/day)

BODin = Influent BOD concentration (mg/l)

1,000,000 = Conversion (l/mg)

8.34 = Conversion (lb/gal)

### Mass of Biomass

$$\text{MBOD} = \frac{\text{BOD}_L}{F/M} = \frac{475}{0.042} = 11,346 \text{ lb/basin}$$

where: MBOD = Mass of Biomass for BOD Removal (lb/day/basin)

F / M = Food to Microorganism ratio (day<sup>-1</sup>)

### Volume of Biomass

$$\text{Vbio} = \text{MBOD} \times \text{SVI} = 11,346 \times 2.4 = 27,231 \text{ ft}^3/\text{basin}$$

where: Vbio = Volume of Biomass (ft<sup>3</sup>/basin)

SVI = Sludge Volume Index (ft<sup>3</sup>/lb)



Maximum Volume Above Bottom Water Level

Peak Dry Weather Flow:

$$V_{bwld} = \frac{PDWF \times (NCT - NDT)}{24 \times 7.48} = \frac{550,000 \times (4.8 - 1.20)}{24 \times 7.48} = 11,029 \text{ ft}^3/\text{basin}$$

- where:  $V_{bwld}$  = Maximum Volume Above BWL at Peak Dry Weather Flow ( $\text{ft}^3/\text{basin}$ )
- PDWF = Peak Dry Weather Flow (gal/day)
- NCT = Normal Cycle Time (hr/cycle)
- NDT = Decant Time (hr/cycle)
- 7.48 = Conversion (gal/ $\text{ft}^3$ )
- 24 = Conversion (hours/day)

Peak Wet Weather Flow:

$$V_{bwls} = \frac{PWWF \times (SCT - SDT)}{24 \times 7.48} = \frac{1,100,000 \times (2.4 - 0.60)}{24 \times 7.48} = 11,029 \text{ ft}^3/\text{basin}$$

- where:  $V_{bwls}$  = Maximum Volume Above BWL at Peak Wet Weather (Storm) Flow ( $\text{ft}^3/\text{basin}$ )
- PWWF = Peak Wet Weather Flow (gal/day)
- SCT = Storm Cycle Time (hr/cycle)
- SDT = Storm Decant Time (hr/cycle)

MVAB (Maximum Volume Above Bottom Water Level) is larger of Peak Dry Weather and Peak Wet Weather Calculation

$$MVAB = 11,029 \text{ ft}^3/\text{basin}$$

Decant Rates

Peak Dry Weather Flow:

$$PDR = \frac{MVAB \times 7.48}{NDT} + \frac{PDWF}{1,440} = \frac{11,029 \times 7.48}{72.0} + \frac{550,000}{1,440} = 1,528 \text{ gal/min}$$

- where: PDR = Normal Decant Rate (gal/min)
- NDT = Normal Decant Time (min/cycle)
- 1440 = Conversion (min/day)

Peak Wet Weather Flow:

$$PWR = \frac{MVAB \times 7.48}{SDT} + \frac{PWWF}{1,440} = \frac{11,029 \times 7.48}{36.0} + \frac{1,100,000}{1,440} = 3,056 \text{ gal/min}$$

- where: PWR = Peak Decant Rate (gal/min)
- SDT = Storm Decant Time (min/cycle)

## Decanter Sizing

Peak Dry Weather Flow:

$$DL_a = \frac{PDR}{\text{Weir Loading Rate} \times 7.48} = \frac{1,528}{20 \times 7.48} = 10.21 \text{ ft}$$

where: DL<sub>a</sub> = Decanter Length for Average Dry Weather Flow (ft)  
 20 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

Peak Wet Weather Flow:

$$DL_p = \frac{PWR}{\text{Weir Loading Rate} \times 7.48} = \frac{3,056}{25 \times 7.48} = 16.34 \text{ ft}$$

where: DL<sub>p</sub> = Decanter Length for Peak Wet Weather (Storm) Flow (ft)  
 25 = Weir Loading Rate (ft<sup>3</sup>/min/ft of decanter weir)

$$\text{Design Decanter Length} = 17.5 \text{ ft}$$

## Basin Working Volume

$$BWV = MVAB + V_{bio} + V_c = 11,029 + 27,231 + 66 = 38,326 \text{ ft}^3/\text{basin}$$

where: BWV = Basin Working Volume (ft<sup>3</sup>/basin)  
 V<sub>c</sub> = Volume of chemical sludge due to Phosphorus removal (ft<sup>3</sup>/basin)  
 (Please refer to phosphorus removal calculation.)

## Basin Area

$$BA = \frac{BWV}{TWL - BZ} = \frac{38,326}{16.3 - 3.0} = 2,893 \text{ ft}^2/\text{basin}$$

where: BA = Basin Area (ft<sup>2</sup>)  
 TWL = Top Water Level (ft)  
 BZ = Buffer Zone (ft) (Safety Factor)

## Sludge Depth

$$SD = \frac{V_{bio}}{BA} = \frac{27,231}{2,893} = 9.41 \text{ ft}$$

where: SD = Sludge Depth (ft)





Decanter Draw Down

$$DD = \frac{MVAB}{BA} = \frac{11,029}{2,893} = 3.81 \text{ ft}$$

where: DD = Draw Down (ft)

Bottom Water Level

$$BWL = SD + BZ + Vd = 9.41 + 3.00 + 0.02 = 12.44 \text{ ft}$$

where: BWL = Bottom Water Level (ft)  
Vd = Depth of Chemical Sludge for Phosporus precipitation (ft)

Top Water Level

$$TWL = BWL + DD = 12.44 + 3.81 = 16.25 \text{ ft}$$

where: TWL = Top Water Level (ft)

Hydraulic Retention Time

$$HRT = \frac{BA \times MAFD \times 7.48}{QT}$$

where: HRT = Hydraulic Retention Time (days)  
MAFD = Maximum Average Flow Depth (ft)  
QT = Fill Rate at Average Dry Weather Flow (gal/day)

$$MAFD = \frac{Q \times [(NCT \times 60) - NDT]}{BA \times 1,440 \times 7.48} + BWL = \frac{300,000 \times [(4.8 \times 60) - 72.0]}{2,893 \times 1,440 \times 7.48} + 12.44 = 14.52 \text{ ft}$$

$$HRT = \frac{2,893 \times 14.52 \times 7.48}{300,000} = 1.05 \text{ days}$$



### MLSS Concentration at Bottom Water Level

$$MLSS = \frac{M_{bio} \times 1,000,000}{BWL \times (BA - CA) \times 62.42} = \frac{11,346 \times 1,000,000}{12.44 \times (2,893 - 4.04) \times 62.42} = 5,062 \text{ mg/l}$$

where: MLSS = Mixed Liquor Suspended Solids concentration at Bottom Water Level (mg/l)

62.42/1E+06 = Conversion (lb/mg x l/ft<sup>3</sup>)

CA = Area Increment due to chemical sludge (ft<sup>2</sup>/basin)

### Mass of Sludge Produced

$$\Delta M = \left( \frac{Y \times (BOD_{in} - BOD_{out})}{1 + (B \times \theta^{(T-20)} \times SRT)} + Z_{io} + Z_{no} \right) \times \frac{Q \times 8.34}{1,000,000}$$

$$\Delta M = \left( \frac{0.6 \times (190 - 10.0)}{1 + (0.07 \times 1.04^{(10-20)} \times 28.1)} + 84.0 + 21.0 \right) \times \frac{3.0E+05 \times 8.34}{1,000,000} = 379 \text{ lb/day/basin}$$

(Lawrence-McCarty Equation as presented in WEF MOP/8 4th Edition, pg 11-11, Eqn. 11.7)

where:  $\Delta M$  = Mass of Sludge Produced (lb/day/basin)

Y = Volatile cell yield (VSS/BOD removed)

q = Arrhenius Temperature Correction Factor

B = Decay Rate (day<sup>-1</sup>)

BOD<sub>out</sub> = Anticipated Effluent BOD (mg/l)

SRT = Solids Retention Time (days)

Z<sub>io</sub> = Influent nonvolatile suspended solids (mg/l)

Z<sub>no</sub> = Influent volatile nonbiodegradable solids (mg/l)

T = Minimum Wastewater Temperature (°C)



**Volume of Sludge Produced**

$$V_{ws} = \frac{\Delta M + C_{sludge}}{SF_{ws} \times 8.34} = \frac{379 + 27}{0.0085 \times 8.34} = 5,727 \text{ gal/day/basin}$$

where:  $V_{ws}$  = Volume of Waste Sludge (gal/day/basin)  
 $SF_{ws}$  = Solids Fraction in Waste Sludge  
 8.34 = Density (lb/gal)  
 $C_{sludge}$  = Mass of chemical sludge produced (lb/day/basin)  
 (Please refer to phosphorus removal calculation)

**Observed Yield Factor**

$$Y_{obs} = \frac{\Delta M}{BOD_L} = \frac{379}{475} = 0.80 \frac{MLSS}{BOD}$$

Observed Yield Factor (lb/day MLSS/lb/day BODremoved)

**Mean Cell Residence Time**

$$MCRT = \frac{M_{bio}}{\Delta M + \{(Q - V_{ws}) \times SS_{out} \times 8.34 / 1E+06\}}$$

$$MCRT = \frac{11,346}{379 + \{(300,000 - 5,727) \times 10.0 \times 8.34 / 1,000,000\}} = 28.1 \text{ days}$$

where:  $MCRT$  = Mean Cell Residence Time (days)  
 $SS_{out}$  = Anticipated Effluent Total Suspended Solids (mg/l)  
 $8.34E-06$  = Conversion (lb/mg x l/gal)



Sludge Age for Nitrification

Refer to Metcalf and Eddy, Edition IV pages 614 and 705

Constants and Temperature Corrections:

Coefficient	Base Value	Theta	Temperature Corrected	Symbol
Maximum Specific Growth Rate of Nitrifying bacteria, g VSS/g VSS.day	0.75	1.07	0.381	$\mu_{nm}(T)$
Half-Velocity constant for nitrifiers	0.74	1.053	0.442	$K_n(T)$
Nitrifier decay rate	0.08	1.04	0.054	$K_{dn}(T)$
Dissolved Oxygen, mg/l	2		2	DO
Half-Velocity Constant for Dissolved Oxygen, mg/l	0.5		0.5	$K_o$
Minimum Water Temperature, °C	10		10	T
Safety Factor	1.5		1.5	SF

Calculations:

$$\mu_n = \left( \mu_{nm}(T) \times \frac{TENH_3}{TENH_3 + K_n(T)} \times \frac{DO}{DO + K_o} \right) - K_{dn}(T)$$

$$\mu_n = \left( 0.381 \times \frac{1.0}{1.0 + 0.442} \times \frac{2.0}{2.0 + 0.5} \right) - 0.054 = 0.158 \text{ days}^{-1}$$

$$SRT_{min} = \frac{1}{\mu_n} = \frac{1}{0.158} = 6.3 \text{ days}$$

$$SRT_{aerobic} = SRT_{min} \times SF = 6.3 \times 1.5 = 9.5 \text{ days}$$

$$SRT_{overall} = \frac{SRT_{aerobic} \times 24}{TA} = \frac{9.5 \times 24}{8.0} = 28.6 \text{ days}$$

Design sludge age not adequate for nitrification.

where:  $\mu_{nm}(T)$  = Maximum Temperature Corrected Nitrifier Growth Rate ( $\text{days}^{-1}$ )

$\mu_n$  = Specific Nitrifier Growth Rate at Temperature, DO, and Effluent  $NH_3$  (g/g-days)

SRT<sub>min</sub> = Minimum Sludge age required for Nitrification (days)

SRT<sub>aerobic</sub> = Design Aerobic Sludge Age (days)

SF = Safety Factor

SRT<sub>overall</sub> = Sludge Age accounting for entire ICEAS cycle (days)

TA = Aeration Time (hrs/day)

TENH<sub>3</sub> = Anticipated Effluent Ammonia (mg/l)

CONFIDENTIAL





Waste Sludge Pump Capacity

$$WSP = \frac{Vws \times NCT}{24 \times SPT} = \frac{5,727 \times 4.8}{24 \times 10.41} = 110 \text{ gal/min}$$

where: WSP = Waste Sludge Pump Capacity(gal/min)  
 SPT = Sludge Pumping Time (min/cycle)

Biological Phosphorus Removal

$$TPb = TPI - [Yobs \times (BODin - BODout)] \times TPps = 7.0 - [0.80 \times (190 - 10.0) \times 0.03] = 2.70 \text{ mg/l}$$

where: TPb = Concentration of the Total Phosphorus in the Effluent after biological removal (mg/l)  
 TPI = Concentration of the Total Phosphorus in the Influent (mg/l)  
 TPps = Percent of Total Phosphorus in Biomass

Chemical Dosing

$$CD = CDt \times (TPb - TPe) \times (1 + SF)$$

where: CDt= Theoretical Weight Ratio Chemical Dosage  
 SF= Safety Factor for Chemical Dosing (%)  
 TPe = Required Phosphorus concentration in effluent (mg/l)

Alum Dosage Based on percentage removal (PR) of Phosphorus:  
 Refer to ASCE Design of Municipal Wastewater Treatment Plants (4th Edition) pg 16-67

PR	CDt
PR < 85	13
85 ≤ PR ≤ 95	16
PR > 95	22

$$PR = \frac{TPb - TPe}{TPb} \times 100 = \frac{2.70 - 1.0}{2.70} \times 100 = 63\%$$

CDt= 13

$$CD = 13 \times (2.70 - 1.0) \times (1 + 25\%) = 27.6 \text{ mg/l}$$

...Rounded to the next 5 mg/l

$$CD = 30 \text{ mg/l}$$

## Mass of Chemical Sludge

$$C_{\text{sludge}} = \frac{Q \times CD \times 0.091 \times 4 \times 8.34}{1,000,000} = \frac{300,000 \times 30 \times 0.091 \times 4 \times 8.34}{1,000,000} = 27 \text{ lb/day/basin}$$

where: 0.091 = Fraction of Alum reacting with Phosphorus  
4 = Mass of Precipitate formed per Mass of Alum

## Volume of Chemical Sludge

$$V_{\text{cs}} = C_{\text{sludge}} \times SVI = 27 \times 2.4 = 66 \text{ ft}^3/\text{basin}$$

where:  $V_{\text{cs}}$  = Volume of Chemical Sludge ( $\text{ft}^3/\text{basin}$ )

**SANITAIRE ICEAS Aeration Design Calculations**  
**BOD Removal, Nitrification, and De-Nitrification Process**

**SANITAIRE Project #24970-14a**  
**Dravosburg, PA**

**Carbonaceous Oxygen Demand**

$$AOR1 = A \times \frac{Q \times BOD_{in}}{1,000,000} \times 8.34 = 1.20 \times \frac{300,000 \times 190}{1,000,000} \times 8.34 = 570 \text{ lb/day/basin}$$

- where AOR1 = Actual Oxygen Required for BOD oxidation (lb/day/basin)
- A = O<sub>2</sub> / BOD
- Q = Average flow (gal/day/basin)
- BOD<sub>in</sub> = Influent BOD received (mg/l)
- 1,000,000 = Conversion (g x mg)
- 8.34 = Conversion (lb x gal)

$$A = 1.20 \text{ O}_2/\text{BOD}$$

**Nitrification Oxygen Demand**

$$AOR2 = \Delta N \times 4.60 = 72.5 \times 4.60 = 333 \text{ lb/day/basin}$$

where AOR2 = Actual Oxygen required for Ammonia Oxidation (lb/day/basin)

$$\Delta N = \frac{[(NH3_{in} - NH3_{out}) - (BOD_{in} - BOD_{out}) \times Y_{obs} \times N_s] \times Q \times 8.34}{1,000,000}$$

$$\Delta N = \frac{[(40.0 - 1.0) - (190.0 - 10.0) \times 0.80 \times 0.07] \times 300,000 \times 8.34}{1,000,000} = 72.5 \text{ lb/day/basin}$$

- where AOR2 = Actual Oxygen required for Ammonia Oxidation (lb/day/basin)
- TKN<sub>in</sub> = Influent TKN concentration (mg/l)
- 4.6 = Mass of O<sub>2</sub> per Mass of Ammonia Oxidized
- NLOAD = Mass of TKN applied lb/day/basin
- NH<sub>3</sub><sub>out</sub> = Effluent ammonia required (mg/l)
- N<sub>s</sub> = Sludge Nitrogen content (N / sludge)
- BOD<sub>out</sub> = Effluent BOD (mg/l)





**Total Actual Oxygen Transfer**

$$AOR = AOR1 + AOR2 = 570 + 333 = 904 \text{ lb/day/basin}$$

where AOR = Total Actual Oxygen Required (lb/day/day/basin)

**Total Standard Oxygen Transfer**

$$SOR = \frac{AOR}{AOR / SOR} = \frac{904}{0.4766} = 1,897 \text{ lb/day/basin}$$

$$\frac{AOR}{SOR} = \frac{\alpha \times \theta^{(T_{site} - 20)} \times (\beta \times C^*_{sat_{20}} \times P_{site} / P_{std} \times C_{surf_T} / C_{surf_{20}} - D.O.)}{C^*_{sat_{20}}}$$

$$\frac{AOR}{SOR} = \frac{0.65 \times 1.024^{(20 - 20)} \times (0.95 \times 10.31 \times 14.34 / 14.70 \times 9.07 / 9.07 - 2.0)}{10.31} = 0.4766$$

- where SOR = Standard Condition Oxygen Requirement (lb/day/day/basin)
- α = Alpha factor
- θ = Temperature coefficient
- T<sub>site</sub> = Water temperature (°C)
- β = Beta factor
- P<sub>site</sub> = Site Atmospheric Pressure
- P<sub>std</sub> = Standard atmospheric pressure (psig)
- C<sup>\*</sup><sub>sat<sub>20</sub></sub> = Dissolved oxygen solubility at standard conditions (mg/l)
- C<sub>surf<sub>T</sub></sub> = Dissolved oxygen solubility at site water temperature (mg/l)
- C<sub>surf<sub>20</sub></sub> = Dissolved oxygen solubility at 20°C (mg/l)
- D.O. = Residual dissolved oxygen concentration (mg/l)

**Aeration System Standard Oxygen Transfer Rate**

$$SOTR = \frac{SOR}{TA} = \frac{1,897}{8} = 237 \text{ lb/hr}$$

where SOTR = Standard oxygen transfer rate (lb/day/hr)  
 TA = Aeration Time, hrs/day

Aeration Depth

Average Aeration Depth

$$MAD_{ad} = \frac{Q \times [(NCT \times 60) - (NDT + NST)]}{2 \times 1,440 \times 7.48 \times BA} + BWL$$

$$MAD_{ad} = \frac{300,000 \times [(4.8 \times 60) - (72 + 48)]}{2 \times 1,440 \times 7.48 \times 2,890} + 12.44 = 13.25 \text{ ft}$$

where AADad = Average Aeration Depth at Average Dry Weather Flow (gpd)

Q = Average Dry Weather Flow (gpd/basin)

NCT = Normal Cycle Time (hr)

NDT = Normal Decant Time (min)

NST = Normal Settling Time (min)

BA = Basin Area (ft<sup>2</sup>)

1440 = Conversion (min/day)

7.48 = Conversion (gal/ft<sup>3</sup>)

2 = Calculate Aeration Depth at Middle of Normal Reaction Phase (NCT - NST - NDT)

Maximum Aeration Depth

$$MAD_{pw} = \frac{PWWF \times [(SCT \times 60) - (SDT + SST)]}{1,440 \times 7.48 \times BA} + BWL$$

$$MAD_{pw} = \frac{1,100,000 \times [(2.4 \times 60) - (36 + 36)]}{1,440 \times 7.48 \times 2,890} + 12.44 = 14.98 \text{ ft}$$

where MADpw = Maximum Aerartion Depth at Peak Wet Weather Flow (gpd)

PWWF = Peak Wet Weather Flow (gpd/basin)

SCT = Storm Cycle Time (hr)

SDT = Storm Decant Time (min)

SST = Storm Settle time (min)

MAD = Maximum Aeration Depth (ft)

MAD is larger of MADad and MADpw

$$MAD = 15.40 \text{ ft}$$

Air Flow Requirement

$$\text{Process Air} = \frac{SOTR \times 10,000}{\rho \times SOTE \times O_{pw} \times 60} = \frac{237 \times 10,000}{0.075 \times 26.05 \times 23.2 \times 60} = 872 \text{ scfm}$$

where Process Air = Process air flow requirement (scfm)



$\rho$  = Air density (0.075 lb/day/ft<sup>3</sup>)  
 SOTE = Standard Oxygen Transfer Efficiency @ Submergence of 12.25 ft  
 Opw = Fraction of Oxygen in air by Weight  
 10,000 = Conversion (100% \* 100%)  
 60 = Conversion (min/hr)

$$\text{Mixing Air} = \text{MI} \times \text{BA} = 0.13 \times 2,890 = 362 \text{ scfm}$$

where      Mixing Air = Mixing air flow requirement (scfm)  
               MI = recommended air flow per unit area of basin (scfm/ft<sup>2</sup>)

**Blower Unit Capacity**

Blower unit capacity (BUC) is the larger of the process air requirement and the mixing air requirement.

Process Air              872 scfm

Mixing Air                362 scfm

Use 1 blower per tank

$$\text{BUC} = 880 \text{ scfm}$$

**Blower Pressure**

$$\text{psig} = \text{MAD} \times 0.432 + H_L = 14.98 \times 0.432 + 1.00 = 7.7 \text{ psig}$$

where      psig = blower pressure (rounded to next psig)  
               0.432 = water density (psi/ft)  
               H<sub>L</sub> = Cumulative piping and diffuser headloss (psig)

**Average Blower Power**


Blower power based on vendor curves, BUC, and Average Aeration Depth (12.25 ft)


$$\text{Power}_{\text{avg}} = 40.0 \text{ bhp}$$

APPENDIX Q

---

ALTERNATIVE 2  
PROCESS FLOW DIAGRAM



Scale: As Shown Date: August 2014 Drawn By: BHD Checked By: BNC Approved By: SHG	Order No. <b>220-53</b> Drawing No. <b>EX4</b> Sheet No. <b>1 of 1</b>	<b>BOROUGH OF DRAVOSBURG</b> <b>ALLEGHENY COUNTY, PENNSYLVANIA</b> <b>WASTEWATER TREATMENT PLANT CONVERSION</b> <b>TO PUMP STATION</b> <b>PROCESS FLOW DIAGRAM</b>	 6173 Campbell Run Road Pittsburgh, PA 15205 Phone: 412.464.0810 Fax: 412.464.0810 info@klhengineers.com												
			<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Date</th> <th style="width: 10%;">Revisions</th> <th style="width: 10%;">Date</th> <th style="width: 10%;">Revisions</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	Date	Revisions	Date	Revisions								
Date	Revisions	Date	Revisions												

APPENDIX R


---

ALTERNATIVE 2  
SITE PLAN



Scale:	As Shown
Date:	July 2014
Drawn By:	EHD
Checked By:	BMC
Approved By:	SHG
Order No.:	220-53
Drawing No.:	EX1
Sheet No.:	1 of 1

**BOROUGH OF DRAVOBSBURG  
ALLEGHENY COUNTY, PENNSYLVANIA  
LONG TERM CONTROL PLAN  
ALTERNATIVE 2 SITE PLAN**



5175 Conestoga Run Road  
Pittsburgh, PA 15205  
Phone: 412-464-0810  
Fax: 412-464-0428  
info@klhengineers.com

Date	Revisions	Date	Revisions


Information on this drawing was prepared by the Borough of Dravosburg. The Borough of Dravosburg is not responsible for the accuracy of the information provided on this drawing.

APPENDIX S

---

ALTERNATIVE 2  
FORCE MAIN ALIGNMENT





Scale: NTS	Date: May 2014	Drawn By: VLB	Checked By: BMC	Approved By: SHG
Order No. 220-53	Drawing No. FM-EX2	Sheet No. 1 of 1		
<b>MUNICIPAL AUTHORITY OF THE CITY OF MCKEESPORT</b> <b>ALLEGHENY COUNTY, PENNSYLVANIA</b> <b>DRAVOSBURG-OUQUESNE AREA ACT 537 &amp; LONG TERM CONTROL PLAN</b> <b>FORCE MAIN EXHIBIT</b>				
			5175 Cramohills Blvd. Road Cranberry, PA 15006 Phone: 412.484.0850 Fax: 412.484.0426 info@klhengineers.com	
Date	Revisions	Date	Revisions	Revisions

APPENDIX T

---

PROJECT COST ESTIMATES

**Dravosburg WWTP Long Term Control Plan**  
**Alternative 1 - Upgrade WWTP**  
**Planning Cost Estimate**

ITEM	COST
General Site Work	\$ 138,000
Headworks Building	\$ 863,000
SBR Tank Conversion	\$ 864,000
Influent Pump Station	\$ 1,199,000
Grit Removal	\$ 504,000
Sludge Holding Facilities	\$ 130,000
Ultraviolet Disinfection	\$ 477,000
<b>SUBTOTAL CONSTRUCTION COST</b>	<b>\$ 4,175,000</b>
Electrical Costs (25%)	\$ 1,044,000
Mobilization/Demobilization/Bonds/Insurance (15%)	\$ 627,000
Contingency (30%)	\$ 1,253,000
<b>TOTAL CONSTRUCTION COST</b>	<b>\$ 7,099,000</b>
Engineering, Permitting, Legal (15%)	\$ 1,065,000
Construction Administration (10%)	\$ 710,000
<b>TOTAL PROJECT COST</b>	<b>\$ 8,874,000</b>

**Site Work**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		E&S Controls	1	lot	\$ 10,000.00	\$ 10,000.00	\$ 10,000.00
		By-Pass Pumping	1	lot	\$ 50,000.00	\$ 50,000.00	\$ 50,000.00
		Site Paving	385	s.y.	\$ 50.00	\$ 19,259.26	\$ 19,259.26
		Lawn Restoration	1	lot	\$ 5,000.00	\$ 5,000.00	\$ 5,000.00
Division 3	Concrete						
		Repairs/Rehabilitation	1	lot	\$ 10,000.00	\$ 10,000.00	\$ 10,000.00
		Manholes (0'-8' Deep)	3	ea	\$2,500.00	\$ 7,500.00	\$ 7,500.00
		Manhole VF over 8' Deep	25	v.f.	\$110.00	\$ 2,750.00	\$ 2,750.00
						\$ -	
Division 15	Mechanical						
		8" D.I. Pipe (Buried) - F.M.	250	L.F.	\$ 50.00	\$ 12,500.00	\$ 12,500.00
		18" D.I. Pipe (Buried) - F.M.	100	L.F.	\$ 200.00	\$ 20,000.00	\$ 20,000.00
<b>Subtotal Construction = \$ 137,009.26</b>							

Headworks							
			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Excavation	972.2	c.y.	\$ 50.00	\$ 48,611.11	\$ 48,611.11
		Backfill	243.1	c.y.	\$ 50.00	\$ 12,152.78	\$ 12,152.78
		Stone Backfill	28.11	c.y.	\$ 172.00	\$ 4,834.92	\$ 4,834.92
		Excavation/Shoring/Dewatering/Backfill	1	LOT	\$ 50,000.00	\$ 50,000.00	\$ 50,000.00
Division 3	Concrete						
		Foundation Slab	84.33	c.y.	\$ 532.10	\$ 44,871.99	\$ 44,871.99
		First Floor Slab	56.22	c.y.	\$ 1,123.40	\$ 63,157.55	\$ 63,157.55
		Walls	85.92	c.y.	\$ 1,123.40	\$ 96,522.53	\$ 96,522.53
Division 4	Masonry						
		Block	1200	s.f.	\$ 8.35	\$ 10,020.00	\$ 14,923.83
Division 5	Metals						
		Aluminum Grating	150	s.f.	\$ 65.00	\$ 9,750.00	\$ 9,750.00
		Aluminum Handrail	200	L.F.	\$ 70.00	\$ 14,000.00	\$ 14,000.00
		4'x4' Aluminum Hatchway	1	each	\$ 3,500.00	\$ 3,500.00	\$ 5,212.91
		Stairs	82	riser	\$ 185.00	\$ 15,170.00	\$ 22,594.26
Division 7	Thermal and Moisture						
		Masonry Insulation	1200	s.f.	\$ 1.31	\$ 1,572.00	\$ 2,341.34
		Roofing	1	Lot	\$ 25,000.00	\$ 25,000.00	\$ 37,235.10
		Alum Fascia	100	s.f.	\$ 5.35	\$ 535.00	\$ 796.83
		Alum Soffit	404	s.f.	\$ 7.65	\$ 3,090.60	\$ 4,603.15
		Alum Gutters	100	L.F.	\$ 5.00	\$ 500.00	\$ 744.70
		Downspouts	48	L.F.	\$ 4.84	\$ 232.32	\$ 346.02
Division 8	Doors and Windows						
		7'x3' Mandoor w/window	1	each	\$ 1,000.00	\$ 1,000.00	\$ 1,489.40
		7'x6' Door	1	each	\$ 2,500.00	\$ 2,500.00	\$ 3,723.51
		10'x14' Rolling Garage	1	each	\$ 7,000.00	\$ 7,000.00	\$ 10,425.83
		3'x3' window	2	each	\$ 500.00	\$ 1,000.00	\$ 1,489.40
		4'x4' skylight	2	each	\$ 200.00	\$ 400.00	\$ 595.76
Division 9	Coatings						
		Paints	10000	s.f.	\$ 2.00	\$ 20,000.00	\$ 29,788.08
Division 11	Equipment						
		Coarse Screen (Mechanical)	1	each	\$ 234,000.00	\$ 234,000.00	\$ 304,200.00
		Coarse Screen (Manual)	1	each	\$ 7,500.00	\$ 7,500.00	\$ 7,500.00
Division 15	Mechanical						
		Sluice Gates	4	each	\$ 3,500.00	\$ 14,000.00	\$ 20,851.66
		HVAC	1	Lot	\$ 50,000.00	\$ 50,000.00	\$ 50,000.00
<b>Subtotal Construction = \$</b>							<b>862,762.69</b>

**SBR Tanks**

			Qty	Unit	Price per Unit	Materials	Total
Division 3	Concrete						
		Walls	68.15	c.y.	\$1,123.40	\$ 76,557.63	\$ 76,557.63
Division 11	Equipment						
		SBR Equipment	1	each	\$ 510,000.00	\$ 510,000.00	\$ 663,000.00
		SCADA and SIMS	1	each	\$ 80,000.00	\$ 80,000.00	\$ 104,000.00
Division 15	Mechanical						
		WAS Sludge Piping	200	LF	\$ 100.00	\$ 20,000.00	\$ 20,000.00
<b>Subtotal Construction = \$</b>						<b>863,557.63</b>	

### Influent Pump Station and Valve Vault

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Excavation	513	c.y.	\$ 50.00	\$ 25,648.15	\$ 25,648.15
		Backfill	128	c.y.	\$ 50.00	\$ 6,412.04	\$ 6,412.04
		Stone Backfill	21	c.y.	\$ 172.00	\$ 3,612.00	\$ 3,612.00
		Excavation/Shoring/Dewatering/Backfill	1	LOT	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
		Anchoring					
Division 3	Concrete						
		Foundation Slab	62	c.y.	\$ 532.10	\$ 32,990.20	\$ 32,990.20
		Elevated Slabs and Walls	191	c.y.	\$ 1,123.40	\$ 214,569.40	\$ 214,569.40
Division 5	Metals						
		6'x6' Aluminum Hatchway	2	each	\$ 5,000.00	\$ 10,000.00	\$ 10,000.00
Division 11	Equipment						
		Influent Pumps	3	each	\$ 100,000.00	\$ 300,000.00	\$ 300,000.00
		MCC	1	each	\$ 300,000.00	\$ 300,000.00	\$ 300,000.00
		PLC and Controls	1	each	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
		Bridge Crane	1	each	\$ 25,000.00	\$ 25,000.00	\$ 25,000.00
Division 15	Mechanical						
		Wet Well and Valve Vault Piping	1	LOT	\$ 80,000.00	\$ 80,000.00	\$ 80,000.00

Subtotal Construction = \$ 1,198,231.79

**Grit Removal**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Excavation	188.15	c.y.	\$ 49.00	\$ 9,219.26	\$ 9,219.26
		Backfill	47.037	c.y.	\$ 49.00	\$ 2,304.81	\$ 2,304.81
		Stone Backfill	80.22	c.y.	\$ 172.00	\$ 13,797.84	\$ 13,797.84
		Fill Existing Grit Basin	25.87	c.y.	\$ 30.00	\$ 776.10	\$ 776.10
		Remove Existing Grit Equipment	1	LOT	\$ 5,000.00	\$ 5,000.00	\$ 5,000.00
Division 3	Concrete						
		Foundation Slab	37.62	c.y.	\$ 532.10	\$ 20,017.60	\$ 20,017.60
		Elevated Slabs and Walls	53.51	c.y.	\$ 1,123.40	\$ 60,113.13	\$ 60,113.13
Division 5	Metals						
		Aluminum Grating	508	s.f.	\$ 23.00	\$ 11,684.00	\$ 11,684.00
		Aluminum Handrail	100	L.F.	\$ 75.21	\$ 7,521.00	\$ 7,521.00
Division 11	Equipment						
		Grit Unit Equipment	1	each	\$ 259,000.00	\$ 259,000.00	\$ 336,700.00
		Davit Crane	1	each	\$ 5,000.00	\$ 5,000.00	\$ 7,447.02
Division 15	Mechanical						
		Stop Plate	2	each	\$ 10,000.00	\$ 20,000.00	\$ 20,000.00
		Weir Plate	2	each	\$ 2,000.00	\$ 4,000.00	\$ 4,000.00
		16" D.I. Pipe (Flanged)	20	L.F.	\$ 160.00	\$ 3,200.00	\$ 4,766.09
<b>Subtotal Construction = \$</b>							<b>503,346.86</b>



**UV Disinfection**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Convert CCT to UV	1	LOT	\$ 250,000.00	\$ 250,000.00	\$ 250,000.00
Division 11	Equipment						
		UV Equipment	1	each	\$ 174,500.00	\$ 174,500.00	\$ 226,850.00
						Subtotal Construction = \$	<b>476,850.00</b>

**Sludge Holding**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Equipment Removal	1	LOT	\$ 30,000.00	\$ 30,000.00	\$ 30,000.00
Division 11	Equipment						
		Diffusers	1	each	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
					<b>Subtotal Construction = \$ 130,000.00</b>		

**Dravosburg WWTP Long Term Control Plan**  
**Alternative 2 - Pump Dravosburg to MACM**  
**Planning Cost Estimate**

ITEM	COST
General Site Work	\$ 181,000
Pump Station and Valve Vault	\$ 1,449,000
Force Main to MACM	\$ 748,000
Aeration/Storage Tank Renovations	\$ 210,000
<b>SUBTOTAL CONSTRUCTION COST</b>	<b>\$ 2,588,000</b>
Electrical Costs (25%)	\$ 647,000
Mobilization/Demobilization/Bonds/Insurance (15%)	\$ 389,000
Contingency (30%)	\$ 777,000
<b>TOTAL CONSTRUCTION COST</b>	<b>\$ 4,401,000</b>
Engineering, Permitting, Legal (15%)	\$ 661,000
Construction Administration (10%)	\$ 441,000
<b>TOTAL PROJECT COST</b>	<b>\$ 5,503,000</b>

**Site Work**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		E&S Controls	1	lot	\$ 10,000.00	\$ 10,000.00	\$ 10,000.00
		By-Pass Pumping	1	lot	\$ 50,000.00	\$ 50,000.00	\$ 50,000.00
		Fill Final Clarifiers (Stone)	323	c.y.	\$ 30.00	\$ 9,690.00	\$ 9,690.00
		Site Paving	385	s.y.	\$ 50.00	\$ 19,259.26	\$ 19,259.26
		Lawn Restoration	1	lot	\$ 5,000.00	\$ 5,000.00	\$ 5,000.00
Division 3	Concrete						
		Repairs/Rehabilitation	1	lot	\$ 10,000.00	\$ 10,000.00	\$ 10,000.00
		Manholes (0'-8' Deep)	3	ea	\$2,500.00	\$ 7,500.00	\$ 7,500.00
		Manhole VF over 8' Deep	25	v.f.	\$110.00	\$ 2,750.00	\$ 2,750.00
		Fill Final Clarifiers (Cap)	31	c.y.	\$ 532.10	\$ 16,495.10	\$ 16,495.10
						\$ -	
Division 15	Mechanical						
		8" D.I. Pipe (Buried) - F.M.	150	L.F.	\$ 50.00	\$ 7,500.00	\$ 7,500.00
		18" D.I. Pipe (Buried) - F.M.	210	L.F.	\$ 200.00	\$ 42,000.00	\$ 42,000.00
						Subtotal Construction = \$	180,194.36

**Influent Pump Station and Valve Vault**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Excavation	513	c.y.	\$ 50.00	\$ 25,648.15	\$ 25,648.15
		Backfill	128	c.y.	\$ 50.00	\$ 6,412.04	\$ 6,412.04
		Stone Backfill	21	c.y.	\$ 172.00	\$ 3,612.00	\$ 3,612.00
		Excavation/Shoring/Dewatering/Backfill	1	LOT	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
Division 3	Concrete						
		Foundation Slab	62	c.y.	\$ 532.10	\$ 32,990.20	\$ 32,990.20
		Elevated Slabs and Walls	191	c.y.	\$ 1,123.40	\$ 214,569.40	\$ 214,569.40
Division 5	Metals						
		6'x6' Aluminum Hatchway	2	each	\$ 5,000.00	\$ 10,000.00	\$ 10,000.00
Division 11	Equipment						
		Normal Flow Pumps	3	each	\$ 50,000.00	\$ 150,000.00	\$ 150,000.00
		Storm Pumps	3	each	\$ 100,000.00	\$ 300,000.00	\$ 300,000.00
		MCC	1	each	\$ 300,000.00	\$ 300,000.00	\$ 300,000.00
		PLC and Controls	1	each	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
		Bridge Crane	1	each	\$ 25,000.00	\$ 25,000.00	\$ 25,000.00
		Grinder Unit	1	each	\$ 100,000.00	\$ 100,000.00	\$ 100,000.00
Division 15	Mechanical						
		Wet Well and Valve Vault Piping	1	LOT	\$ 80,000.00	\$ 80,000.00	\$ 80,000.00
<b>Subtotal Construction = \$ 1,448,231.79</b>							

**Force Main to MACM**

			Qty	Unit	Price per Unit	Materials	Total
Division 2	Site Work						
		Select Backfill	3025	c.y.	\$ 30.00	\$ 90,750.00	\$ 90,750.00
		Fliter Fence	4600	L.F.	\$ 2.50	\$ 11,500.00	\$ 11,500.00
		Municipal Road Repavement	4533	s.y.	\$ 50.00	\$ 226,666.67	\$ 226,666.67
		Exploratory Excavation	10	ea	\$ 270.00	\$ 2,700.00	\$ 2,700.00
Division 3	Concrete						
		Manhole 0-8' Deep - 4'-0" Diameter	10	ea	\$ 2,150.00	\$ 21,500.00	\$ 21,500.00
		Watertight Manhole Frame and Cover	5	ea	\$ 500.00	\$ 2,500.00	\$ 2,500.00
Division 15	Mechanical						
		8" D.I. Pipe (Buried)	4600	L.F.	\$ 50.00	\$ 230,000.00	\$ 230,000.00
		Bore 20" Stl. Casing Pipe	800	L.F.	\$ 190.00	\$ 152,000.00	\$ 152,000.00
		CCTV Inspection	4600	L.F.	\$ 1.50	\$ 6,900.00	\$ 6,900.00
		Force Main Testing	4600	L.F.	\$ 0.60	\$ 2,760.00	\$ 2,760.00
<b>Subtotal Construction = \$</b>						<b>747,276.67</b>	

**Storage Tanks**

			Qty	Unit	Price per Unit	Materials	Total
Division 11	Equipment						
		Storage Basin Dewatering Pumps	2	each	\$ 30,000.00	\$ 60,000.00	\$ 60,000.00
		Replace Aeration Diffusers	1	LOT	\$ 150,000.00	\$ 150,000.00	\$ 150,000.00
							<b>\$ 210,000.00</b>

APPENDIX E

---

MUNICIPAL ADOPTION THROUGH RESOLUTION



Municipal Adoption through Resolution  
to be included with Final Plan submission

APPENDIX F

---

ACHD AND MUNICIPAL PLANNING DEPARTMENT  
GENERAL CORRESPONDENCE

ACHD and Municipal Planning Department General Correspondence  
to be included with Final Plan submission

APPENDIX G

---

PROOF OF PUBLICATION FOR COMMENT PERIOD


Proof of Publication for Comment Period  
to be included with Final Plan submission

APPENDIX H

---


PUBLIC COMMENT AND RESPONSES

Public Comment and Responses  
to be included with Final Plan submission



**EXHIBIT 1**

**220-53**




**KLH**  
KLEINFELDER ASSOCIATES, INC.

5173 Campbells Run Road  
Pittsburgh, PA 15205  
Phone: 412-494-0510  
Fax: 412-494-0426  
www.klhengineers.com

**Legend**



- WWTP Locations
- Boundary
- Municipal Boundaries
- County Boundaries

**CITY OF  
MCKEESPORT  
ALLEGHENY COUNTY  
PENNSYLVANIA  
LOCATION**



Author: Ross Volkwein  
Date: 6/21/2014  
NAD 1983 StatePlane Pennsylvania South FIPS 3202 Feet  
Projection: Lambert Conformal Conic







**KLH**  
CONSULTANTS, INC.  
5173 Campbells Run Road  
Pittsburgh, PA 15205  
Phone: 412-484-0010  
Fax: 412-484-0426  
www.klhengineers.com

- Legend**
- WWTP Locations
  - Boundary
  - Municipal Boundaries
  - County Boundaries

**CITY OF  
MCKEESPORT  
ALLEGHENY COUNTY  
PENNSYLVANIA  
LOCATION**





**KLH**  
5173 Campbells Run Road  
Pittsburgh, PA 15205  
Phone: 412-494-0510  
Fax: 412-494-0426  
www.klhengineers.com

**Legend**

- WWTP Locations
- All areas are prime farmland
- Farmland of statewide importance
- Not prime farmland
- Boundary
- Municipal Boundaries
- County Boundaries

AgC	Evc	SwD
CstB	UCD	SstF
CndD	GGF	Uu
CuB	GwF	UuB
CwC	QuB	UuD
CuD	GwC	UCE
CwB	GuD	UuB
CwC	GwB	UuD
CwD	GwC	UuB
CwB	GwC	UuB
DstB	GwC	UuB
DstC	HwC	UuB
DuD	RstB	W
DstC	SstC	WstB
Evc	SstB	

**CITY OF  
MCKEESPORT  
ALLEGHENY COUNTY  
PENNSYLVANIA  
SOIL AND FARMLAND  
CLASSIFICATION**

0 1,200 2,400  
Feet

Author: Ross Williams  
Date: 6/21/2014  
NAO 1983 StatePlane Pennsylvania South FP96 3702 Feet  
Projection: Lambert Conformal Conic



**EXHIBIT 4**  
220-53

**KLH**  
KLEINFELDER  
LANGRISH & HENNINGSON

5173 Campbell Run Road  
Pittsburgh, PA 15205  
Phone: 412-494-0510  
Fax: 412-494-0426  
www.klh-engineers.com

**Legend**

- WWTP Locations

**Rock Formations**

- Casselman Formation
- Glenshaw Formation
- Monongahela Group


**Boundary**

- Municipal Boundaries
- County Boundaries

**CITY OF  
MCKEESPORT  
ALLEGHENY COUNTY  
PENNSYLVANIA  
GEOLOGIC FEATURES**

0      1,200      2,400  
Feet


Public: Free Version  
Date: 6/21/2014  
HAD 1083 StatePlane Pennsylvania South FIPS 3702 Feet  
Projection: Lambert Conformal Conic




**KLH**  
CONSULTANTS  
5173 Campbell Run Road  
Pittsburgh, PA 15205  
Phone: 412-494-0510  
Fax: 412-494-0426  
www.klhengineers.com










- Legend**
- WWTP Locations
  - Freshwater Pond
  - Riverine
  - All hydric
  - Not hydric
  - Partially hydric
  - Unknown
  - Boundary
  - Municipal Boundaries
  - County Boundaries



**CITY OF  
MCKEESPORT  
ALLEGHENY COUNTY  
PENNSYLVANIA  
WETLANDS AND  
HYDRIC CONDITIONS**



Author: Ross Volkman  
Date: 9/21/2014  
NAD 1983 StatePlane Pennsylvania North FIPS 2002 Feet  
Projection: Lambert Conformal Conic




	<b>EXHIBIT 6</b>
	<b>220-53</b>
	
	
5173 Campbells Run Road Pittsburgh, PA 15205 Phone: 412-494-0610 Fax: 412-494-0426 <a href="http://www.klhengineers.com">www.klhengineers.com</a>	
<b>Legend</b>	
	WWTP Locations
	Floodplains
	Boundary
	Municipal Boundaries
	County Boundaries
<b>CITY OF          MCKEESPORT          ALLEGHENY COUNTY          PENNSYLVANIA          FLOODPLAINS</b>	
	
<small>Author: Ross Williams          Date: 8/21/2014          NAD 1983 StatePlane Pennsylvania South FIPS 2012 Feet          Projection: Lambert Conformal Conic</small>	



**KLH**  
 CONSULTANTS  
 5173 Campbelle Run Road  
 Pittsburgh, PA 15205  
 Phone: 412-484-0510  
 Fax: 412-484-0426  
 www.klhengineers.com

- Legend**
- WWTP Locations
  - Municipal Boundaries
  - County Boundaries
- Landuse**
- Agriculture
  - Cemetery
  - Commercial
  - Community Facilities
  - Golf Courses
  - Industrial
  - Open Space
  - Recreation / Conservation
  - Recreation/Conservation
  - Residential
  - Transportation
  - Undeveloped
  - Undeveloped
  - Vacant

**CITY OF  
 MCKEESPORT  
 ALLEGHENY COUNTY  
 PENNSYLVANIA  
 LANDUSE**



Author: Ross Williams  
 Date: 9/2014  
 NAD 1983 StatePlane Pennsylvania South FIPS 502 Feet  
 Projection: Lambert Conformal Conic

APPENDIX J

---

PNDI SEARCH RESULTS

No response has been received from the PA Fish and Boat Commission to date. The response will be included in the final submission of the Act 537 Plan.





ENGINEERS, INC

September 2, 2014  
Ref. No.: 220-53

**CERTIFIED RETURN RECEIPT**  
**7010-0290-0000-3358-9159**

PA Fish and Boat Commission  
Division of Environmental Services  
450 Robinson Lane  
Bellefonte, PA 16823-7437

To Whom It May Concern:

**Municipal Authority of the City of McKeesport  
Allegheny County, Pennsylvania  
Act 537 Sewage Facilities Plan Update – City of Duquesne and Borough of Dravosburg**

On behalf of the Municipal Authority of the City of McKeesport (MACM), KLH Engineers, Inc. is providing this correspondence to fulfill the requirements of the Pennsylvania Natural Diversity Inventory (PNDI) review process. This is being done in an effort to complete the planning required as part of the Act 537 Sewage Facilities Plan Update to evaluate proposed wastewater treatment plant (WWTP) and combined sewer system (CSS) upgrades in the City of Duquesne and the Borough of Dravosburg. The Plan Update was developed to serve as the governing Act 537 Sewage Facilities Plan for the City of Duquesne and the Borough of Dravosburg, whose conveyance and treatment facilities are now owned and operated by the MACM.

The PNDI search was conducted for the alternatives proposed within the Plan Update resulting in a potential impact identified by the PA Fish and Boat Commission at the site of the Duquesne WWTP. The location of the Duquesne WWTP is shown on the enclosed USGS 7.5-minute Quadrangle Map.

Detailed evaluation led to the recommendation of continued operation of existing processes at the Duquesne WWTP and construction of new combined sewer overflow (CSO) bypass treatment facilities. The existing WWTP is in good operating condition with adequate capacity for dry weather flows. This alternative utilizes the existing WWTP up to peak flows of 2.5 MGD. Peak flows above 2.5 MGD will receive CSO bypass treatment. The project, which will be constructed at the existing WWTP site that is roughly one third of an acre in size, includes construction of new headworks facilities, influent pump station, and CSO bypass treatment facilities, as well as the installation of new clarifier equipment to maximize efficiency. The proposed site plan is shown on an enclosed exhibit.

The following items are included in the project proposed for the Duquesne WWTP:

- New automatic bar screen and by-pass channel with static screen.
- New headworks building.
- New raw sewage pump station and controls.
- New raw sewage pump station piping and valve vault.
- New pump flow meter.

220-53\_PNDI to PA Fish & Boat Commission\_SRG\_11c\_09.02.14

5173 Campbells Run Road Pittsburgh, PA 15205 Phone: 412.494.0510 Fax: 412.494.0426 info@klhengineers.com

[www.klhengineers.com](http://www.klhengineers.com)

PA Fish and Boat Commission  
September 2, 2014  
-Page Two-

- Site gravity and force main piping.
- New CSO bypass treatment.
- Upgrade final clarifier equipment to maximize efficiency.

As part of the Act 537 planning process, a preliminary evaluation of the presence of wetlands and hydric soil conditions was conducted. The results of these studies are shown on the enclosed hydric soil and wetlands mapping. The only wetland areas in the planning area are located along the Monongahela River and are classified as riverine. Furthermore, there are soils in the planning areas classified as partially hydric.

The MACM will make all attempts to minimize the impact on ecologically sensitive areas during any construction activities. All construction work associated with the chosen alternative will be consistent with all applicable state and federal regulations regarding wetlands. A detailed wetlands delineation analysis to determine the extent of jurisdictional wetlands will be completed should any proposed construction encroach on areas conducive to the presence of wetlands. Implementation of this Plan Update is not expected to affect wetlands in any way and the selected alternative will be consistent with wetland protection practices and legislation.

Enclosed with this correspondence are the following documents:


- Signed copy of the Project Environmental Review Receipt.
- USGS 7.5-minute Quadrangle Map showing the location of the Duquesne WWTP.
- Hydric Soils and Wetlands Mapping.
- Proposed WWTP site plan.

All appropriate permits will be obtained before any construction activities, and the project will meet all local, county, state and federal regulations regarding wetlands, prime agricultural areas, erosion and sedimentation pollution control, stormwater management, and all other applicable requirements. No environmental impacts are expected as a result of these projects.

Please feel free to contact our office if you have any questions or concerns.

Sincerely,


KLH ENGINEERS, INC.

  
Samuel R. Gibson, E.I.T.

Enclosures

### 1. PROJECT INFORMATION

Project Name: Duquesne WWTP  
 Date of review: 8/5/2014 1:53:04 PM  
 Project Category: Waste Transfer, Treatment, and Disposal, Liquid waste/Effluent, Wastewater treatment plant (construction, expansion or modification)  
 Project Area: 0.8 acres  
 County: Allegheny Township/Municipality: Duquesne  
 Quadrangle Name: BRADDOCK ~ ZIP Code: 15110  
 Decimal Degrees: 40.379129 N, -79.849883 W  
 Degrees Minutes Seconds: 40° 22' 44.9" N, -79° 50' 59.6" W



### 2. SEARCH RESULTS

Agency	Results	Response
PA Game Commission	No Known Impact	No Further Review Required
PA Department of Conservation and Natural Resources	No Known Impact	No Further Review Required
PA Fish and Boat Commission	Potential Impact	<b>FURTHER REVIEW IS REQUIRED, See Agency Response</b>
U.S. Fish and Wildlife Service	No Known Impact	No Further Review Required

As summarized above, Pennsylvania Natural Diversity Inventory (PNDI) records indicate there may be potential impacts to threatened and endangered and/or special concern species and resources within the project area. If the response above indicates "No Further Review Required" no additional communication with the respective agency is required. If the response is "Further Review Required" or "See Agency Response," refer to the appropriate agency comments below. Please see the DEP Information Section of this receipt if a PA Department of Environmental Protection Permit is required.

### 3. AGENCY COMMENTS

Regardless of whether a DEP permit is necessary for this proposed project, any potential impacts to threatened and endangered species and/or special concern species and resources must be resolved with the appropriate jurisdictional agency. In some cases, a permit or authorization from the jurisdictional agency may be needed if adverse impacts to these species and habitats cannot be avoided.

These agency determinations and responses are valid for two years (from the date of the review), and are based on the project information that was provided, including the exact project location; the project type, description, and features; and any responses to questions that were generated during this search. If any of the following change: 1) project location, 2) project size or configuration, 3) project type, or 4) responses to the questions that were asked during the online review, the results of this review are not valid, and the review must be searched again via the PNDI Environmental Review Tool and resubmitted to the jurisdictional agencies. The PNDI tool is a primary screening tool, and a desktop review may reveal more or fewer impacts than what is listed on this PNDI receipt. The jurisdictional agencies strongly advise against conducting surveys for the species listed on the receipt prior to consultation with the agencies.

#### PA Game Commission

**RESPONSE:** No impact is anticipated to threatened and endangered species and/or special concern species and resources.

#### PA Department of Conservation and Natural Resources

**RESPONSE:** No impact is anticipated to threatened and endangered species and/or special concern species and resources.

#### PA Fish and Boat Commission

**RESPONSE:** Further review of this project is necessary to resolve the potential impacts(s). Please send project information to this agency for review (see WHAT TO SEND).

**PFBC Species:** (Note: The PNDI tool is a primary screening tool, and a desktop review may reveal more or fewer species than what is listed below.)

**Scientific Name:** Chaenobryttus gulosus

**Common Name:** Warmouth

**Current Status:** Endangered

**Scientific Name:** Toxolasma parvus

**Common Name:** Lilliput

**Current Status:** Special Concern Species\*

#### U.S. Fish and Wildlife Service

**RESPONSE:** No impacts to federally listed or proposed species are anticipated. Therefore, no further consultation/coordination under the Endangered Species Act (87 Stat. 884, as amended; 16 U.S.C. 1531 et seq. is required. Because no take of federally listed species is anticipated, none is authorized. This response does not reflect potential Fish and Wildlife Service concerns under the Fish and Wildlife Coordination Act or other