

**BUREAU OF TECHNICAL UTILITY SERVICES DATA REQUESTS
TO PENNSYLVANIA-AMERICAN WATER COMPANY**

**Docket No. A-2017-2606103
Data Request 1**

Data Requests A-18 through A-20 refer to Tab 6 of the information submitted on June 9, 2017, to supplement the Application's Appendix A-17-a.

A-19. Please provide a detailed inventory, including quantity, material, and year of construction of wastewater collection system assets in West Mifflin Borough that provide service to the 18 MACM customers in West Mifflin Borough.

Response: The collection system piping associated with service to the 18 MACM customers in West Mifflin appears to be 1960 vintage vitrified clay pipe with the following characteristics:

Diameter	Length, ft
10"	459
12"	237
Total	696

Responsible Witness: David Kaufman
Title: Vice President, Engineering

Date: July 14, 2017