

**BEFORE THE  
PENNSYLVANIA PUBLIC UTILITY COMMISSION**

Petition of PPL Electric Utilities Corporation :  
for Approval of Tariff Modifications and :  
Waivers of Regulations Necessary to : Docket No. P-2019-3010128  
Implement its Distributed Energy Resources :  
Management Plan :

**REJOINDER TESTIMONY OF  
SALIM SALET**

**PPL Electric Statement No. 1-RJ**

**August 26, 2020**

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. My name is Salim Salet, and my business address is 2 North Ninth Street, Allentown, PA  
3 18101.

4  
5 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

6 A. I am employed by PPL Electric Utilities Corporation (“PPL Electric” or the “Company”)  
7 as Director – Operations.

8  
9 **Q. HAVE YOU PREVIOUSLY SUBMITTED TESTIMONY IN THIS PROCEEDING?**

10 A. Yes. My direct testimony is set forth in PPL Electric Statement No. 1, and my rebuttal  
11 testimony is set forth in PPL Electric Statement No. 1-R.

12  
13 **Q. WHAT IS THE PURPOSE OF YOUR REJOINDER TESTIMONY?**

14 A. I will respond to many of the allegations and recommendations made in NRDC Statement  
15 No. 1-SR, the Surrebuttal Testimony of Harry Warren submitted on behalf of the Natural  
16 Resources Defense Council (“NRDC”); OCA Statement No. 1-SR, the Surrebuttal  
17 Testimony of Ron Nelson submitted on behalf of the Office of Consumer Advocate  
18 (“OCA”); SEF Statement No. 1-SR, the Surrebuttal Testimony of John Costlow submitted  
19 on behalf of the Sustainable Energy Fund (“SEF”); and SEF Statement No. 2-SR, the  
20 Surrebuttal Testimony of Ron Celentano submitted on behalf of SEF. In this rejoinder  
21 testimony, I will address the witnesses’ surrebuttal testimony in that order.

22 Furthermore, some parties recommended in their surrebuttal testimony that PPL  
23 Electric undertake a pilot program to test and evaluate the Company’s remote management

1 of distributed energy resources (“DERs”) interconnected with its distribution system  
2 through the use of the ConnectDER LLC (“ConnectDER”) DER management devices.  
3 PPL Electric continues to maintain that its DER Management proposal should be granted  
4 in full as set forth in its rebuttal testimony. However, if the Commission concludes that  
5 the Company should undertake a pilot program, the Commission should direct PPL Electric  
6 to implement the DER Management Plan as set forth at the conclusion of my rejoinder  
7 testimony, which includes a program to test and evaluate the remote active management of  
8 DERs. Moreover, such direction from the Commission should not prohibit the Company’s  
9 ability to seek recovery of the costs and expenses associated with the DER Management  
10 Plan in a future proceeding.

11  
12 **Q. ARE YOU SPONSORING ANY EXHIBITS WITH YOUR REJOINDER**  
13 **TESTIMONY?**

14 A. Yes. Attached to my rejoinder testimony is PPL Electric Exhibit SS-1RJ, which is a more  
15 in-depth analysis of the costs and benefits of the Company being able to remotely manage  
16 the smart inverters’ grid support functions, along with a detailed list of the assumption used  
17 in that analysis.

18  
19 **I. NRDC STATEMENT NO. 1-SR – SURREBUTTAL TESTIMONY OF HARRY**  
20 **WARREN**

21 **Q. DO YOU HAVE ANY OVERALL COMMENTS ON NRDC WITNESS WARREN’S**  
22 **SURREBUTTAL TESTIMONY?**

23 A. Yes. I would like to note that Mr. Warren does agree with the Company, at least in part,  
24 on the need for PPL Electric’s proposal. Specifically, Mr. Warren recommends that PPL

1 Electric be permitted to begin requiring Institute of Electrical and Electronics Engineers  
2 (“IEEE”) 1547-2018 compliant smart inverters and establishing the autonomous settings  
3 on the DERs’ smart inverters beginning January 1, 2022. (NRDC Statement No. 1-SR, pp.  
4 2-3.) He then recommends a pilot program that is “designed to demonstrate the incremental  
5 costs vs. the incremental benefits of communication with and control of newly installed  
6 der inverters.” (NRDC Statement No. 1-SR, pp. 2, 16, 22.) Although I disagree with  
7 certain points in Mr. Warren’s testimony, such as the January 1, 2022 start date for  
8 requiring IEEE 1547-2018 compliant smart inverters and autonomous settings as well as  
9 his pilot program recommendation, his surrebuttal testimony, at the very least, establishes  
10 that PPL Electric’s DER Management Petition should be granted in part.

11  
12 **Q. YOU MENTIONED THAT YOU DISAGREE WITH NRDC WITNESS**  
13 **WARREN’S PILOT PROGRAM PROPOSAL. COULD YOU PLEASE EXPLAIN**  
14 **WHY?**

15 A. NRDC witness Warren makes the pilot program recommendation for three primary  
16 reasons: (1) remote management is “not necessary to assure the safe and reliable operation  
17 of the distribution system or the bulk power system,” but if PPL Electric wants to do that,  
18 it “should demonstrate that incremental advantages warrant incremental costs”; (2) the  
19 Company’s analysis of cost savings for DER customers “is inaccurate in some respects,  
20 not universal in other respects, and does not address systems larger than 15 kW”; and (3)  
21 it is uncertain whether ConnectDER can “furnish the needed supplies of ConnectDER  
22 devices to cover all PPL DER systems.” (NRDC Statement No. 1-SR, p. 4.)

1           However, none of these reasons have merit. First, PPL Electric has demonstrated  
2           that remote management of DERs has substantial safety and reliability benefits and that the  
3           incremental benefits of remote management outweigh the reduced benefits of solely relying  
4           on autonomous functions. One of the principal benefits is increasing the amount of DERs  
5           that can be safely and reliably interconnected with the distribution system, which can be  
6           accomplished by managing DERs' settings remotely, such as Volt/VAR and Constant  
7           Power Factor. Doing so across the distribution system increases the amount of DERs that  
8           can be interconnected to the system before making costly system upgrades. This is known  
9           in the industry as increasing "hosting capacity." Although autonomous functions can help  
10          increase hosting capacity in some circumstances, remote management will result in far  
11          fewer disruptions and reductions to service. For example, if the Volt/VAR curve on a  
12          customer's DER needs to be changed to accommodate a temporary or permanent  
13          overvoltage condition, remote management would enable PPL Electric to adjust the DER's  
14          Volt/VAR curve in a very quick and inexpensive manner. Without remote management,  
15          PPL Electric would have to dispatch personnel to adjust the settings on the inverter  
16          manually.

17          As a result, Mr. Warren continues to overlook how initial autonomous settings on  
18          smart inverters cannot be relied upon prospectively. Subsequent changes on the  
19          distribution system, such as the addition of more DERs or customers to a feeder, will  
20          require new autonomous settings. In other words, the autonomous settings will be  
21          established to address the conditions of the system existing today, not tomorrow. While  
22          Mr. Warren wants PPL Electric to solely rely on the autonomous settings, he fails to  
23          account for the obvious benefits of PPL Electric remotely adjusting those settings as needed

1 in a quick, inexpensive manner, rather than having to dispatch personnel to manually adjust  
2 the settings on the inverter.

3 Second, PPL Electric’s estimates of cost savings for customers under its proposal  
4 are accurate, as explained by Mr. Wallace (PPL Electric Statement No. 6-RJ) and shown  
5 by PPL Electric Exhibit MW-1RJ.

6 Third, NRDC witness Warren’s concerns about whether ConnectDER can supply  
7 a sufficient quantity of ConnectDER DER Management devices should be rejected. The  
8 Company will maintain a running inventory for minimum of three months’ worth of system  
9 demand, starting at 400 units, which will be replenished monthly. ConnectDER will  
10 maintain minimum of three months’ worth of inventory, which will be available for  
11 immediate delivery. ConnectDER’s manufacturer, Allen Integrated Assemblies (“AIA”),  
12 will maintain an allocated inventory for PPL Electric of the necessary parts and  
13 components to assemble an additional three months’ worth of units, which can all be  
14 delivered within one month’s time. For additional materials beyond the nine-month supply,  
15 the longest lead time is three months. AIA can hire and train additional labor in two weeks’  
16 time. In addition, based on the Company’s experience with DER installations in its service  
17 area, it takes customers a minimum of approximately six weeks to install their DER  
18 systems after they receive the PPL Electric’s approval. Therefore, the Company will be  
19 able to foresee the demand coming. ConnectDER also has provided PPL Electric with a  
20 letter of prioritization, showing that demand by other utilities should not affect the  
21 Company’s demand for the DER Management devices.

22 Further, despite recognizing that any pilot program would need “a significant  
23 number of DER management devices to be deployed,” NRDC witness Warren proposes an

1           unsound “opt-in” approach for participation in the pilot, thereby significantly reducing the  
2           number of participants and unduly hindering the benefits and evaluation of any such pilot.  
3           Indeed, for the past couple years, PPL Electric has been operating a pilot program in  
4           coordination with the U.S. Department of Energy (“DOE”) called the Keystone Solar  
5           Future Project, which has been trying to evaluate the benefits of remote active management  
6           of DERs. Participation in this pilot program has been entirely voluntary. While the  
7           Company believes that the Keystone Solar Future Project has provided valuable insights  
8           and information, participation in the pilot has been far below the Company’s expectations  
9           due to the limited geographic scope of the pilot, the Company’s inability to control where  
10          DERs will be interconnected, and, most critically, the voluntary nature of the pilot. Thus,  
11          if Mr. Warren truly wants the Company to evaluate “a significant number of DER  
12          management devices,” an opt-in approach is not the correct strategy.

13                   Notwithstanding, although PPL Electric disagrees with NRDC’s pilot program  
14          recommendation, it appears that the NRDC recognizes the benefits of PPL Electric  
15          requiring IEEE 1547-2018 compliant smart inverters and using automated grid support  
16          functions.

17  
18      **Q.    NRDC WITNESS WARREN ALSO RECOMMENDS THAT THE COMPANY “BE**  
19      **AUTHORIZED TO REQUIRE THAT INVERTERS CERTIFIED TO IEEE-1547-**  
20      **2018 BE USED IN ALL NEW DER INSTALLATIONS AFTER JANUARY 1, 2022”**  
21      **(NRDC STATEMENT NO. 1-SR, P. 3.) WOULD YOU PLEASE RESPOND?**

22      **A.**    There is no need to wait until January 1, 2022, to launch PPL Electric’s DER Management  
23      proposal. The basis for Mr. Warren’s recommendation is his estimation that IEEE 1547-

1 2018 compliant smart inverters will not be readily available on the market by January 1,  
2 2022. (NRDC Statement No. 1-SR, p. 18.) However, as explained in my prior testimony,  
3 PPL Electric has a robust and detailed interim solution for using certified smart inverters  
4 until the IEEE 1547-2018 and UL 1741 standards are finalized and published. Therefore,  
5 PPL Electric should be permitted to begin implementing its DER Management proposal as  
6 soon as the Commission enters its Order approving the Company's Petition.

7  
8 **Q. NRDC WITNESS WARREN ALSO RAISES A QUESTION AS TO WHETHER**  
9 **THE COMPANY'S DER MANAGEMENT PROPOSAL WOULD APPLY TO DER**  
10 **SYSTEMS WITH NAMEPLATE CAPACITIES LARGER THAN 15 KW. (NRDC**  
11 **STATEMENT NO. 1-SR, PP. 8-9.) CAN YOU PLEASE CLARIFY?**

12 **A.** PPL Electric would purchase, install, own, and maintain DER Management devices for  
13 larger DER installations in the same manner as the Company would for smaller  
14 installations. However, for systems larger than 15 kW, the customers may not be able to  
15 enjoy the benefits of the reduced installation costs stemming from the use of the  
16 ConnectDER DER Management Device, as seen in PPL Electric Exhibit MW-1RJ attached  
17 to Mr. Wallace's rejoinder testimony (PPL Electric Statement No. 6-RJ).

18  
19 **Q. NRDC WITNESS WARREN ALSO ASSERTS THAT EVEN IF THE**  
20 **COMMISSION APPROVES PPL ELECTRIC'S DER MANAGEMENT PLAN OR**  
21 **HIS PROPOSED PILOT PROGRAM, A STATEWIDE PROCEEDING SHOULD**  
22 **STILL BE INITIATED TO ADDRESS OTHER UTILITIES' PLANS TO**



1           **IMPLEMENT IEEE 1547-2018. (NRDC STATEMENT NO. 1-SR, P. 19.) WHAT IS**  
2           **YOUR RESPONSE?**

3    A.    If such a proceeding is initiated after PPL Electric’s DER Management Petition is approved,  
4           the Company would be willing to share its experiences obtained through DER Management  
5           Plan with other utilities in Pennsylvania and the Commission. In that respect, PPL  
6           Electric’s DER Management proposal should provide valuable data and information for  
7           interested parties and the Commission to consider in that statewide proceeding. Therefore,  
8           other utilities, stakeholders, customers, and the Commission would benefit from PPL  
9           Electric implementing its DER Management proposal before any such statewide  
10          proceeding.

11  
12   **II.    OCA STATEMENT NO. 1-SR – SURREBUTTAL TESTIMONY OF RON NELSON**

13   **Q.    OCA WITNESS NESLON CLAIMS THAT PPL ELECTRIC’S DECISION TO**  
14           **MAKE ITS UPDATED DER MANAGEMENT PROPOSAL IN ITS REBUTTAL**  
15           **TESTIMONY REFLECTS A LACK OF PLANNING AND CALLS INTO**  
16           **QUESTION THE COMPANY’S ANALYSIS OF THE DER MANAGEMENT**  
17           **DEVICES. (OCA STATEMENT NO. 1-SR, PP. 3-5.) DO YOU AGREE?**

18    A.    Absolutely not. PPL Electric made its updated proposal after careful analysis and in an  
19           effort to respond to the other parties’ issues raised in their direct testimony, including the  
20           impact of the Company’s proposal on customers’ costs to install new DERs. Moreover,  
21           OCA was provided with details about the ConnectDER DER Management device in  
22           discovery as early as December 3, 2019, when the Company served its response to  
23           Interrogatory 42 in SEF’s first set of discovery. In fact, Mr. Nelson attached that discovery

1 response to his direct testimony as an exhibit, which has a picture of the ConnectDER DER  
2 Management device and has multiple paragraphs explaining the development, installation,  
3 and operation of the device. (See OCA Schedule REN-2, Answer to Interrogatory SEF-I-  
4 42, Attachment 1, p. 16.) Therefore, the OCA was provided with information about this  
5 device and its potential use by the Company over two months before the OCA served its  
6 direct testimony on February 5, 2020. Thus, the OCA had more than enough time to engage  
7 in discovery about this device before serving its direct testimony.

8  
9 **Q. MR. NELSON ALSO CLAIMS THAT THE ESTIMATED COST OF THE**  
10 **CONNECTDER DER MANAGEMENT DEVICE IS \$400, NOT THE COMPANY'S**  
11 **ESTIMATE OF \$700. (OCA STATEMENT NO. 1-SR, P. 5.) IS MR. NELSON**  
12 **CORRECT?**


13 A. No. It appears Mr. Nelson was looking at the Simple ConnectDER device, not the  
14 ConnectDER DER Management device that PPL Electric plans on utilizing. The Simple  
15 ConnectDER device allows for a straightforward connection of the electrical output of the  
16 DER system, in lieu of connection to a customer's electrical panel. The Simple  
17 ConnectDER device consists of the meter collar only and lacks the radio that can  
18 communicate with the smart inverter and manage the smart inverter's grid support  
19 functions.

20 In contrast, the ConnectDER DER Management device, which PPL Electric is  
21 proposing to use, does contain the radio and can communicate with the smart inverter and  
22 manage the smart inverters' settings. Such capabilities are necessary to realize the safety  
23 and reliability benefits of the DER Management Plan. Therefore, OCA witness Nelson's

1 analysis on the estimate cost of the DER Management device is based on the wrong  
2 ConnectDER device.

3  
4 **Q. OCA WITNESS NELSON CONTENDS THAT PPL ELECTRIC DID NOT**  
5 **ADDRESS THE INSTALLATION COSTS OR EXPLAIN HOW THE DER**  
6 **MANAGEMENT DEVICES WOULD INTERCONNECT TO STANDALONE**  
7 **BATTERY STORAGE OR ELECTRIC VEHICLES (“EVs”). (OCA STATEMENT**  
8 **NO. 1-SR, PP. 8-9.) PLEASE RESPOND.**

9 A. To clarify, the Company no longer is proposing to include EVs under its present DER  
10 Management Plan. In the future, as standards develop and mature, as well as EV  
11 technology, PPL Electric will continue to evaluate impact to safety and reliability on the  
12 distribution system. As for standalone battery storage, IEEE 1547-2018, the “Standard for  
13 Interconnection and Interoperability of Distributed Energy Resources with Associated  
14 Electric Power Systems Interfaces,” applies to all DERs, including fuel cells, photovoltaics,  
15 dispersed generation, and energy storage. The Standard specifies standardized  
16 communication interfaces for DERs, including generators (like solar photovoltaic  
17 generators) and energy storage (like lithium ion batteries). Just as PPL Electric would  
18 connect the dongle of the DER Management device to the interface on a solar photovoltaic  
19 smart inverter certified to IEEE 1547-2018, the Company would connect the dongle of the  
20 DER Management device to the interface on a standalone battery inverter certified to IEEE  
21 1547-2018. A one-line diagram of how the device would be interconnected with a  
22 standalone battery storage unit’s inverter is provided below.



1

2

I further note that PPL Electric will only connect a DER Management device to a standalone battery that acts as a DER, *i.e.*, exports power onto the electric distribution system. PPL Electric will not connect a DER Management device to standalone batteries that are intended exclusively for backup generation, rather than exporting electric power onto the distribution system.

7

8

**Q. MR. NELSON ALSO ASSERTS THAT PPL ELECTRIC FAILED TO ADDRESS THE CUSTOMER PROTECTION CONCERNS RAISED BY THE OCA. (OCA STATEMENT NO. 1-SR, PP. 10-11.) DO YOU AGREE?**

10

1 A. No. PPL Electric’s updated proposal substantially addressed the customer protection  
2 concerns raised by the OCA, including the submission of annual reports to the Commission  
3 and individual customers that would provide the Commission, stakeholders, and customers  
4 with significant oversight of the DER Management Plan. Moreover, as set forth in the  
5 Company’s pilot program alternative, PPL Electric would provide extensive annual reports  
6 to the Commission, stakeholders, and individual customers about the progress of the DER  
7 Management Plan and the impact, if any, on participating customer-generators’ production.  
8

9 **Q. OCA WITNESS NELSON TAKES THE POSITION THAT OTHER ELECTRIC**  
10 **DISTRIBUTION COMPANIES (“EDCs”) CAN SIMPLY IMPLEMENT IEEE-1547**  
11 **2018 WITHOUT FURTHER INVESTMENTS. (OCA STATEMENT NO. 1-SR, PP.**  
12 **20-21.) DO YOU BELIEVE THIS IS A SOUND APPROACH?**

13 A. No. Although other EDCs could just require all DERs to use IEEE 1547-2018 compliant  
14 inverters, this would not produce any substantial benefits. Indeed, to get any substantial  
15 benefit out of those smart inverters, EDCs have to study their distribution systems and  
16 come up with EDC-specific default settings that fit their distribution circuits. The other  
17 EDCs would have to devote the necessary time and expense to conduct this analysis and  
18 implement their default settings, which they may not be willing to do. In addition, without  
19 the investments made in Distributed Energy Resource Management System (“DERMS”),  
20 Distribution Management System (“DMS”), and the communication system, EDCs cannot  
21 achieve the significant safety and reliability benefits highlighted by PPL Electric’s DER  
22 Management Plan, such as managing voltage issues, increasing hosting capacity,  
23 improving safety and reliability, addressing issues with masked load, and mitigating fault

1 location concerns. Therefore, Mr. Nelson's claim that other EDCs can implement IEEE  
2 1547-2018 without further investments should be rejected.

3  
4 **Q. MR. NELSON ALSO CRITICIZES THE COMPANY'S COST-BENEFIT**  
5 **ANALYSIS OF ITS PROPOSAL. (OCA STATEMENT NO. 1-SR, PP. 7-9.)**  
6 **PLEASE RESPOND.**

7 A. As Ms. Johnson will explain in her rejoinder testimony, OCA witness Nelson's allegations  
8 related to the Company's cost-benefit analysis are without merit. Nonetheless, attached as  
9 PPL Electric Exhibit SS-1RJ is a more in-depth analysis of the costs and benefits of the  
10 Company being able to remotely manage the smart inverters' grid support functions, along  
11 with a detailed list of the assumption used in that analysis.

12  
13 **III. SEF STATEMENT NO. 1-SR – SURREBUTTAL TESTIMONY OF JOHN**  
14 **COSTLOW**

15 **Q. SEF WITNESS COSTLOW RAISES ISSUES CONCERNING THE USE OF THE**  
16 **SMART INVERTERS' REMOTE ON/OFF FUNCTION FOR SOLAR PLUS**  
17 **STORAGE DER INSTALLATIONS. (SEF STATEMENT NO. 1-SR, PP. 2-3, 8.)**  
18 **WOULD YOU PLEASE RESPOND?**

19 A. Mr. Costlow's arguments lack merit and show that he fundamentally misunderstands  
20 unintentional islanding. Mr. Costlow claims that unintentional islanding will not happen  
21 since solar and battery inverters will shut off automatically. Although inverters are  
22 designed to shut off during an grid outage, unintentional islanding could still happen when:  
23 (1) inverters malfunction and fail to shut off; (2) inverters on the same feeder use different  
24 algorithms that may cause each other to stay online during a loss-of-source; or (3)

1 combined generation is approximately equal to load on the line and cause reference voltage  
2 at the DER to appear sufficiently similar to grid voltage.

3 Further, PPL Electric has no intention to remotely turn off solar plus storage after  
4 it has automatically disconnected from the distribution system in case of an outage. In the  
5 case of an outage, and assuming there is no emergency situation such as a gas leak, PPL  
6 Electric will not remotely turn off solar plus storage after that system has automatically  
7 disconnected from the distribution system. After the customer's solar plus storage  
8 disconnects from the distribution system, the customer can continue to operate the DER  
9 system to supply their native load. Therefore, the customer's solar plus storage system can  
10 provide power behind the customer disconnect.

11  
12 **Q. MR. COSTLOW ALSO RECOMMENDS THAT ANY MODIFICATIONS TO PPL**  
13 **ELECTRIC'S DER MANAGEMENT PLAN SHOULD HAVE TO BE APPROVED**  
14 **BY THE COMMISSION AFTER THE SUBMISSION OF COMMENTS AND**  
15 **REPLY COMMENTS ON THE PROPOSED MODIFICATIONS, LIKE IN THE**  
16 **ENERGY EFFICIENCY AND CONSERVATION ("EE&C") PLAN**  
17 **PROCEEDINGS. (SEF STATEMENT NO. 1-SR, P. 3.) DO YOU AGREE?**

18 A. No. Mr. Costlow's recommendation lacks merit. In the EE&C Plan proceedings, different  
19 review processes are set up for "minor" and "major" plan changes, as defined by the  
20 Commission's *Minor Plan Change Order*.<sup>1</sup> However, I have been advised by counsel that  
21 not every change or adjustment to an EE&C Plan is subject to Commission review and

---

<sup>1</sup> See *Energy Efficiency and Conservation Program*, Docket No. M-2008-2069887 (Order entered June 10, 2011) ("*Minor Plan Change Order*").

1 approval, as suggested by Mr. Costlow. Indeed, PPL Electric’s currently-effective Phase  
2 III EE&C Plan has various provisions that give the Company flexibility in operating its  
3 EE&C Plan without the need for formal Plan changes to be approved. For example, many  
4 of the incentives offered for EE&C measures have incentive ranges, allowing the Company  
5 to change the incentive offered to customers to any dollar figure within those ranges.  
6 Moreover, the EE&C Plan has language allowing PPL Electric to adjust the available  
7 measures offered under certain programs, so that the Company can efficiently operate its  
8 programs while still achieving the requisite level of savings and remaining under the  
9 established budget. Therefore, Mr. Costlow’s reliance on the Company’s EE&C Plan as  
10 support for his recommendation that “PPL Electric should not be given the authority to  
11 modify, in any way, its DER Management Plan at Company discretion” is misplaced. (SEF  
12 Statement No. 1-SR, p. 3.)

13 Furthermore, Mr. Costlow fails to recognize that there are already established  
14 procedures for modifications to tariffs and Commission orders. I have been advised by  
15 counsel that if the Company wanted to change any terms in the proposed Tariff Rule 12,  
16 PPL Electric would have to follow the Commission’s established procedures for proposal  
17 and approval of tariff modifications. Similarly, counsel has advised me that PPL Electric  
18 would have to adhere to the terms of the Commission’s order approving the DER  
19 Management Plan. If a party wishes to propose amendments or modifications to a  
20 Commission order, both the Public Utility Code and the Commission’s regulations set forth  
21 the procedures for a party to file a petition to amend or modify that Order. *See* 66 Pa. C.S.  
22 § 703(g); 52 Pa. Code § 5.41.



1 **Q. WILL PPL ELECTRIC’S DER MANAGEMENT PLAN LIMIT THE ABILITY OF**  
2 **DER OWNERS TO MONITOR AND CONTROL THEIR SMART INVERTERS,**  
3 **AS ALLEGED BY SEF WITNESS COSTLOW? (SEF STATEMENT NO. 1-SR, P.**  
4 **5.)**

5 A. No. PPL Electric’s DER Management Plan will not limit the ability of DER owners to  
6 monitor and control their smart inverters. PPL Electric has evaluated inverters with three  
7 ports that would allow the Company to connect its DER Management device without  
8 impacting the ability for the customer to manage their energy infrastructure. In cases where  
9 three communications ports are needed, such as in a solar plus storage situation, PPL  
10 Electric will provide a multi-port solution at no direct cost to that customer. Therefore, Mr.  
11 Costlow’s concern is moot.

12 In addition, in SEF witness Costlow’s surrebuttal testimony, he references SEF’s  
13 system that will be used in its “Net Zero Energy Office Building.” (SEF Statement No. 1-  
14 SR, p. 5.) The SolarEdge SE43.2KUS inverters used in this system feature two RS485  
15 ports, where one port is used to network the inverters together and the other port is used to  
16 connect to the customer’s energy management system. Out-of-the-box, this model of  
17 inverter may not be capable of simultaneously connecting to: (a) other inverters; (b) the  
18 customer’s energy management system; and (c) PPL Electric’s DER Management device.  
19 However, a mini Remote Terminal Unit (“RTU”) could be utilized to connect multiple  
20 devices (such as the customer’s energy management system and PPL Electric’s DER  
21 Management device) to a single RS485 port.

22 Further, other commercially available inverters feature enough RS485 interfaces to  
23 accommodate such a configuration out-of-the-box. For example, the CanadianSolar CSI

1 Series inverters (available in 40KVA, 50KVA, and 60KVA capacities) feature three ports  
2 and are comparable to the inverters used in SEF’s Net Zero Energy Office Building. And  
3 once the IEEE 1547-2018 Standard is fully adopted by the inverter manufacturing industry,  
4 inverters will feature a standardized interface that can be used by the EDC, per Section  
5 10.7 of the Standard.

6 Lastly, SEF’s interconnection application for the system it is installing at its Net  
7 Zero Energy Office Building has already been approved to move forward. Given that the  
8 Company’s DER Management Plan will only apply to new DERs that are installed in its  
9 service territory, SEF’s currently-designed system will not be affected by the Company’s  
10 proposal. Thus, SEF’s concerns about its own system being negatively affected by the  
11 DER Management Plan are invalid.

12  
13 **Q. SEF WITNESS COSTLOW ALSO RAISES A CONCERN ABOUT THE NUMBER**  
14 **OF INVERTERS CERTIFIED AS MEETING THE COMPANY’S INTERIM**  
15 **REQUIREMENTS. (SEF STATEMENT NO. 1-SR, PP. 3-4.) PLEASE RESPOND.**

16 A. SEF witness Costow’s concerns should be rejected. PPL Electric’s DER Management Plan  
17 is ready to be implemented upon the Commission’s approval and does not need to be  
18 delayed until, as SEF witness Costlow alleges, “significantly more smart inverters . . .  
19 become commercially available.” (SEF Statement No. 1-SR, p. 4.) PPL Electric has  
20 already approved inverters from six major inverter brands (*i.e.*, Fronius, Delta, ABB, Sol-  
21 Ark, Canadian Solar, and Chint) as meeting its interim criteria (*i.e.*, inverters that are  
22 certified to Underwriters Laboratories (“UL”) 1741 Supplement A and also satisfy the  
23 communication requirements described IEEE 1547-2018, Section 10.7) and is rapidly

1 evaluating additional major brands that it expects will also satisfy these requirements, such  
2 as SolarEdge, Ginlong Solis, Sungrow, and Yaskawa. By the time the Commission  
3 approves the DER Management Petition, customers will have many choices of smart  
4 inverters that meet the Company's interim requirements.

5  
6 **Q. SEF WITNESS COSTLOW ASSERTS THAT PPL ELECTRIC'S UPDATED DER**  
7 **MANAGEMENT PROPOSAL ONLY REDUCES COSTS TO CUSTOMERS**  
8 **WHEN COMPARED TO THE COMPANY'S ORIGINAL PROPOSAL. (SEF**  
9 **STATEMENT NO. 1-SR, P. 7.) DO YOU AGREE?**

10 A. No. Mr. Costlow completely overlooks how the updated proposal will substantially reduce  
11 installation costs for most new DER customers. Without PPL Electric's DER Management  
12 Plan being approved, those customers will lose out on the opportunity to save on those  
13 installation costs. Thus, PPL Electric's updated proposal will reduce costs to customers  
14 versus the status quo.

15  
16 **Q. MR. COSTLOW ALSO CLAIMS THAT PPL ELECTRIC'S DISTRIBUTION**  
17 **GENERATION ("DG") WEB PORTAL'S CURRENT INABILITY TO ACCEPT**  
18 **NEW CONSTRUCTION APPLICATIONS INDICATES A "LACK OF**  
19 **UNDERSTANDING OF THE DER MARKET WHICH WILL CERTAINLY**  
20 **IMPACT THE COMPANY'S ABILITY TO SUCCESSFULLY MANAGE DERS,"**  
21 **AS ALLEGED BY SEF WITNESS COSTLOW. (SEF STATEMENT NO. 1-SR, PP.**  
22 **8-9.) DO YOU AGREE?**

1 A. Absolutely not. As noted in my rebuttal testimony, PPL Electric has all of the necessary  
2 infrastructure and equipment in place to implement its DER Management proposal, and  
3 continues to be an industry leader for implementing grid modernization technologies such  
4 as Distribution Automation, DMS, and Fault Isolation and Service Restoration (“FISR”).  
5 PPL Electric also is the only utility in the Commonwealth that currently has an operational  
6 DERMS platform. The Company also has a RF Mesh network that is capable of handling  
7 all of the communications between PPL Electric and the smart inverters through the  
8 Company’s service territory. Thus, PPL Electric is well-equipped to leverage these  
9 investments, its stellar customer service record, and its in-house knowledge and resources  
10 to implement its DER Management proposal. Those facts are what matter when evaluating  
11 whether PPL Electric can successfully implement the DER Management Plan, not the lack  
12 of a minor functionality in the Company’s DG Web Portal. Additionally, although the DG  
13 Web Portal cannot currently process new construction applications until an account and  
14 meter number are assigned, PPL Electric can process those applications manually through  
15 the Company’s customer service department.

16  
17 **Q. WOULD YOU PLEASE RESPOND TO SEF WITNESS COSTLOW’S**  
18 **ARGUMENTS ABOUT THE ALLEGED DISTANCE OF THE CONNECTDER**  
19 **DER MANAGEMENT DEVICE’S WI-FI COMMUNICATIONS AFFECTING**  
20 **THE “MOST EFFICIENT” PLACEMENT OF INVERTERS? (SEF STATEMENT**  
21 **NO. 1-SR, P. 9.)**

1 A. The most efficient place to have the inverter is close to the connection point of the  
2 distribution system. The closer the inverter is to the distribution system, the lower the  
3 losses are.

4 Likewise, SEF witness Costlow inaccurately claims that inverters may need to be  
5 placed more than 100 feet away in order to avoid “significant losses associated with the  
6 transmission of DC power.” (SEF Statement No. 1-SR, p. 9.) While there are many design  
7 considerations that come into play with inverter placement, the general rule is to keep the  
8 inverter as close to the Area EPS interconnection (*i.e.*, the meter) as possible to help  
9 maximize power output and, by extension, the customer’s return on investment. However,  
10 if the smart inverter must be located outside of the Wi-Fi communication distance of the  
11 DER Management device, the Company will install necessary additional equipment to  
12 extend the range of connection.

13  
14 **Q. MR. COSTLOW ALSO OUTLINES A PILOT PROGRAM RECOMMENDATION**  
15 **IN CASE THE COMMISSION DOES NOT DENY PPL ELECTRIC’S DER**  
16 **MANAGEMENT PLAN. (SEF STATEMENT NO. 1-SR, PP. 10-14.) DO YOU**  
17 **AGREE WITH THIS RECOMMENDATION?**

18 A. No. Like NRDC’s proposal, it is a poorly designed “opt-in” proposal. Moreover, SEF’s  
19 proposal contains several unnecessary and burdensome requirements that would severely  
20 limit participation in the pilot, impose additional costs on the Company, and significantly  
21 hinder the benefits and evaluation of any such pilot. For example, Mr. Costlow  
22 recommends that PPL Electric be directed to “create a text alert system that will notify  
23 customers when PPL Electric modifies an inverter setting as well as a text alert when the

1 system is restored to its previous settings.” (SEF Statement No. 1-SR, p. 13.) This would  
2 require substantial IT work, be expensive, and provide little benefit to customers.

3 Mr. Costlow also proposes that PPL Electric be prevented from commencing the  
4 pilot until it “certifies 80% of the inverters in the market,” which “should include, at  
5 minimum, five (5) inverter manufacture[rs] as well as micro inverters.” (SEF Statement  
6 No. 1-SR, p. 11.) As in any competitive market, the market for inverters is continually  
7 changing, with new products coming to market and old products being removed from the  
8 market in a fairly unpredictable manner. Therefore, it is highly questionable as to when  
9 PPL Electric could certify 80% of the inverters in the market, when more inverters are  
10 being added to the market and older inverters are being removed. Such certifications would  
11 also be rendered moot once IEEE 1547-2018 and UL 1741 are fully implemented. Thus,  
12 this requirement would only serve to unduly delay the implementation of any such pilot.  
13 Nevertheless, I note that PPL Electric has approved six major inverter brands’ inverters as  
14 meeting the Company’s interim criteria and will approve more by the time the Commission  
15 approves the DER Management Petition.

16 Finally, as mentioned previously, PPL Electric no longer will include EVs under  
17 its DER Management Plan, so SEF’s recommendation for EVs to be excluded from the  
18 pilot program is now moot.

19  
20 **IV. SEF STATEMENT NO. 2-SR – SURREBUTTAL TESTIMONY OF RON**  
21 **CELENTANO**

22 **Q. CONCERNING THE COMPANY’S PROPOSED USE OF THE REMOTE ON/OFF**  
23 **FUNCTION DURING POWER OUTAGES, SEF WITNESS CELENTANO**  
24 **ARGUES THAT UNINTENTIONAL ISLANDING IS NOT A CONCERN AND**

1           **THAT IT IS UNCLEAR HOW THE COMPANY’S USE OF THE REMOTE**  
2           **ON/OFF FUNCTION WOULD AFFECT SOLAR PLUS STORAGE SYSTEMS.**  
3           **(SEF STATEMENT NO. 2-SR, PP. 2-3.) DO YOU AGREE?**

4    A.    No. Unintentional islanding could still occur when inverters on the same distribution  
5           feeder use different algorithms that may cause each other to stay online during a loss-of-  
6           source, or when combined generation is approximately equal to load on the line and causes  
7           reference voltage at the DERs to appear sufficiently similar to grid voltage. Line loading  
8           is dynamic during a fault, so a lower generation-to-load ratio is used to assess islanding in  
9           these scenarios.

10                 Moreover, for solar plus storage, the Company has no intention of shutting down a  
11           battery storage system or the solar system during outage situation. With either a DC  
12           coupled or an AC coupled solar plus storage, the Company would only remotely turn off  
13           the inverter connected to the distribution system in the case where its grid side failed to  
14           disconnect and is back-feeding into a de-energized and faulted line section, or if there is an  
15           emergency situation such as a gas leak.

16  
17    **Q.    SEF WITNESS CELENTANO ALSO MAKES CERTAIN CRITICISMS ABOUT**  
18           **YOUR TWO-WAY POWER FLOW EXAMPLE. (SEF STATEMENT NO. 2-SR,**  
19           **PP. 3-4.) DO THOSE CRITICISMS HAVE MERIT?**

20    A.    No. Mr. Celentano’s criticisms of the Company’s two-way power flow example should be  
21           rejected. PPL Electric included a simple example of a small two-way power flow that can  
22           happen anywhere in Company’s distribution system for illustration purposes. This simple  
23           example was intended to show how two-way power flows work and create issues on the

1 distribution system. Further, the example helped show that, contrary to OCA witness  
2 Nelson's characterization in his direct testimony, PPL Electric is not only experiencing  
3 two-way power flows on a "de minimus number of circuits." (OCA St. No. 1, p. 33.) In  
4 fact, PPL Electric experiences two-way power flows on a regular basis. In discovery, the  
5 Company listed several locations where two-way power flow known to the Company  
6 because the two-way power flow is high enough to back-feed circuit breaker level or 3  
7 phase circuit device. Thus, depending on the circuit, the amount of generation and load on  
8 a circuit could create a much more dire two-way power flow situation than the illustrative  
9 example set forth in my rebuttal testimony.

10  
11 **Q. MR. CELENTANO ALSO CONTENDS THAT YOU REFERENCE TO THE**  
12 **NATIONAL AVERAGE RESIDENTIAL SOLAR INSTALLATION COST DOES**  
13 **NOT COMPARE TO AVERAGE COST IN PENNSYLVANIA. (SEF STATEMENT**  
14 **NO. 2-SR, PP. 5-6.) PLEASE RESPOND.**

15 A. Mr. Celentano misunderstands the purpose of my reference to the national solar installation  
16 cost. In my rebuttal testimony, I referenced national data compiled by National Renewable  
17 Energy Laboratory ("NREL"), which indicated that the residential solar installation cost  
18 has dropped 63%, from \$7.34 per watt in 2010 to \$2.70 per watt in 2018. While Mr.  
19 Celentano asserts that the residential solar installation cost in Pennsylvania is \$2.94 per  
20 watt, he does not dispute that the costs have been dropping substantially. No reason exists  
21 to believe that this trend will stop or reverse course in Pennsylvania. In fact, even Mr.  
22 Celentano's \$2.94 per watt figure is a substantial 60% drop from the national average cost  
23 in 2010.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**Q. MR. CELENTANO ALSO AVERS THAT THE COMPANY’S USE OF THE CONNECTDER DER MANAGEMENT DEVICE MAY BE INCONSISTENT WITH 52 PA. CODE § 75.36(9)’S REQUIREMENTS FOR A LOCKABLE, VISIBLE BREAK ISOLATION DEVICE OR A DRAW-OUT TYPE CIRCUIT BREAKER. (SEF STATEMENT NO. 2-SR, PP. 6-7.) WOULD YOU PLEASE RESPOND?**

A. PPL Electric maintains that the new ConnectDER DER Management device should be allowed to be used and, to the extent necessary, a waiver of this regulation should be granted. I have been advised by counsel that Section 75.36(9) of the Commission’s regulations is intended to provide the EDCs with the ability to, if necessary, isolate interconnected DERs from the distribution system. Although the ConnectDER DER Management device is not a physical switch like an AC Disconnect, it is a device that provides a lockable, visible-break isolation point. If PPL Electric were required to isolate the customer’s inverter system, PPL Electric would simply remove the ConnectDER DER Management device’s meter collar and reinstall the customer’s meter with a meter lock. Thus, even if the ConnectDER DER Management device were used, the Company could use the device as a visible break isolation point for the customer’s inverter system and install the meter lock to prevent any re-energization without PPL Electric’s permission.

Moreover, my understanding is that Section 75.36 is founded upon the principle that the “lockable, visible-break isolation device” must be “accessible by the EDC.” 52 Pa. Code § 75.36(9). The requirement for accessibility is a moot concern when the EDC owns the isolation device instead of the customer. As proposed by the Company in its rebuttal

1 testimony, PPL Electric would purchase, own, install, and maintain the ConnectDER DER  
2 Management device. Importantly, PPL Electric’s Tariff Rule 2(F) grants the Company  
3 “access at all reasonable hours to customer’s premises, without charge, for the purpose of  
4 inspecting installations, installing meters, reading, testing, removing, replacing or  
5 otherwise maintaining or disposing of any of Company’s property.” Supp. No. 59 to  
6 Electric Pa. P.U.C. No. 201, Fifth Revised Page No. 6B. As a result, there would be no  
7 issues with the Company’s ability to access this equipment. Therefore, I do not believe  
8 that Section 75.36(9) should be used to restrict the Company’s ability to implement the  
9 DER Management Plan.

10 Finally, PPL Electric requested in its DER Management Petition that “the  
11 Commission grant any additional waivers of the Commission’s regulations it deems are  
12 necessary to implement the DER Management Plan.” (DER Management Petition ¶ 81.)  
13 Therefore, to the extent that the Commission believes that a waiver of Section 75.36(9) is  
14 necessary, the Commission should grant such waiver so that the Company can implement  
15 the DER Management Plan and reap the substantial benefits of the proposal.

16  
17 **Q. DO YOU AGREE WITH SEF WITNESS CELENTANO’S ASSERTION THAT**  
18 **“THE VAST MAJORITY OF INVERTERS ARE CURRENTLY NOT**  
19 **TEMPORARILY SHUTTING DOWN TOO OFTEN WITHOUT ENGAGING**  
20 **VOLTAGE AND FREQUENCY RIDE-THROUGH”?** (SEF STATEMENT NO. 2-  
21 **SR, P. 8.)**

22 **A.** No. Mr. Celentano’s claim should be rejected because: (1) it is based on his “belief” and  
23 not any cited support; and (2) incorrectly discounts the benefits of ride-through settings.

1 (SEF Statement No. 2-SR, p. 8.) Further, while the Electric Power Research Institute  
2 (“EPRI”) study shows that the impact of five different solar systems on flicker is not  
3 significant, the impact of hundreds or thousands of systems ramping up or ramping down  
4 would likely be much more significant.

5  
6 **V. AMENDED DER MANAGEMENT PLAN THAT SHOULD BE IMPLEMENTED**  
7 **IF THE COMMISSION DIRECTS THE COMPANY TO UNDERTAKE A PILOT**  
8 **PROGRAM**

9 **Q. YOU PREVIOUSLY ADDRESSED THE PILOT PROGRAMS RECOMMENDED**  
10 **BY NRDC WITNESS HARRY WARREN AND SEF WITNESS JOHN COSTLOW.**  
11 **ALTHOUGH THE COMPANY DISAGREES WITH THOSE**  
12 **RECOMMENDATIONS, DOES PPL ELECTRIC HAVE A COUNTER-**  
13 **PROPOSAL ON WHAT PILOT PROGRAM, IF ANY, SHOULD BE**  
14 **IMPLEMENTED BY THE COMPANY?**

15 A. Yes. Again, based on the evidence presented in this proceeding, PPL Electric should be  
16 permitted to implement its DER Management proposal as currently proposed. The benefits  
17 of the Company’s proposal are well-documented and cannot reasonably be disputed. At a  
18 bare minimum, as the operator of its distribution system, PPL Electric needs the ability to  
19 monitor and manage the generation from DERs that is flowing onto its system so that the  
20 Company can safely and reliably provide electric service to its customers.

21 However, in the event that the Commission decides that it would be more prudent  
22 to test and evaluate some of these technologies, PPL Electric recommends that the pilot  
23 program be focused on the remote active management aspect of its DER Management Plan.

1 Thus, to the extent the Commission believes a pilot program is appropriate here, the DER  
2 Management Plan should be implemented as follows:

3 **A. SMART INVERTERS**

- 4 1. Effective January 1, 2021, new DERs interconnecting with the Company's  
5 distribution system must have smart inverters installed that meet: (1) Underwriters  
6 Laboratories ("UL") Standard 1741 Supplement A ("UL 1741 SA"); and (2) the  
7 Company's testing for the communications requirements under the 2018 revisions  
8 to the Institute of Electrical and Electronics Engineers ("IEEE") Standard 1547,  
9 "Standard for Interconnection and Interoperability of Distributed Energy Resources  
10 with Associated Electric Power Systems Interfaces" ("IEEE Standard 1547" or  
11 "IEEE 1547-2018"). These requirements shall be known as the "Interim  
12 Requirements." The list of smart inverters that meet the Interim Requirements will  
13 be publicly available and regularly updated on the Company's website.
- 14 2. The Interim Requirements shall be used by PPL Electric until January 1, 2022. At  
15 that point, the Company will transition to requiring new DERs to have smart  
16 inverters installed that meet IEEE 1547-2018 and have been certified with IEEE  
17 1547.1 / UL 1741 Supplement B ("UL 1741 SB").
- 18 3. The smart inverters that are installed consistent with Paragraphs 2 and 3, *supra*,  
19 must have one of their communications ports dedicated to use by PPL Electric. In  
20 the event that the customer's DER requires two communications ports to operate  
21 (such as in a solar plus battery storage set-up), PPL Electric will provide a multi-  
22 port solution at no direct cost to that customer.

- 1 4. PPL Electric shall not be responsible for purchasing, owning, installing, or  
2 maintaining the customers' smart inverters.

3 **B. DER MANAGEMENT PLAN**

4 **i. Automated Grid Support Functions**

- 5 5. Effective January 1, 2021, PPL Electric shall be authorized to set the automated  
6 Volt/VAR curve, Voltage Ride-through settings, and Frequency Ride-through  
7 settings on every new DER installation in its service territory pursuant to the terms  
8 and conditions set forth in PPL Electric Exhibit SS-1R. If the DERs are equipped  
9 with the Company's DER management devices installed pursuant to Paragraph 7,  
10 *infra*, PPL Electric shall be permitted to monitor the DERs and their autonomous  
11 settings. Such monitoring will be conducted remotely through the use of the smart  
12 inverters, the DER management devices, and the Company's DERMS.

- 13 6. Although not required under the DER Management Plan, PPL Electric can enable  
14 the Volt-Watt function or specify a Watt Ramp Rate upon voluntary consent of the  
15 DER customer.

16 **ii. DER Management Devices**

- 17 7. Effective January 1, 2021, new DERs interconnecting with the Company's  
18 distribution system must have DER management devices that are purchased,  
19 installed, owned, and maintained by the Company.

20 **iii. Remote Active Management of Grid Support Functions**

- 21 8. The first 1,000 new DERs installed in the Company's service territory on or after  
22 January 1, 2021, shall function as a control group for the remote active management  
23 program. The customers in the control group will be required to have DER

1 management devices installed on their DERs. Pursuant to Paragraph 5, *supra*, the  
2 Company will monitor the control group's DERs and smart inverters and will set  
3 the automated grid support functions on the control group's smart inverters. During  
4 the term of the remote active management program, the Company will not actively  
5 manage the control group's smart inverter grid support functions as described in  
6 Paragraph 9, *infra*.

7 9. After the control group is established pursuant to Paragraph 9, PPL Electric shall  
8 be authorized to conduct a 5-year program, under which the Company would be  
9 permitted to actively manage the grid support functions of new DERs installed in  
10 its service territory through the use of the smart inverters, the DER management  
11 devices, and the Company's DERMS, provided that the Company only actively  
12 manages the following grid support functions of the smart inverters pursuant to the  
13 terms and conditions set forth in PPL Electric Exhibit SS-1R: (a) Volt/VAR; (b)  
14 Constant Power Factor; (c) Remote On/Off; (d) Voltage Ride-through; and (e)  
15 Frequency Ride-through.

16 10. The program's purpose will be to test and evaluate the benefits of remote active  
17 management of DERs, as compared to the use of the smart inverters' automated  
18 grid support functions.

19 11. Participation in the program will be required for all new DERs installed in the  
20 Company's service territory during the 5-year program period.

21 12. Within 60 days after the end of the program's fourth year, PPL Electric will be  
22 permitted to file a petition with the Commission to: (a) extend the program and, in  
23 the Company's discretion, make other changes to the program; and/or (b) authorize

1 the Company to remotely and actively manage (i) the DERs that were in the control  
2 group described in Paragraph 8, *supra*, (ii) the DERs that have enrolled and will  
3 enroll in the program, and (iii) any new DERs that will interconnect with the  
4 Company's distribution system after the program concludes. PPL Electric reserves  
5 the right to request that the Commission continue the existing remote active  
6 management program until litigation over a petition filed pursuant to Paragraph 12  
7 concludes. If no such petition is filed within 60 days after the end of the program's  
8 fourth year, the remote active management program will end after the fifth program  
9 year.

- 10 13. Regardless of whether this remote active management program is continued or not,  
11 the Company will be authorized to continue: (a) requiring new DERs to have IEEE  
12 1547-2018 compliant smart inverters per Paragraph 3, *supra*; (b) requiring new  
13 DERs to have DER management devices installed on them per Paragraph 4, *supra*;  
14 (c) utilizing the smart inverters' automated grid support functions per Paragraph 5,  
15 *supra*; and (d) monitoring the DERs that have the Company's DER management  
16 devices installed per Paragraph 5, *supra*.

17 **iv. Grandfathering of Current DER Installations and Interconnection**  
18 **Applications**

- 19 14. DER installations whose interconnection applications are submitted to PPL Electric  
20 before January 1, 2021, shall not be required to install smart inverters and DER  
21 management devices. However, the Company reserves the right to propose the  
22 application of its DER Management Plan to existing DERs in a future proceeding.

1           **C.     REPORTING REQUIREMENTS**

2                   **i.     Annual Reports Submitted to the Commission**

3           15.     PPL Electric will track and report the real power reductions experienced by  
4                   customers under the Company's DER Management Plan, including the 5-year  
5                   program for remote active management. Specifically, the Company will use the  
6                   real time output of the DER, the nameplate of the DER, and the duration of the  
7                   voltage regulation function to calculate the DER's generation loss.

8           16.     PPL Electric shall file annual reports that provide the following information for the  
9                   annual reporting period: (a) the aggregate amount of DERs' net generation loss  
10                  due to the use of the automated grid support functions set forth in Paragraph 5,  
11                  *supra*; (b) the aggregate amount of DERs' net generation loss due to the Company's  
12                  active management of the grid support functions set forth in Paragraph 9, *supra*; (c)  
13                  the method and technique used to calculate the DERs' net generation loss; (d) the  
14                  number of times each grid support function was used on an automated basis and the  
15                  average duration of that function's automated use; (e) the number of times that PPL  
16                  Electric actively managed each grid support function and the average duration that  
17                  the function was actively managed; and (f) the non-wires alternatives installed to  
18                  improve customer reliability or defer voltage control investments using DER  
19                  management, in lieu of traditional alternatives, for that annual reporting period.

20           17.     In addition, the annual report will set forth the number of DERs installed, the  
21                   number of DER management devices installed, and the capital costs and expenses  
22                   associated with the purchase, installation, ownership, and maintenance of the DER  
23                   management devices.



1           18.    The annual reports filed with the Commission shall not contain any identifying  
2                   customer information. The annual reports shall be filed within 30 days following  
3                   the end of each calendar year.

4                   **ii.    Annual Reports to Individual DER Customers**

5           19.    PPL Electric shall send an individualized annual report to each new DER customer,  
6                   whose smart inverter’s grid support functions are used by the Company during the  
7                   annual reporting period. The customer’s annual report shall provide the following  
8                   information for the annual reporting period: (a) the amount of the DER’s net  
9                   generation loss due to the use of the automated grid support functions set forth in  
10                  Paragraph 5, *supra*; (b) the aggregate amount of DERs’ net generation loss due to  
11                  the Company’s active management of the grid support functions set forth in  
12                  Paragraph 9, *supra*; (c) the method and technique used to calculate the DER’s net  
13                  generation loss; (d) the number of times each grid support function was used on an  
14                  automated basis and the average duration of that function’s automated use; and (e)  
15                  the number of times that PPL Electric actively managed each grid support function  
16                  and the average duration that the function was actively managed. In addition, for  
17                  the events where a Constant Power Factor is temporarily used to override an  
18                  existing Volt/VAR curve, the customer’s annual report will show the existing  
19                  Volt/VAR curve, the Volt/VAR curve that was temporarily used, and the duration  
20                  of the event. For the events where a new Volt/VAR curve is issued, the new curve  
21                  will be included in the report. The customer’s annual report will be sent to the  
22                  customer within 30 days following the cash-out of the customer’s banked excess

1 generation, which typically occurs at the end of each PJM Interconnection LLC  
2 (“PJM”) Planning Year.

3 **D. COMPLIANCE TARIFF SUPPLEMENT**

4 20. Upon Commission approval of the DER Management Petition, PPL Electric shall  
5 file a compliance tariff supplement consistent with PPL Electric Exhibit SS-1 and  
6 the terms outlined above. The compliance tariff supplement will be effective on  
7 one day’s notice.

8 **E. ELECTRIC VEHICLES**

9 21. Electric vehicles (“EVs”) shall be exempt from the requirements of Section B,  
10 *supra*.

11  
12 Again, the Company disagrees that a pilot program is necessary. However, if the  
13 Commission decides that such a pilot would be appropriate here, the Commission should  
14 direct PPL Electric to implement the program outlined above. It will enable PPL Electric  
15 to gather valuable data on the benefits of remote active management and present that data  
16 to the Commission, the other parties, and the Company’s customers. Such data can then  
17 be used to evaluate whether the Company should continue remotely managing the grid  
18 support functions beyond the 5-year program.

19  
20 **Q. DOES THIS CONCLUDE YOUR REJOINDER TESTIMONY AT THIS TIME?**

21 A. Yes, although I reserve the right to supplement my rejoinder testimony.

# Economic Analysis of DER for Voltage Management

- The objective of this analysis was to develop various scenarios and their cost benefits of PPL's DER Management proposal's active management of DERs

# Establishing Context for Distribution Cost For Voltage Control

- Distribution system voltage control costs vary significantly depending on locational factors, loads, the status of the rest of the power system, and DER penetration.
- Distribution system costs are higher when DERs are clustered together and located further from the substation.
- Distribution costs are higher in rural areas, which are currently more likely to be lightly loaded, have a lower rated capacity, and host larger PV systems located further from the substation
- PPL feeders require voltage management, especially as DER is added, because feeders are generally long, rural, and typically do not have Transformer Load Tap Changers (LTCs)
- Increased DER hosting capacity and voltage management can be achieved through communications and management of DERs enabled by the DER Management proposal

# Methodology

- One actual PPL feeder is used throughout this analysis to review various scenarios. The feeder characteristics
  - 1800 customers, mix of residential, commercial and industrial
  - Currently 100 kW of connected DER
  - Located in a geographic pocket that has been realizing DER growth
- Assumptions used for DER growth, capital costs and models are included in the Appendix.
- Some scenarios are shown with both conservative and aggressive rates to show impact at an adoption level near the current rate as well as with the potential for future accelerated growth.
- With assumed DER growth, multiple scenarios are evaluated to demonstrate the overall cost benefit of voltage management enabled by DER Management Petition.

# Hypothetical Ranges of DER Integration Costs

- Figure 1 is an illustration of three regions of PV integration costs:
  1. (near) zero cost when within the hosting capacity range
  2. increasing, quantifiable cost
  3. fuzzy cost domain
- Curve illustrates potential cost drivers
- The shape and magnitude of the curve is scenario dependent




Figure 1: Distribution System Costs Associated with Solar PV Adoption

Source: Distribution system costs associated with the deployment of photovoltaic systems by Kelsey A.W. Horowitz<sup>2</sup>, Bryan Palmintier, Barry Mather, Paul Denholm National Renewable Energy Laboratory (NREL), 15013 Denver West Parkway, Golden, CO 80401, USA, Elsevier Renewable and Sustainable Energy Reviews

# Summary of Cost Benefits

Multiple Scenarios are evaluated in this study to show the overall costs benefits of the DER Management Petition.

	Scenario/Situation	Traditional Costs	Costs with DER Management	Conservative DER Growth Cost Savings	Aggressive DER Growth Cost Savings	
Quantifiable Cost Domain	<b>Scenario 1</b>	Areas of aggressive small & large DER growth	\$48.6M over 10 years	\$25.2M over 10 years	<b>\$23.4M over 10 years</b>	<b>\$58.3M over 10 years</b>
	<b>Scenario 2</b>	Permanent Configuration Changes Yields Settings Modification Manual or Automated	\$4.5M over 20 years	\$0 over 20 years	<b>\$8.5M over 20 years</b>	<b>\$30.4M over 20 years</b>
	<b>Scenario 3</b>	Impact to DER Inverter Settings During Temporary Configurations and N-1 Emergencies	Customer's DER may be required to shut off during temporary configurations to maintain reliable grid	Customer's DER may lose revenue of \$2.65/year	<b>Customer's DER may be required to shut off during temporary configurations</b>	
Fuzzy Cost Domain	<b>Situation 1</b>	Unexpected System Fluctuations Due to Unforeseen Events	<b>Utilize the DER Management Plan to build flexibility into the distribution system to maintain safe and reliable service during unforeseen system instabilities or variations</b>			
	<b>Situation 2</b>	Large Scale Voltage and VAR Control Without Substation Transformer LTCs	<b>The transmission and distribution systems may see negative voltage or VAR impacts because most station transformers on PPL Electric's systems are not equipped with LTCs. Defer or avoid LTC additions with the DER Management Plan</b>			

## Scenario 1: *Impact to Voltage in Areas of Aggressive Small & Large DER growth*

- **Base Case Scenario, see Table 1**

- No DER Management
- Increasing small DER, 10 kW each, at a rate of 30% per year
- Increasing medium DER, 250 kW installation every year
- Increasing large DER, 1 MW installation every 3<sup>rd</sup> year

*Voltage remediation requirements:*

- Added Regulators in Years 3, 6, and 9
- \$60,000 in Year 3; \$60,000<sup>1</sup> in Year 6; \$60,000 in Year 9,
- **Total cost for voltage support over 10 years: \$180,000 (using traditional means to fix voltage)**

- **Alternative Scenario, see Table 1**

- DER Management
- Increasing small DER installations at a rate of 30% per year for residential systems (typical growth rate in Lancaster region)
- Increasing medium DER, 250 kW installation every year
- Increasing large DER, 1 MW installation every 3<sup>rd</sup> year


*Voltage remediation requirements:*

- \$0 in voltage support equipment in any year for at least 10 years
- **Cost of DER management devices over 10 years: \$112,000**

**Scenario 1 continued on the next page.**



## Scenario 1: Impact to Voltage in Areas of Aggressive Small & Large DER growth



### --- Cost/Benefit Impact ---

Voltage regulators to address for overvoltage in Years 3, 6, and 9, **without DER management:**

1. Total cost for voltage support over 10 years: \$180k
2. Extrapolated to 20% of PPL feeders:  $(1,350 \times 20\%) \times \$180k = \$48.6M$
3. Extrapolated to 50% of PPL feeders:  $(1,350 \times 50\%) \times \$180k = \$121.5M$

### With Remote DER Management:

1. \$0 in voltage support equipment in any year for at least 10 years
2. Cost of DER management devices over 10 years: \$93.6k
3. DER Management savings on just one feeder: \$86.4k or 48%
4. Extrapolated to 20% of PPL feeders:  $(1,350 \times 20\%) \times \$93.6k = \$25.2M$
5. Extrapolated to 50% of PPL feeders:  $(1,350 \times 50\%) \times \$93.6k = \$63.2M$

Conservative Total Savings to customers:  $\$48.6M - \$25.2M = \$23.4M$

Aggressive Total Cost Savings to customer:  $\$121.5M - \$63.2M = \$58.3M$

Table 1: DER Growth – Base Case Scenario vs Alternative Scenario

Year	kW @ 30% residential growth rate	Adding 250kW C&I growth/year	Adding 1MW DER every 3 years	Total DER installed (kW)	Quantity @ 30% residential, plus C&I and 1MW growth rate	Per year DER Management devices @ \$755/device	Total spent on DER Management Devices	Total Spent on Voltage Reinforcements required	% Savings : DER Mangement vs Voltage Reinforcements
Year 0	100.0			100	10	0			
Year 1	130.0	250.0	0	380	14	\$3,020			
Year 2	169.0	250.0	0	669	19	\$3,926			
Year 3	219.7	250.0	1000	1970	26	\$5,104	\$12,050	\$60,000	80%
Year 4	285.6	250.0	0	2286	35	\$6,635			
Year 5	371.3	250.0	0	2621	46	\$8,625			
Year 6	482.7	250.0	1000	3983	61	\$11,213	\$35,503	\$120,000	70%
Year 7	627.5	250.0	0	4377	80	\$14,577			
Year 8	815.7	250.0	0	4816	105	\$18,950			
Year 9	1060.4	250.0	1000	6310	138	\$24,635	\$93,665	\$180,000	48%
Year 10	1378.6	250.0	0	6879	180	\$32,026			

## Optimal Voltage Management from Centralized and Distributed Control

- The benefits in Scenario 1, can not be fully realized with autonomous settings that are set initially and remained unmanaged throughout the life-cycle.
- As shown in the Drexel University studies summarized in PPL Electric Exhibit SS-1RJ, DER injections can lead to voltage issues at other distribution locations, which can not be mitigated with pre-set Volt/Var curves contribution at the DER location.
- This highlights the importance of centralized system to manage voltage remotely, like PPL Electric's DERMS, as well as localized voltage management capabilities that can be provided by DERs to maintain distribution voltage within operational tolerances.

## Scenario 2: Permanent Feeder Configuration Changes Yields Volt/VAR Modification Manual vs. Automated




Figure 2: Feeder with high DER penetration




Figure 3: Scenario 2 Base Case Volt/VAR curve

- **Scenario 2 Base Case**

- Feeder shown in Figure 2 is has approximately 1,800 customers, mix of residential, commercial, and industrial.
- Volt/VAR curves issued at interconnection for customers in the circles have lower dead bands as they are between 8 and 12 miles from the substation where voltage is typically lower, as shown in Figure 3, where voltage is typically 0.96 p.u. (115.2V).

## Scenario 2: Permanent Feeder Configuration Changes Yields Volt/VAR Modification Manual vs. Automated




Figure 4: A New substation is built, splitting the feeder in two, with high DER Penetration

### Scenario 2 Future State – A split of the Feeder

- Feeder shown in red is served by the upper substation as it is in the base case.
- Feeder in black is now served by the lower “new substation”.
- The red feeder length, shown in Figure 4, is reduced to 40% of its original length, now with 800 customers. The black feeder is approximately 60% of the original feeder with 1000 customers. Both have a mix of residential, commercial and industrial customers.
- Volt/VAR curves issued for customers in the circles have higher dead bands, as shown in Figure 5, as they are within 0 – 3 miles of the new substation where voltage is typically near 1.03 p.u. (123.6V)
- DER default settings issued at interconnection are no longer adequate and are required to be changed.
- **Modification of Volt/VAR provides benefit to the customer and PPL as the curve should fit the customer’s location and typical voltage on the system in order to maintain unity power factor as much as possible.**




Figure 5: Scenario 2 Future State Volt/VAR curve

### --- Cost/Benefit Impact ---

1. Manual Volt/VAR modification by visiting each DER site and adjusting inverter settings: ~\$225 per solar PV
2. Feeder in Figure 4 includes 35 inverters requiring Volt/VAR modification
3. Due to the dynamic nature of PPL’s system, 4 or more Volt/VAR modifications may occur over the 20-year life of a system on 20% of PPL’s feeders (~1350 total)

#### Conservative:

\$225 x 35 inverters x 4 changes over life of systems = **\$31.5k**

If this level of change occurs on 20% of PPL feeders:  
 $\$31.5k \times (1350 \text{ feeders} \times 20\%) = \mathbf{\$8.5M \text{ over 20 years}}$

Modification of Volt/VAR settings using DERMs through PPL’s DER management costs **\$0 over 20 years**

#### Aggressive:

\$225 x 50 inverters x 4 changes over life of systems = **\$45k**

If this level of change occurs on 50% of PPL feeders:  
 $\$45k \times (1350 \text{ feeders} \times 50\%) = \mathbf{\$30.4M \text{ over 20 years}}$

## Scenario 3: Impact to Voltage and Volt/VAR Settings During Temporary Configurations and N-1 Emergencies

Key

 = Installed Solar PV DER




Figure 6: Two Feeders both with high DER penetrations




Figure 7: Volt/VAR Scenario 2 Base Case

### Scenario 3 Base Case:

- Substation A serves Feeder A (shown in black)
- Substation B serves Feeder B (shown in yellow)
- Multiple feeders with high penetration (>5000kW) in the same geographic area
- Upon interconnection, the solar PV DER within the circle shown in Figure 6 are provided the autonomous Volt/VAR curve shown in Figure 7 due to the proximity of the source (substation B with an average voltage p.u. of 1.03 or 123.6V)
- N-1 is defined a form of resilience which ensures distribution system availability in the event of one component failure. A temporary transfer occurs as part of an N-1 reliability driven plan

## Scenario 3: Impact to Voltage and Volt/VAR Settings During Temporary Configurations and N-1 Emergencies




Figure 8: Two Feeders both with high DER penetrations




Figure 9: Volt/VAR Scenario 2 Base Case

### Scenario 3 Event (alternative 1)

- Autonomous Volt/VAR settings are in use on all DERs.
- Feeder B is transferred to Feeder A due to maintenance.
- Autonomous Volt/VAR settings are in use on all DERs.
- The solar PV installations shown in DER Set 1, continue operating on their autonomous Volt/VAR curves during the temporary transfer.
- As DER Set 1 is no longer in close proximity to the source, those DERs' typical operating voltage is 0.965 p.u. (115.8V). Therefore, the Volt/Var settings for DER Set 1 needs to be changed.

### --- Cost/Benefit Impact ---

#### 1. Assume:

- All generators in DER Set 1 are 100kW.
- See all assumptions in Salet Rebuttal Exhibit SS-2R

100kW x 4 hr/year = 400kWh (Assumptions 1 and 2 from Exhibit SS-2R)

400kWh x 10% = 40kWh (Assumption 3 from Exhibit SS-2R)

40kWh x \$0.0663 cent/kWh = \$2.65 revenue reduction/year (Assumption 4 from Exhibit SS-2R)

Without active DER management, DERs may be asked to shut off and remain off during abnormal configurations and N-1 Emergencies because the DERs may operate at an inappropriate power factor due to the applied Volt/VAR curve. With active management, DERMS will send new settings to these DER to maintain reliability and keep the DERs operational.

## Situation 1: *Unexpected System Fluctuations Due to Unforeseen Events*

When studying and planning for the impacts of DERs, the Company's Distribution Planning and Engineering team delineates system upgrades, protection requirements, and voltage settings and reinforcements based on historic and projected peak and daytime minimum loads and voltage as well as known system changes (including new loads, DER, reconfigurations, system upgrades, etc.) Without visibility of DERs, performing planning functions is extremely difficult due to issues such as hidden load. However, not all system fluctuations can be predicted. Unprecedented events, such as the recent coronavirus pandemic, have unquestionably altered electric demand as cities are locked down, shops close, and industry significantly slows or halts.

A preliminary coronavirus electric demand impact study for Italy in March 2020 shows a peak and daily energy use reduction of 18 – 21% compared to the same weeks of the prior year. At the time of this writing, worldwide electric system impacts are not yet fully experienced or appreciated. However, PPL Electric has preliminary load data that mimic Italy's experience.

System upgrades, protection requirements, and voltage settings and reinforcements are based on daytime minimum loads. When those loads are further reduced by 20%, especially during spring or autumn months, the system is operating in a way in which it was not planned, engineered, or designed. Without real time visibility and management of DERs, a system with higher DER penetration will certainly face real-time operating challenges that could cause overvoltage, overloads, equipment damage, and outages.

During an unexpected event like the coronavirus pandemic that impacts load dramatically, PPL Electric could change inverter settings as needed to operate within voltage tolerances. The DER Management Plan would provide operating flexibility to continue to provide reliable service, even if life-sustaining supply shortages change future customer behavior and drive consumer demand for more DERs that provide a capability for self-sufficient existence. By proceeding with the DER Management Plan, PPL can be more adaptable to meet customers' needs for a flexible, reliable, and fully integrated distribution system.

*Source: "COVID-19 Impacts and Actions: Preliminary Analysis of Italy Load Trends Summary of Industry Response, by Aidan Tuohy, Adrian Kelly, Brian Deaver, Eamonn Lannoye, Daniel Brooks, Electric Power Research Institute (EPRI), 19 March 2020.*

## Situation 2: Large Scale Voltage and VAR Control Without Substation Transformer LTCs

PPL Electric is mandated to maintain voltage at  $\pm 5\%$ , per ANSI C84.1 and PUC requirements.

System conditions at PPL Electric make voltage management a challenge

- Average feeder length is 27 miles long
  - Other Pennsylvania EDCs have average feeder lengths which are significantly shorter
- Past practice design includes few Load Tap Changers (LTCs) on station transformers
  - Inability to actively manage voltage at the head of a circuit
  - Heavily reliant on capacitors to control voltage
  - Dependent on transmission voltage

Managing voltage

- Limited options to manage the voltage
- Overvoltage conditions can only be effectively managed with overhead line regulators (\$60,000 per regulator)
- Leverage automated capacitor banks and regulators for voltage control
- Voltage profiles can swing widely, especially on the end of a feeder
  - *Due to the nature and seasonality of loads on the distribution system, voltages may swing significantly between seasons*
  - *Example: One feeder may see loads exceeding 10.5MW in the winter and less than 1MW in the spring/fall.*

In the event of high DER penetration on multiple feeders out of the same substation, the transmission and distribution systems may see negative voltage or VAR impacts as most station transformers on PPL Electric's systems are not equipped with LTCs. Along with some wide and significant swings between peak and daytime minimum load, an LTC transformer may be required to be installed to maintain acceptable voltage year-round without autonomous Volt/VAR. **Cost of \$1.1M**

- With remote DER management, this cost could be deferred for up to 10 years as DERMS will be able to manage voltage and VAR flow on the system in real time.
- Extrapolated to 5% of PPL substations (~350 Substations) = **\$19.3M, showing significant financial value is possible from a 10-year deferral**





# Appendix

## Assumptions

- **DER growth rate**
  - Over the last 5 years, PPL has seen an average DER growth rate of 25% per year. This study assumes 30% DER growth for residential customers, as some of PPL see growth rates higher than average. The DER growth rate in 2019 was 28% over 2018 suggesting that these are reasonable DER growth rates.
- **Installed capital cost**
  - **ConnectDER:** The cost of an installed ConnectDER is \$755. In this study it is assumed the ConnectDER cost will remain constant for the next ten years.
  - **Regulator:** The cost of an installed regulator is \$60,000. In this study it is assumed this cost will remain constant for the next ten years.
  - **LTC:** The cost of an installed LTC transformer \$1.1M
- **Models**
  - The models in these studies were built to determine at what level randomly placed DER will cause overvoltage and require system upgrades.
  - System upgrades are heavily dependent on the location and size of the DER, which is impossible to accurately predict. This methodology, with DER randomly placed on the feeder, yields the need for system upgrades at a slower rate than if DER were they were clustered together. In industry and economic research strongly suggests a strong relationship between solarPV adoption and the number of nearby previously installed system (as well as other factors)
  - The models in this study were built to reflect conservative projections of DER growth and penetration. Pockets of the Company's system will experience aggressive DER growth over time. To reflect this, aggressive DER growth is extrapolated.

*Source: Marcello Graziano, Kenneth Gilligham, "Spatial Patters of Solar Photovoltaic System Adoption: The Influence of Neighbors and the Built Environment", Journal of Economic Geography, 2015, pp 815-839.*